

ST WOLFGANG, Austria

WMO: 113570

Lat: 47.740N

Lon: 13.442E

Elev: 1781

StdP: 13.77

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.6	18.6	10.3	9.9	16.9	14.5	12.3	20.9	14.2	39.8	12.3	37.4	2.3	20	0.460

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	85.1	68.9	81.7	67.0	78.7	65.6	70.0	82.4	68.4	79.2	66.9	76.4	4.5	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.1	102.7	75.1	64.6	97.3	73.2	63.2	92.7	71.4	35.1	82.4	33.6	79.5	32.4	76.4	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.7	9.2	7.6	DB	11.0	90.7	6.8	3.0	6.1	92.9	2.2	94.6	-1.7	96.3	-6.6	98.5
			WB	10.1	73.1	6.6	1.8	5.3	74.4	1.4	75.5	-2.3	76.5	-7.1	77.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.5	31.5	33.7	40.2	49.1	56.9	63.2	66.5	66.1	58.5	51.5	41.9	34.4	(6)
	DBStd	14.03	6.42	6.99	6.98	7.48	6.67	6.99	5.97	6.02	6.17	6.31	7.05	6.10	(7)
	HDD50	2273	574	457	309	105	16	2	0	0	6	60	260	484	(8)
	HDD65	5926	1038	877	770	478	261	116	55	60	210	419	694	948	(9)
	CDD50	2103	0	0	4	78	230	398	511	500	260	106	15	1	(10)
	CDD65	283	0	0	0	0	11	62	101	94	14	1	0	0	(11)
	CDH74	1992	0	0	0	15	103	468	712	627	63	4	0	0	(12)
	CDH80	485	0	0	0	1	12	113	185	167	7	0	0	0	(13)
(14) Wind	WSAvg	2.8	3.1	2.8	2.9	2.9	2.8	2.9	3.0	2.7	2.6	2.6	2.7	2.8	(14)
(15) Precipitation	PrecAvg	60.9	3.6	3.4	4.7	3.8	5.7	7.2	8.0	7.2	5.8	4.1	3.8	3.7	(15)
	PrecMax	69.5	9.1	8.8	9.9	6.2	10.1	11.9	15.4	13.6	11.0	7.7	8.4	9.6	(16)
	PrecMin	49.3	0.3	1.3	2.0	1.2	1.4	3.8	3.7	4.1	2.4	1.2	0.5	1.3	(17)
	PrecStd	5.1	2.1	1.8	2.1	1.4	2.1	2.0	2.7	2.0	2.0	1.6	1.7	1.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.6	55.5	64.4	75.8	81.6	87.7	89.4	89.1	79.8	72.5	67.7	56.3	(19)
		MCWB	45.6	44.3	50.2	57.7	64.7	69.7	70.2	70.4	65.9	58.7	52.9	45.4	(20)
	2%	DB	45.9	49.6	59.1	70.6	76.9	83.1	84.8	84.6	75.2	67.1	61.0	47.7	(21)
		MCWB	40.6	42.1	47.8	55.1	62.0	67.4	68.9	68.9	63.4	56.8	50.4	42.7	(22)
	5%	DB	42.1	45.5	54.8	66.5	72.7	79.4	81.3	80.6	71.7	63.7	55.3	44.3	(23)
		MCWB	39.0	39.7	45.7	53.3	59.7	65.6	67.2	67.0	61.9	55.3	48.4	41.6	(24)
	10%	DB	39.3	42.2	50.6	62.3	68.9	75.6	77.8	77.1	68.3	60.5	51.2	41.8	(25)
		MCWB	37.1	38.4	43.7	51.1	57.7	63.8	65.7	65.7	60.3	54.2	47.1	39.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.3	45.6	51.5	58.5	66.4	71.2	72.5	72.2	67.4	60.4	53.8	46.6	(27)
		MCDB	51.5	53.5	61.8	73.5	78.1	85.3	84.9	85.2	75.8	67.9	64.7	53.3	(28)
	2%	WB	41.4	42.7	48.6	55.9	63.7	68.7	70.1	69.8	64.8	58.4	51.3	44.1	(29)
		MCDB	44.5	47.9	56.7	68.8	74.6	80.4	82.2	81.9	72.7	64.7	58.9	47.1	(30)
	5%	WB	39.1	40.5	46.6	53.9	61.0	66.9	68.3	68.1	63.0	56.7	49.2	41.6	(31)
		MCDB	41.6	44.6	53.2	64.4	70.1	76.9	78.9	78.8	69.6	61.8	54.1	44.0	(32)
	10%	WB	37.3	38.6	44.6	52.0	58.9	64.9	66.7	66.5	61.3	55.0	47.3	39.6	(33)
		MCDB	39.2	41.7	49.8	60.6	66.8	73.6	75.8	75.5	66.8	59.7	51.2	41.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.6	11.1	13.9	16.4	15.6	15.6	16.1	15.8	13.7	13.4	10.0	8.0	(35)
		MCDBR	11.8	17.5	22.8	25.1	23.6	23.4	22.9	22.5	19.2	18.5	17.0	11.9	(36)
	5% WB	MCWBR	7.9	10.7	12.2	11.3	10.3	9.4	8.9	8.9	9.0	9.5	9.2	7.8	(37)
		MCWBR	11.2	15.2	21.1	22.9	21.3	21.6	21.0	21.2	17.7	17.0	15.1	11.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.288	0.317	0.358	0.392	0.405	0.410	0.413	0.406	0.376	0.345	0.316	0.288	(40)
		taud	2.399	2.324	2.283	2.262	2.273	2.300	2.290	2.329	2.385	2.452	2.474	2.446	(41)
	Ebn at Noon		252	266	271	272	272	271	268	265	263	254	239	238	(42)
		Edh at Noon	22	29	35	40	41	40	40	37	32	25	20	18	(43)
(44) All-Sky Solar Radiation	RadAvg		385	684	998	1315	1505	1661	1667	1481	1074	737	404	308	(44)
	RadStd		51	87	118	165	180	170	164	174	144	78	62	47	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (94 neighbors)	+0.81	N/A	N/A	N/A	+0.68	+0.67	N/A	N/A	+119	+54

Nomenclature: See separate page