

ST WOLFGANG, Austria

WMO: 113570

Lat: 47.740N

Lon: 13.442E

Elev: 543

StdP: 94.97

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.7	-7.5	-12.1	1.4	-8.4	-9.7	1.8	-6.2	6.3	4.4	5.5	3.0	1.0	20	0.460

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	29.5	20.5	27.6	19.5	26.0	18.7	21.1	28.0	20.2	26.2	19.4	24.7	2.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	14.7	23.9	18.1	13.9	22.9	17.3	13.2	21.9	63.8	28.0	60.4	26.4	57.5	24.7	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.8	4.1	3.4	DB	-11.6	32.6	3.8	1.7	-14.4	33.8	-16.6	34.8	-18.7	35.7	-21.4	37.0	(4)
(5)			WB	-12.2	22.8	3.7	1.0	-14.8	23.5	-17.0	24.1	-19.1	24.7	-21.7	25.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	-0.3	0.9	4.5	9.5	13.8	17.3	19.2	19.0	14.7	10.8	5.5	1.3	(6)	
	DBStd	7.80	3.56	3.88	3.88	4.16	3.71	3.88	3.32	3.34	3.43	3.51	3.91	3.39	(7)	
	HDD10.0	1263	319	254	172	58	9	1	0	0	3	33	144	269	(8)	
	HDD18.3	3292	577	487	428	266	145	64	31	33	117	233	386	527	(9)	
	CDD10.0	1168	0	0	2	43	128	221	284	278	144	59	8	1	(10)	
	CDD18.3	157	0	0	0	0	6	34	56	52	8	1	0	0	(11)	
	CDH23.3	1107	0	0	0	8	57	260	396	348	35	2	0	0	(12)	
	CDH26.7	269	0	0	0	1	7	63	103	93	4	0	0	0	(13)	
(14) Wind	WSAvg	1.3	1.4	1.2	1.3	1.3	1.3	1.3	1.3	1.2	1.1	1.2	1.2	1.2	(14)	
(15) Precipitation	PrecAvg	1546	91	87	119	96	144	182	203	183	148	103	96	95	(15)	
	PrecMax	1766	230	223	252	158	256	302	390	345	280	195	214	243	(16)	
	PrecMin	1251	8	32	51	30	35	97	94	103	60	30	12	33	(17)	
	PrecStd	129	54	46	54	36	53	51	68	51	52	41	43	45	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	13.1	18.0	24.3	27.6	30.9	31.9	31.7	26.6	22.5	19.9	13.5	(19)	
		MCWB	7.6	6.8	10.1	14.3	18.2	20.9	21.2	21.3	18.8	14.8	11.6	7.5	(20)	
	2%	DB	7.7	9.8	15.1	21.4	24.9	28.4	29.3	29.2	24.0	19.5	16.1	8.7	(21)	
		MCWB	4.8	5.6	8.8	12.8	16.7	19.7	20.5	20.5	17.5	13.8	10.2	5.9	(22)	
	5%	DB	5.6	7.5	12.7	19.1	22.6	26.3	27.4	27.0	22.1	17.6	12.9	6.8	(23)	
		MCWB	3.9	4.3	7.6	11.8	15.4	18.7	19.5	19.5	16.6	12.9	9.1	5.4	(24)	
	10%	DB	4.1	5.7	10.3	16.8	20.5	24.2	25.5	25.0	20.2	15.8	10.7	5.4	(25)	
		MCWB	2.8	3.5	6.5	10.6	14.3	17.7	18.7	18.7	15.7	12.3	8.4	4.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	7.6	10.8	14.7	19.1	21.8	22.5	22.3	19.7	15.8	12.1	8.1	(27)	
		MCDB	10.9	11.9	16.5	23.0	25.6	29.6	29.4	29.5	24.3	19.9	18.2	11.8	(28)	
	2%	WB	5.2	5.9	9.2	13.3	17.6	20.4	21.1	21.0	18.2	14.7	10.7	6.7	(29)	
		MCDB	7.0	8.8	13.7	20.4	23.7	26.9	27.9	27.7	22.6	18.2	14.9	8.4	(30)	
	5%	WB	4.0	4.7	8.1	12.2	16.1	19.4	20.2	20.1	17.2	13.7	9.6	5.4	(31)	
		MCDB	5.3	7.0	11.8	18.0	21.2	24.9	26.1	26.0	20.9	16.5	12.3	6.7	(32)	
	10%	WB	3.0	3.7	7.0	11.1	14.9	18.3	19.3	19.2	16.3	12.8	8.5	4.2	(33)	
		MCDB	4.0	5.4	9.9	15.9	19.3	23.1	24.3	24.2	19.4	15.4	10.7	5.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	6.1	7.7	9.1	8.7	8.7	8.9	8.8	7.6	7.5	5.5	4.5	(35)	
		MCDBR	6.6	9.7	12.7	14.0	13.1	13.0	12.7	12.5	10.7	10.3	9.5	6.6	(36)	
	5% WB	MCWBR	4.4	6.0	6.8	6.3	5.7	5.2	5.0	4.9	5.0	5.3	5.1	4.4	(37)	
		MCWBR	6.2	8.4	11.7	12.7	11.8	12.0	11.6	11.8	9.8	9.4	8.4	6.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.288	0.317	0.358	0.392	0.405	0.410	0.413	0.406	0.376	0.345	0.316	0.288	(40)	
		taud	2.399	2.324	2.283	2.262	2.273	2.300	2.290	2.329	2.385	2.452	2.474	2.446	(41)	
	Ebn at Noon		794	840	855	858	859	855	845	836	828	801	755	751	(42)	
		Edh at Noon	68	91	111	125	129	126	126	116	100	80	64	58	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.22	2.15	3.15	4.14	4.74	5.24	5.26	4.67	3.39	2.32	1.27	0.97	(44)	
	RadStd		0.16	0.27	0.37	0.52	0.57	0.54	0.52	0.55	0.46	0.24	0.20	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (94 neighbors)		+0.45	N/A	N/A	N/A	+0.38	+0.37	N/A	N/A	+66	+30

Nomenclature: See separate page