

HOHE WAND HOCHKOGELHAUS, Austria

WMO: 113850

Lat: 47.822N

Lon: 16.035E

Elev: 937

StdP: 90.56

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.1	-10.0	-15.9	1.0	-8.9	-13.3	1.3	-7.1	11.7	-8.1	10.4	-6.7	4.6	300	0.585

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	27.3	18.9	25.3	18.1	23.6	17.2	19.9	25.4	18.8	24.1	17.8	22.7	3.7	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	14.4	23.4	16.8	13.4	22.0	15.7	12.5	20.8	61.4	25.6	57.4	24.1	54.0	22.8	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	9.1	7.9	-13.4	30.4	2.6	2.5	-15.3	32.2	-16.8	33.7	-18.3	35.1	-20.2	36.9		
(5)			-14.2	21.9	2.6	1.2	-16.0	22.8	-17.5	23.5	-18.9	24.1	-20.8	25.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-1.7	-0.5	2.4	7.7	11.7	15.3	17.1	17.3	12.5	8.6	4.1	0.2		
	DBStd	8.07	4.93	5.32	4.96	4.94	4.25	4.24	3.90	3.94	4.18	4.73	4.71	4.84		
	HDD10.0	1627	363	294	238	99	32	6	1	1	22	84	184	303		
	HDD18.3	3890	621	527	493	321	209	111	71	67	181	302	427	561		
	CDD10.0	873	0	1	3	29	83	164	221	228	96	41	7	1		
	CDD18.3	93	0	0	0	0	3	18	33	35	4	0	0	0		
	CDH23.3	442	0	0	0	0	7	75	169	179	12	0	0	0		
	CDH26.7	84	0	0	0	0	1	10	33	39	2	0	0	0		
(14) Wind	WSAvg	3.4	3.4	3.5	3.3	3.6	3.8	3.4	3.6	3.4	3.3	3.1	3.2	3.1		
(15) Precipitation	PrecAvg	775	41	37	52	52	85	101	95	88	69	55	54	46		
	PrecMax	987	111	96	128	112	179	204	215	166	196	98	119	99		
	PrecMin	525	4	2	15	8	19	31	10	23	10	10	0	6		
	PrecStd	116	26	25	32	25	40	45	48	36	40	27	24	21		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	13.1	15.8	21.5	24.2	28.0	29.7	30.2	24.8	21.0	16.1	12.3		
		MCWB	6.1	6.4	9.2	13.3	16.5	19.5	19.7	18.8	17.6	13.7	9.9	6.2		
	2%	DB	9.2	10.4	13.4	18.6	22.0	25.5	27.1	27.4	22.2	18.6	14.0	9.9		
		MCWB	4.8	4.8	7.7	11.8	15.5	18.5	19.1	18.7	16.3	12.7	9.1	5.2		
	5%	DB	7.3	8.5	11.1	16.6	20.0	23.5	25.0	25.1	19.9	16.6	12.2	8.3		
		MCWB	3.9	4.2	6.4	10.5	14.4	17.4	18.1	17.9	15.1	11.9	8.4	4.5		
	10%	DB	5.3	6.6	9.1	14.5	18.2	21.7	23.1	23.3	18.0	14.8	10.6	6.9		
		MCWB	2.8	3.2	5.4	9.3	13.2	16.4	17.3	17.0	14.0	11.1	7.4	3.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.0	7.2	9.7	13.9	17.9	20.9	21.6	21.1	18.3	14.9	11.1	7.4		
		MCDB	9.8	11.4	15.0	20.4	22.9	25.6	27.6	27.6	23.2	19.4	14.3	10.4		
	2%	WB	5.5	5.8	8.1	12.3	16.1	19.2	20.0	19.5	16.8	13.5	9.8	6.2		
		MCDB	8.4	9.4	12.5	17.7	20.8	24.3	25.5	25.5	21.0	17.3	12.9	8.9		
	5%	WB	4.3	4.6	6.9	11.0	14.9	17.9	18.8	18.5	15.6	12.5	8.7	5.2		
		MCDB	6.9	7.8	10.3	15.7	19.3	22.9	23.8	24.0	19.1	15.8	11.6	7.7		
	10%	WB	3.0	3.5	5.8	9.8	13.5	16.7	17.6	17.4	14.5	11.4	7.7	4.0		
		MCDB	5.1	6.3	8.6	13.8	17.5	21.1	22.5	22.4	17.6	14.3	10.1	6.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	5.1	5.9	7.2	7.2	7.3	7.6	7.6	6.4	5.9	4.9	5.0		
		MCDBR	6.7	7.1	8.6	9.5	9.5	9.5	10.2	10.2	9.0	7.8	6.8	7.0		
	5% WB	MCWBR	4.3	4.5	5.5	5.6	5.8	5.8	5.4	5.4	5.5	4.9	4.3	4.5		
		MCWBR	6.1	6.4	8.0	8.8	9.2	8.8	9.4	9.6	8.5	7.2	6.2	6.4		
(40) Clear-Sky Solar Irradiance	taub		0.278	0.300	0.334	0.371	0.372	0.378	0.382	0.381	0.357	0.331	0.307	0.278		
		taud	2.448	2.420	2.374	2.310	2.339	2.347	2.332	2.349	2.399	2.460	2.491	2.482		
	Ebn at Noon		814	867	884	880	890	884	874	859	848	817	769	770		
		Edh at Noon	64	82	101	119	120	120	121	114	98	79	62	56		
(44) All-Sky Solar Radiation	RadAvg		1.08	1.92	3.04	4.36	5.11	5.57	5.45	4.86	3.49	2.24	1.19	0.86		
	RadStd		0.12	0.25	0.37	0.45	0.55	0.42	0.48	0.50	0.43	0.23	0.13	0.11		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (92 neighbors)	+0.55	N/A	N/A	+0.83	+0.44	+0.40	-117	-150	+84	+45

Nomenclature: See separate page