

ST POELTEN LANDHAUS, Austria

WMO: 113890

Lat: 48.200N

Lon: 15.631E

Elev: 270

StdP: 98.13

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.9	-8.3	-13.7	1.2	-10.1	-11.1	1.5	-7.5	11.2	3.9	10.2	3.9	2.0	180	0.509

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	31.4	21.3	29.3	20.3	27.6	19.5	21.9	29.6	20.9	28.0	20.1	26.4	3.0	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.4	25.4	18.4	13.7	24.3	17.7	13.1	23.3	65.2	29.7	61.6	28.1	58.7	26.5	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	8.0	7.1	-13.8	34.4	3.9	1.9	-16.6	35.7	-18.8	36.8	-21.0	37.9	-23.8	39.3		
(5)			-14.1	23.7	3.8	0.9	-16.9	24.4	-19.1	24.9	-21.2	25.4	-23.9	26.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	-0.6	1.4	5.6	10.6	14.9	18.5	20.2	20.3	15.2	10.1	5.1	0.7
	DBStd	8.33	4.29	4.70	4.20	4.19	3.61	3.68	3.28	3.33	3.42	3.84	3.89	4.24
	HDD10.0	1252	328	241	145	43	3	1	0	0	2	47	154	288
	HDD18.3	3188	586	473	396	234	116	42	19	18	105	256	398	546
	CDD10.0	1329	0	1	8	60	157	256	316	318	157	50	7	0
	CDD18.3	224	0	0	0	1	11	48	77	78	10	0	0	0
	CDH23.3	1923	0	0	0	23	107	429	636	651	74	2	0	0
	CDH26.7	588	0	0	0	2	14	132	208	220	11	0	0	0
Wind	WSAvg	3.0	3.5	3.4	3.4	3.0	3.0	2.9	3.1	2.6	2.7	2.7	3.0	3.2
Precipitation	PrecAvg	690	32	34	45	53	73	87	91	85	58	40	50	43
	PrecMax	919	65	92	103	152	171	229	217	290	147	161	119	114
	PrecMin	462	1	4	9	10	16	35	20	17	10	1	9	6
	PrecStd	113	18	20	23	35	35	40	44	48	33	27	24	21
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.5	14.0	19.7	26.0	28.5	32.7	33.8	34.2	28.1	22.6	17.8	11.7
		MCWB	8.1	8.9	11.5	15.6	18.8	21.6	21.7	21.0	19.3	15.9	12.4	8.6
	2%	DB	9.0	11.8	16.7	23.0	26.2	30.3	31.1	31.2	25.5	19.5	14.7	9.6
		MCWB	6.5	8.0	10.5	14.4	17.9	21.2	21.2	21.1	18.1	14.6	11.0	7.4
	5%	DB	7.0	9.8	14.2	20.4	24.2	27.9	28.9	29.1	23.2	17.4	12.5	7.6
		MCWB	5.1	6.7	9.2	13.1	16.9	19.8	20.0	20.3	17.2	13.8	10.1	5.9
	10%	DB	5.2	7.9	12.0	18.2	22.2	25.8	27.0	27.0	21.2	15.5	10.4	6.0
		MCWB	3.8	5.5	8.3	12.0	15.7	18.7	19.4	19.5	16.0	12.9	8.7	4.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	9.6	12.3	16.3	20.1	23.2	23.0	22.9	20.0	16.6	13.0	8.9
		MCDB	11.0	12.7	17.9	24.7	27.0	30.7	31.3	31.2	25.9	20.9	16.8	10.9
	2%	WB	6.8	8.2	10.8	14.8	18.5	21.6	21.8	21.6	18.6	15.3	11.5	7.6
		MCDB	8.8	11.4	15.8	21.9	24.7	28.8	29.4	29.4	24.6	18.6	14.2	9.4
	5%	WB	5.3	7.0	9.7	13.6	17.3	20.4	20.7	20.7	17.6	14.2	10.1	6.0
		MCDB	6.8	9.5	13.3	19.6	23.0	26.9	27.4	27.8	22.3	16.7	12.3	7.4
	10%	WB	3.8	5.6	8.6	12.4	16.3	19.2	19.8	19.8	16.6	13.2	8.7	4.7
		MCDB	5.1	7.8	11.7	17.3	21.2	24.8	25.8	26.1	20.3	15.4	10.4	5.9
Mean Daily Temperature Range	5% DB	MDBR	4.2	5.9	8.0	9.7	9.7	9.8	9.8	10.2	8.5	7.0	4.9	4.1
		MCDBR	6.3	9.1	12.9	14.5	13.9	13.9	14.1	14.1	12.5	10.1	8.2	6.2
		MCWBR	4.7	6.0	7.3	7.1	6.6	6.0	5.5	5.5	5.9	5.7	5.3	4.7
	5% WB	MCDBR	6.1	8.4	11.5	13.4	12.9	13.3	12.6	13.1	11.5	9.3	7.7	6.2
		MCWBR	4.7	5.8	6.9	6.8	6.4	6.0	5.4	5.5	5.6	5.6	5.2	4.9
Clear-Sky Solar Irradiance	taub	0.305	0.329	0.370	0.412	0.414	0.420	0.426	0.423	0.395	0.363	0.335	0.305	
	taud	2.397	2.349	2.291	2.224	2.261	2.279	2.263	2.288	2.336	2.405	2.436	2.437	
	Ebn at Noon	765	822	840	837	850	845	833	818	805	773	720	719	
	Edh at Noon	68	88	110	130	130	129	129	121	105	84	66	58	
All-Sky Solar Radiation	RadAvg	1.04	1.92	2.98	4.28	4.97	5.43	5.28	4.72	3.38	2.15	1.13	0.84	
	RadStd	0.14	0.25	0.37	0.49	0.57	0.46	0.50	0.49	0.43	0.23	0.13	0.10	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (98 neighbors)		+0.71	N/A	N/A	+1.22	+0.51	+0.37	-188	-258	+155
		+0.53	N/A	N/A	N/A	+0.42	+0.36	-120	-150	+78

Nomenclature: See separate page