

CHEB, Czech Republic

WMO: 114060

Lat: 50.0683N

Lon: 12.3914E

Elev: 1608

StdP: 13.86

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.8	14.0	4.1	7.2	11.4	9.1	9.3	16.0	19.8	42.3	17.6	38.7	2.8	0	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	86.2	65.6	82.2	64.0	78.8	63.0	67.3	80.7	65.7	78.2	64.3	75.9	5.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.0	91.4	70.9	61.5	86.6	69.6	60.1	82.4	68.2	32.6	80.5	31.4	78.4	30.3	75.9	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.6	13.6	11.9	3.0	92.2	6.7	3.4	-1.8	94.6	-5.7	96.6	-9.5	98.5	-14.4	101.0		
(5)			2.4	70.6	6.6	2.0	-2.4	72.1	-6.2	73.2	-10.0	74.4	-14.8	75.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	47.1	29.5	31.9	38.6	47.1	54.9	60.8	64.2	63.7	56.0	47.5	38.3	31.8	(6)
(7)		DBStd	14.12	8.22	8.15	6.98	7.43	6.56	6.65	6.17	5.83	6.01	6.77	6.23	7.59	(7)
(8)		HDD50	2726	634	506	357	141	27	3	0	0	13	129	352	564	(8)
(9)		HDD65	6700	1099	926	819	539	320	160	92	95	277	543	801	1029	(9)
(10)		CDD50	1668	0	0	2	52	178	326	441	425	191	51	2	0	(10)
(11)		CDD65	168	0	0	0	0	6	34	68	55	5	0	0	0	(11)
(12)		CDH74	2059	0	0	0	13	110	435	762	646	92	1	0	0	(12)
(13)		CDH80	584	0	0	0	1	14	119	249	190	11	0	0	0	(13)
(14)	Wind	WSAvg	5.5	6.4	6.3	6.3	5.6	5.3	4.9	4.9	4.5	4.5	5.1	5.7	6.3	(14)
(15)	Precipitation	PrecAvg	22.2	1.4	1.1	1.4	1.4	2.1	2.7	2.6	2.6	1.9	1.6	1.6	1.8	(15)
(16)		PrecMax	29.5	3.5	2.8	3.9	3.3	5.2	5.6	5.9	5.2	4.4	5.0	3.3	4.4	(16)
(17)		PrecMin	13.7	0.1	0.2	0.4	0.4	0.5	1.1	0.3	0.7	0.3	0.2	0.3	0.1	(17)
(18)		PrecStd	3.6	0.7	0.6	0.7	0.7	1.1	1.1	1.1	1.2	1.0	1.2	0.7	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.8	53.6	63.2	75.5	81.9	88.8	91.9	90.7	81.5	70.3	56.3	49.6	(19)
(20)			MCWB	46.3	45.0	49.3	56.7	62.2	67.1	66.6	65.9	63.4	59.1	51.9	47.0	(20)
(21)		2%	DB	46.1	48.8	58.4	70.1	77.2	83.3	86.5	85.1	76.4	64.6	52.5	46.9	(21)
(22)			MCWB	43.5	44.1	47.0	54.4	61.2	64.8	65.6	65.1	61.7	56.5	49.2	44.8	(22)
(23)		5%	DB	43.1	45.8	53.5	65.6	72.4	79.1	82.1	80.8	72.0	60.7	50.0	43.9	(23)
(24)			MCWB	40.8	42.0	45.3	52.2	58.1	63.1	64.0	63.7	59.8	54.8	47.4	41.9	(24)
(25)		10%	DB	40.0	42.8	49.3	61.0	68.3	74.8	77.7	77.0	67.6	57.1	47.1	41.3	(25)
(26)			MCWB	38.1	39.8	43.7	50.0	55.8	61.2	62.9	62.6	58.3	52.9	44.9	39.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.9	47.3	50.8	58.7	65.6	69.7	69.2	68.8	65.3	60.4	52.3	47.8	(27)
(28)			MCD B	48.9	51.1	59.8	72.3	78.2	84.4	84.5	83.2	77.2	66.6	55.0	49.1	(28)
(29)		2%	WB	43.9	44.7	48.4	55.2	62.1	66.4	67.2	66.8	62.8	57.5	49.8	45.1	(29)
(30)			MCD B	45.8	48.2	55.4	67.3	73.9	78.8	80.9	79.9	73.3	63.1	52.0	46.9	(30)
(31)		5%	WB	40.9	42.3	46.2	53.1	59.6	64.4	65.7	65.2	61.2	55.4	47.4	42.0	(31)
(32)			MCD B	42.9	45.5	52.0	64.0	70.2	76.4	78.3	77.3	69.9	59.9	49.6	43.7	(32)
(33)		10%	WB	38.3	39.8	44.2	50.9	57.3	62.5	64.2	63.6	59.2	53.4	45.1	39.8	(33)
(34)			MCD B	39.9	42.6	48.9	59.7	66.2	73.1	75.3	74.5	66.4	56.7	47.1	41.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.3	11.1	14.4	18.6	19.4	19.8	20.0	20.4	17.8	13.9	8.5	7.3	(35)
(36)			MCDBR	8.8	15.1	23.8	27.3	27.5	28.3	28.7	28.4	26.5	19.6	12.1	8.9	(36)
(37)			MCWBR	7.5	10.4	13.7	13.2	13.0	12.1	10.4	10.9	12.7	11.7	9.0	7.6	(37)
(38)		5% WB	MCD BR	8.6	13.4	19.9	24.8	24.7	25.0	24.4	24.3	23.1	18.0	11.0	8.8	(38)
(39)			MCWBR	7.6	9.7	12.4	12.4	12.3	11.6	9.7	10.3	11.6	11.2	8.8	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.292	0.314	0.354	0.392	0.395	0.396	0.408	0.401	0.370	0.345	0.318	0.289	(40)	
(41)		taud	2.398	2.359	2.326	2.271	2.293	2.314	2.280	2.320	2.383	2.446	2.467	2.427	(41)	
(42)		Ebn at Noon	239	261	269	270	273	274	268	264	260	247	228	223	(42)	
(43)		Edh at Noon	20	27	33	39	40	39	40	36	31	24	19	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	264	527	842	1303	1545	1686	1606	1405	1005	600	287	204	(44)	
(45)		RadStd	49	78	117	169	184	145	170	139	139	75	34	25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+0.94	+0.97	N/A	N/A	+135	+50
(47) Regional (51 neighbors)		N/A	N/A	N/A	N/A	+0.59	+0.70	N/A	N/A	+99	+36

Nomenclature: See separate page