

CHEB, Czech Republic

WMO: 114060

Lat: 50.0683N

Lon: 12.3914E

Elev: 490

StdP: 95.58

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.9	-10.0	-15.5	1.0	-11.4	-12.7	1.3	-8.9	8.9	5.7	7.9	3.7	1.3	0	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	30.1	18.6	27.9	17.8	26.0	17.2	19.6	27.1	18.7	25.7	18.0	24.4	2.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	13.1	21.6	16.4	12.4	20.9	15.6	11.8	20.1	58.0	27.0	55.1	25.8	52.5	24.4	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 7.0	6.1	5.3		-16.1	33.4	3.7	1.9	-18.8	34.8	-21.0	35.9	-23.1	37.0	-25.8	38.3	
(5)			DB	-16.4	21.5	3.7	1.1	-19.1	22.3	-21.2	22.9	-23.3	23.5	-26.0	24.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	-1.4	0.0	3.6	8.4	12.7	16.0	17.9	17.6	13.3	8.6	3.5	-0.1	(6)
(7)		DBStd	7.84	4.57	4.53	3.88	4.13	3.65	3.70	3.43	3.24	3.34	3.76	3.46	4.21	(7)
(8)		HDD10.0	1514	352	281	198	78	15	2	0	0	7	72	196	313	(8)
(9)		HDD18.3	3722	611	514	455	299	178	89	51	53	154	302	445	572	(9)
(10)		CDD10.0	927	0	0	1	29	99	181	245	236	106	28	1	0	(10)
(11)		CDD18.3	93	0	0	0	0	3	19	38	31	3	0	0	0	(11)
(12)		CDH23.3	1144	0	0	0	7	61	242	423	359	51	1	0	0	(12)
(13)		CDH26.7	324	0	0	0	1	8	66	138	106	6	0	0	0	(13)
(14)	Wind	WSAvg	2.4	2.9	2.8	2.8	2.5	2.4	2.2	2.2	2.0	2.3	2.5	2.8	(14)	
(15)	Precipitation	PrecAvg	564	35	29	36	35	53	68	66	67	49	41	40	45	(15)
(16)		PrecMax	750	90	72	98	83	132	143	150	132	113	128	85	111	(16)
(17)		PrecMin	349	3	4	11	9	13	27	8	18	7	5	8	3	(17)
(18)		PrecStd	92	18	16	19	17	28	28	28	30	25	30	18	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.9	12.0	17.3	24.2	27.7	31.5	33.3	32.6	27.5	21.3	13.5	9.8	(19)
(20)			MCWB	7.9	7.2	9.6	13.7	16.8	19.5	19.2	18.8	17.4	15.1	11.1	8.3	(20)
(21)		2%	DB	7.8	9.3	14.6	21.2	25.1	28.5	30.3	29.5	24.6	18.1	11.4	8.3	(21)
(22)			MCWB	6.4	6.7	8.3	12.5	16.2	18.2	18.6	18.4	16.5	13.6	9.5	7.1	(22)
(23)		5%	DB	6.2	7.6	12.0	18.7	22.4	26.2	27.8	27.1	22.2	16.0	10.0	6.6	(23)
(24)			MCWB	4.9	5.6	7.4	11.2	14.5	17.3	17.8	17.6	15.4	12.7	8.6	5.5	(24)
(25)		10%	DB	4.5	6.0	9.6	16.1	20.2	23.8	25.4	25.0	19.8	14.0	8.4	5.1	(25)
(26)			MCWB	3.4	4.3	6.5	10.0	13.2	16.2	17.2	17.0	14.6	11.6	7.2	4.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	8.5	10.4	14.8	18.7	20.9	20.7	20.5	18.5	15.8	11.3	8.8	(27)
(28)			MCDWB	9.4	10.6	15.5	22.4	25.7	29.1	29.1	28.5	25.1	19.2	12.8	9.5	(28)
(29)		2%	WB	6.6	7.1	9.1	12.9	16.7	19.1	19.5	19.3	17.1	14.2	9.9	7.3	(29)
(30)			MCDWB	7.6	9.0	13.0	19.6	23.3	26.0	27.2	26.6	22.9	17.3	11.1	8.3	(30)
(31)		5%	WB	4.9	5.7	7.9	11.7	15.3	18.0	18.7	18.4	16.2	13.0	8.6	5.6	(31)
(32)			MCDWB	6.0	7.5	11.1	17.8	21.2	24.7	25.7	25.2	21.0	15.5	9.8	6.5	(32)
(33)		10%	WB	3.5	4.3	6.8	10.5	14.1	16.9	17.9	17.6	15.1	11.9	7.3	4.3	(33)
(34)			MCDWB	4.4	5.9	9.4	15.4	19.0	22.9	24.0	23.6	19.1	13.7	8.4	5.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.6	6.2	8.0	10.3	10.8	11.0	11.3	9.9	7.7	4.7	4.1	(35)	
(36)			MCDBR	4.9	8.4	13.2	15.2	15.3	15.7	15.9	15.8	14.7	10.9	6.7	5.0	(36)
(37)			MCWBR	4.2	5.8	7.6	7.4	7.2	6.7	5.8	6.1	7.1	6.5	5.0	4.2	(37)
(38)		5% WB	MCDWR	4.8	7.5	11.0	13.8	13.7	13.9	13.6	13.5	12.8	10.0	6.1	4.9	(38)
(39)			MCWBR	4.2	5.4	6.9	6.9	6.9	6.5	5.4	5.7	6.5	6.2	4.9	4.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.292	0.314	0.354	0.392	0.395	0.396	0.408	0.401	0.370	0.345	0.318	0.289	(40)	
(41)		taud	2.398	2.359	2.326	2.271	2.293	2.314	2.280	2.320	2.383	2.446	2.467	2.427	(41)	
(42)		Ebn at Noon	755	824	847	850	862	863	845	832	821	779	718	704	(42)	
(43)		Edh at Noon	63	84	104	122	125	123	126	115	97	77	60	54	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.83	1.66	2.65	4.11	4.87	5.31	5.06	4.43	3.17	1.89	0.90	0.64	(44)	
(45)		RadStd	0.15	0.25	0.37	0.53	0.58	0.46	0.54	0.44	0.44	0.23	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	+0.52	+0.54	N/A	N/A	+75	+28		
(47) Regional (51 neighbors)		N/A	N/A	N/A	N/A	+0.33	+0.39	N/A	N/A	+55	+20		

Nomenclature: See separate page