

KARLOVY VARY, Czech Republic

WMO: 114140

Lat: 50.2017N

Lon: 12.9142E

Elev: 1991

StdP: 13.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.2	12.6	2.9	6.9	10.3	8.0	8.9	15.2	21.4	37.1	19.9	36.9	3.7	60	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.8	83.5	65.0	79.9	63.4	76.6	62.1	66.7	78.9	65.1	76.2	63.5	73.6	6.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.6	91.6	70.5	61.1	86.7	68.7	59.7	82.3	67.2	32.4	78.8	31.1	76.6	29.9	73.5	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.9	15.9	13.9	DB	2.6	89.6	4.6	3.2	-0.7	91.9	-3.3	93.7	-5.9	95.5	-9.2	97.8
			WB	2.2	70.1	4.4	2.4	-1.0	71.8	-3.6	73.2	-6.1	74.6	-9.3	76.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	45.4	28.2	30.3	36.6	45.3	53.0	58.8	62.4	61.9	53.9	45.7	37.1	30.3	(6)
(7)		DBStd	14.07	8.27	8.37	7.30	7.63	6.80	6.77	6.23	6.00	6.28	6.96	6.25	7.78	(7)
(8)		HDD50	3074	677	553	416	177	47	7	0	1	30	168	387	611	(8)
(9)		HDD65	7273	1142	973	880	591	376	205	127	133	335	599	836	1076	(9)
(10)		CDD50	1383	0	0	1	37	138	272	383	370	147	34	1	0	(10)
(11)		CDD65	109	0	0	0	0	3	21	45	38	2	0	0	0	(11)
(12)		CDH74	1310	0	0	0	4	52	273	518	419	44	0	0	0	(12)
(13)		CDH80	306	0	0	0	0	5	56	138	105	2	0	0	0	(13)
(14)	Wind	WSAvg	6.0	6.8	6.8	6.9	6.0	6.0	5.6	5.5	5.0	5.2	5.4	5.9	6.4	(14)
(15)	Precipitation	PrecAvg	27.2	2.0	1.7	1.9	1.5	2.4	3.0	3.3	2.8	2.4	2.0	2.2	2.2	(15)
(16)		PrecMax	36.2	4.7	4.0	5.4	3.3	5.3	4.8	5.6	6.5	5.3	6.3	4.4	4.7	(16)
(17)		PrecMin	19.5	0.2	0.3	0.3	0.4	0.9	1.2	1.0	1.1	1.0	0.6	0.0	1.0	(17)
(18)		PrecStd	3.8	1.0	1.0	1.2	0.7	1.2	0.9	1.1	1.2	1.1	1.1	1.2	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.2	52.1	61.3	72.8	79.6	85.9	88.9	88.4	79.0	68.3	55.6	48.8	(19)
(20)		0.4%	MCWB	44.8	43.9	47.9	55.3	62.0	66.6	65.2	65.7	62.1	57.8	51.0	46.1	(20)
(21)		2%	DB	45.5	47.6	56.5	67.7	74.4	80.9	83.7	82.5	74.0	62.9	51.8	46.3	(21)
(22)		2%	MCWB	43.0	43.0	46.0	53.0	59.6	64.1	64.5	65.0	60.8	55.3	48.3	44.1	(22)
(23)		5%	DB	42.1	44.6	51.8	63.7	70.0	77.0	80.0	78.4	69.8	59.2	48.8	43.2	(23)
(24)		5%	MCWB	40.0	40.9	44.0	51.3	57.3	62.3	63.4	63.2	58.9	53.7	46.4	41.1	(24)
(25)		10%	DB	39.2	41.7	47.7	59.5	66.2	72.9	75.7	74.8	65.4	55.8	46.3	40.2	(25)
(26)		10%	MCWB	37.6	38.9	42.8	49.1	55.0	60.4	62.1	61.8	57.1	51.9	44.1	38.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.9	46.1	50.2	57.3	64.4	69.2	68.4	68.8	64.6	59.0	51.8	46.8	(27)
(28)		0.4%	MCDWB	47.6	49.2	57.9	68.5	76.5	81.5	82.6	82.3	73.9	64.5	55.1	48.2	(28)
(29)		2%	WB	43.1	43.7	47.7	54.4	61.0	66.0	66.3	66.4	61.9	56.6	49.1	44.2	(29)
(30)		2%	MCDWB	45.2	46.8	53.5	65.1	70.7	77.1	78.5	78.7	71.1	61.5	51.0	46.0	(30)
(31)		5%	WB	40.2	41.4	45.5	52.2	58.6	63.5	64.7	64.7	59.9	54.4	46.7	41.2	(31)
(32)		5%	MCDWB	42.0	44.2	50.4	62.0	67.9	73.8	76.1	75.4	67.9	58.4	48.6	42.9	(32)
(33)		10%	WB	37.6	38.8	43.1	50.0	56.5	61.5	63.2	62.9	58.1	52.4	44.3	38.9	(33)
(34)		10%	MCDWB	39.0	41.5	47.5	58.2	64.6	71.0	73.2	72.3	64.3	55.6	46.1	40.1	(34)
(35)	Mean Daily Temperature Range		MDBR	8.4	10.7	13.7	17.8	18.2	18.8	19.3	16.7	13.2	8.6	7.7	(35)	
(36)		5% DB	MCDBR	10.4	14.7	22.8	25.6	25.0	26.5	26.5	26.2	24.2	18.9	12.4	10.4	(36)
(37)			MCWBR	8.5	10.2	13.4	13.1	12.5	12.3	10.7	11.2	11.9	11.6	9.3	8.6	(37)
(38)			MCDBR	9.8	12.4	19.4	23.5	22.5	24.2	22.6	23.1	21.3	17.1	11.2	9.7	(38)
(39)		5% WB	MCWBR	8.5	9.3	12.4	12.7	11.8	12.1	10.1	10.7	11.2	11.0	9.0	8.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.284	0.306	0.344	0.382	0.384	0.385	0.397	0.390	0.361	0.336	0.310	0.281	(40)	
(41)		taud	2.417	2.386	2.352	2.293	2.313	2.330	2.298	2.336	2.399	2.460	2.482	2.442	(41)	
(42)		Ebn at Noon	243	265	272	273	277	277	271	267	264	251	231	227	(42)	
(43)		Edh at Noon	19	26	32	38	39	38	39	36	30	24	18	16	(43)	
(44)	All-Sky Solar Radiation	RadAvg	262	523	833	1293	1538	1675	1595	1395	996	594	284	203	(44)	
(45)		RadStd	49	77	118	168	185	144	170	137	139	75	34	25	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (53 neighbors)	+0.72	N/A	N/A	N/A	+0.59	+0.63	N/A	N/A	+106 +40	(47)

Nomenclature: See separate page