

TUSIMICE, Czech Republic

WMO: 114380

Lat: 50.3767N

Lon: 13.3281E

Elev: 1070

StdP: 14.14

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.7	15.3	4.9	7.4	12.8	10.0	9.5	17.4	31.2	44.2	27.3	41.6	4.4	270	0.551

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	86.7	67.5	82.9	65.9	79.6	64.6	69.3	81.4	67.6	79.2	66.0	76.7	7.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.5	98.1	73.5	63.7	91.8	71.5	62.1	86.6	70.4	34.0	81.4	32.6	79.5	31.3	76.9	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
23.0	19.0	16.3	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			6.8	93.1	5.8	3.9	2.6	96.0	-0.8	98.3	-4.1	100.5	-8.3	103.4
			6.0	73.2	5.7	1.9	1.9	74.6	-1.4	75.7	-4.6	76.7	-8.8	78.1
				DB										
				WB										

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.7	31.0	33.6	40.2	48.8	56.4	62.5	66.3	65.6	57.6	48.4	39.8	33.1
	DBStd	14.25	8.77	8.31	7.29	7.25	6.30	6.27	5.75	5.64	5.86	6.71	6.22	8.23
	HDD50	2436	590	459	312	107	16	1	0	0	6	112	310	523
	HDD65	6192	1054	878	770	486	274	122	54	62	232	516	756	988
	CDD50	1953	1	1	6	72	214	374	504	483	233	61	4	0
	CDD65	237	0	0	0	0	8	45	94	80	10	0	0	0
	CDH74	2381	0	0	0	12	109	462	916	774	106	2	0	0
	CDH80	677	0	0	0	0	13	117	300	232	15	0	0	0
Wind	WSAvg	6.9	7.4	7.6	8.1	7.3	7.0	6.9	7.0	6.4	6.3	6.0	6.2	7.0
Precipitation	PrecAvg	25.2	1.5	1.3	1.6	1.5	2.4	3.0	3.3	3.0	2.2	1.7	1.9	1.8
	PrecMax	34.6	3.2	2.7	5.0	3.1	5.0	5.0	5.4	7.9	3.9	3.8	4.4	3.4
	PrecMin	15.9	0.2	0.3	0.6	0.1	0.6	1.2	0.7	0.7	0.7	0.6	0.0	0.7
	PrecStd	3.6	0.7	0.6	0.9	0.7	1.1	1.0	1.1	1.4	1.0	0.7	1.0	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.9	56.3	64.8	75.9	81.6	88.2	92.2	91.9	82.4	70.3	59.5	52.6
		MCWB	48.2	47.6	50.5	58.3	64.8	69.1	69.0	67.4	63.9	59.3	54.0	48.3
	2%	DB	49.8	51.9	59.8	70.9	77.2	83.5	87.1	85.7	77.0	64.8	54.9	49.4
		MCWB	45.4	45.8	48.8	55.8	62.4	67.2	67.5	66.7	62.5	56.9	50.5	45.6
	5%	DB	46.1	48.5	55.4	66.7	72.9	79.6	83.2	81.7	72.7	61.4	51.8	46.4
		MCWB	42.3	43.6	47.0	53.6	60.0	64.9	65.9	65.5	61.1	55.5	48.4	43.4
	10%	DB	42.7	45.3	51.4	62.9	69.5	75.6	79.0	78.1	68.5	58.1	48.9	43.5
		MCWB	39.5	41.1	45.4	51.7	58.1	63.3	64.3	64.1	59.4	53.8	46.2	40.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.3	49.0	52.5	60.1	67.5	72.4	72.8	70.5	66.6	60.9	54.6	48.7
		MCDB	52.9	54.7	61.6	72.9	78.1	84.2	85.1	83.7	76.5	67.3	58.3	51.8
	2%	WB	45.6	46.5	50.0	56.7	64.1	68.9	69.3	68.5	64.2	58.2	51.1	46.0
		MCDB	49.4	51.3	57.3	67.6	73.7	79.7	81.5	81.4	73.1	63.1	54.0	49.1
	5%	WB	42.5	43.9	47.9	54.6	61.6	66.5	67.3	66.9	62.1	56.2	48.9	43.4
		MCDB	45.9	48.1	54.2	65.0	70.6	76.8	79.2	78.6	70.4	60.3	51.4	46.0
	10%	WB	39.8	41.2	45.7	52.5	59.3	64.2	65.7	65.3	60.4	54.3	46.2	41.2
		MCDB	42.6	45.1	51.2	61.6	67.6	73.2	76.5	75.5	67.5	57.7	48.5	43.1
Mean Daily Temperature Range	5% DB	MDBR	8.1	11.0	14.3	19.0	19.1	18.8	19.3	20.0	17.1	13.1	8.7	7.7
		MCDBR	11.2	14.6	22.7	27.0	26.0	26.5	27.4	27.3	24.8	18.4	13.0	10.6
		MCWBR	8.8	9.9	13.7	13.6	13.2	12.2	10.6	10.9	11.9	11.3	9.7	8.3
	5% WB	MCDBR	11.1	13.3	19.8	24.9	23.5	24.0	23.8	23.6	21.7	16.6	11.8	10.1
		MCWBR	9.1	9.6	12.9	13.2	13.0	12.5	10.4	10.6	11.1	10.7	9.3	8.2
Clear-Sky Solar Irradiance	taub	0.301	0.323	0.366	0.409	0.411	0.410	0.423	0.417	0.383	0.356	0.327	0.296	
	taud	2.384	2.351	2.289	2.219	2.249	2.276	2.243	2.281	2.352	2.411	2.438	2.414	
	Ebn at Noon	233	257	264	264	269	269	263	259	255	241	221	218	
	Edh at Noon	20	27	34	41	41	41	41	38	32	25	19	17	
All-Sky Solar Radiation	RadAvg	259	515	820	1282	1532	1664	1585	1381	987	588	281	201	
	RadStd	49	77	117	167	186	144	171	134	138	75	35	24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	+2.81	N/A	N/A	+0.88	N/A	N/A	N/A	N/A
(47)	Regional (53 neighbors)	+0.72	N/A	N/A	N/A	+0.59	+0.61	N/A	N/A	+90	+31

Nomenclature: See separate page