

TUSIMICE, Czech Republic

WMO: 114380

Lat: 50.3767N

Lon: 13.3281E

Elev: 326

StdP: 97.47

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.8	-9.3	-15.0	1.1	-10.7	-12.2	1.4	-8.1	13.9	6.8	12.2	5.3	2.0	270	0.551

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	30.4	19.7	28.3	18.9	26.4	18.1	20.7	27.5	19.8	26.2	18.9	24.9	3.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	14.0	23.1	17.6	13.1	21.9	16.7	12.4	21.3	61.3	27.4	57.8	26.4	54.9	24.9	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	8.5	7.3	DB	-14.0	34.0	3.2	2.2	-16.3	35.6	-18.2	36.8	-20.0	38.1	-22.4	39.7	(4)
(5)			WB	-14.4	22.9	3.2	1.1	-16.7	23.7	-18.6	24.3	-20.3	24.9	-22.6	25.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	-0.6	0.9	4.5	9.3	13.6	16.9	19.0	18.7	14.2	9.1	4.3	0.6	(6)
(7)		DBStd	7.92	4.87	4.62	4.05	4.03	3.50	3.48	3.19	3.13	3.26	3.73	3.46	4.57	(7)
(8)		HDD10.0	1353	328	255	173	59	9	1	0	0	3	62	172	291	(8)
(9)		HDD18.3	3440	586	488	428	270	152	68	30	34	129	287	420	549	(9)
(10)		CDD10.0	1085	1	1	3	40	119	208	280	268	129	34	2	0	(10)
(11)		CDD18.3	132	0	0	0	0	4	25	52	44	6	0	0	0	(11)
(12)		CDH23.3	1323	0	0	0	7	61	257	509	430	59	1	0	0	(12)
(13)		CDH26.7	376	0	0	0	0	7	65	167	129	8	0	0	0	(13)
(14)	Wind	WSAvg	3.1	3.3	3.4	3.6	3.3	3.1	3.1	3.1	2.8	2.8	2.7	2.8	3.1	(14)
(15)	Precipitation	PrecAvg	640	39	34	41	37	62	76	83	75	55	44	48	46	(15)
(16)		PrecMax	879	82	69	127	78	128	128	137	200	99	97	112	86	(16)
(17)		PrecMin	403	6	8	15	3	16	31	17	18	19	14	0	17	(17)
(18)		PrecStd	92	19	16	23	17	28	26	28	36	25	19	25	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	13.5	18.2	24.4	27.6	31.2	33.4	33.3	28.0	21.3	15.3	11.4	(19)
(20)			MCWB	9.0	8.7	10.3	14.6	18.2	20.6	20.6	19.6	17.7	15.2	12.2	9.0	(20)
(21)		2%	DB	9.9	11.1	15.5	21.6	25.1	28.6	30.6	29.8	25.0	18.2	12.7	9.6	(21)
(22)			MCWB	7.5	7.7	9.3	13.2	16.9	19.6	19.7	19.3	16.9	13.9	10.3	7.5	(22)
(23)		5%	DB	7.8	9.2	13.0	19.3	22.7	26.4	28.4	27.6	22.6	16.4	11.0	8.0	(23)
(24)			MCWB	5.7	6.4	8.3	12.0	15.5	18.3	18.8	18.6	16.2	13.0	9.1	6.3	(24)
(25)		10%	DB	5.9	7.4	10.8	17.2	20.8	24.2	26.1	25.6	20.3	14.5	9.4	6.4	(25)
(26)			MCWB	4.2	5.1	7.4	10.9	14.5	17.4	18.0	17.8	15.2	12.1	7.9	4.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	9.4	11.4	15.6	19.7	22.4	22.6	21.4	19.2	16.0	12.5	9.3	(27)
(28)			MCDWB	11.6	12.6	16.5	22.7	25.6	29.0	29.5	28.7	24.7	19.6	14.6	11.0	(28)
(29)		2%	WB	7.6	8.0	10.0	13.7	17.8	20.5	20.7	20.3	17.9	14.6	10.6	7.8	(29)
(30)			MCDWB	9.6	10.7	14.1	19.8	23.2	26.5	27.5	27.5	22.8	17.3	12.2	9.5	(30)
(31)		5%	WB	5.9	6.6	8.9	12.6	16.4	19.1	19.6	19.4	16.7	13.5	9.4	6.3	(31)
(32)			MCDWB	7.7	9.0	12.3	18.3	21.4	24.9	26.2	25.9	21.3	15.7	10.8	7.8	(32)
(33)		10%	WB	4.3	5.1	7.6	11.4	15.2	17.9	18.7	18.5	15.8	12.4	7.9	5.1	(33)
(34)			MCDWB	5.9	7.3	10.7	16.5	19.8	22.9	24.7	24.2	19.7	14.3	9.2	6.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.5	6.1	7.9	10.6	10.6	10.5	10.7	11.1	9.5	7.3	4.8	4.3	(35)
(36)			MCDBR	6.2	8.1	12.6	15.0	14.4	14.7	15.2	15.2	13.8	10.2	7.2	5.9	(36)
(37)			MCWBR	4.9	5.5	7.6	7.6	7.3	6.8	5.9	6.0	6.6	6.3	5.4	4.6	(37)
(38)		5% WB	MCDBR	6.1	7.4	11.0	13.8	13.0	13.4	13.2	13.1	12.0	9.2	6.6	5.6	(38)
(39)			MCWBR	5.0	5.3	7.2	7.3	7.2	6.9	5.8	5.9	6.2	6.0	5.2	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.301	0.323	0.366	0.409	0.411	0.410	0.423	0.417	0.383	0.356	0.327	0.296	(40)	
(41)		taud	2.384	2.351	2.289	2.219	2.249	2.276	2.243	2.281	2.352	2.411	2.438	2.414	(41)	
(42)		Ebn at Noon	736	809	831	831	847	849	829	815	805	760	698	686	(42)	
(43)		Edh at Noon	63	84	107	128	130	128	130	120	100	79	61	54	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.82	1.62	2.59	4.04	4.83	5.25	5.00	4.36	3.11	1.85	0.89	0.63	(44)	
(45)		RadStd	0.15	0.24	0.37	0.53	0.58	0.45	0.54	0.42	0.43	0.24	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	+1.56	N/A	N/A	+0.49	N/A	N/A	N/A	N/A
(47) Regional (53 neighbors)		+0.40	N/A	N/A	N/A	+0.33	+0.34	N/A	N/A	+50	+17

Nomenclature: See separate page