

PLZEN LINE, Czech Republic

WMO: 114480

Lat: 49.675N

Lon: 13.275E

Elev: 1188

StdP: 14.08

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.4	13.8	3.4	6.8	10.1	8.9	9.0	14.6	20.5	43.4	17.9	42.0	2.1	50	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.4	88.0	67.1	84.2	65.9	80.7	64.9	69.4	82.2	67.7	79.3	66.3	77.9	5.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.8	99.4	72.7	64.1	93.7	71.6	62.5	88.3	70.3	34.2	82.4	32.8	79.3	31.6	78.6	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.9	13.7	11.9	3.3	93.6	9.6	3.1	-3.6	95.9	-9.2	97.7	-14.6	99.4	-21.6	101.7		
(5)			3.2	72.9	8.5	2.6	-3.0	74.8	-7.9	76.3	-12.7	77.8	-18.9	79.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.4	31.0	32.2	39.7	48.6	55.7	62.5	66.5	65.0	56.8	48.8	39.7	32.8		
	DBStd	14.40	8.73	8.27	6.99	7.60	6.63	6.72	5.99	6.08	6.16	6.48	6.41	8.49		
	HDD50	2506	589	499	322	116	21	2	0	0	10	102	312	533		
	HDD65	6317	1053	919	783	494	298	126	56	75	255	502	759	997		
	CDD50	1911	0	0	4	72	198	376	512	466	214	65	4	0		
	CDD65	245	0	0	0	0	9	50	102	75	9	0	0	0		
	CDH74	2896	0	0	0	25	141	603	1154	873	98	2	0	0		
	CDH80	935	0	0	0	2	18	170	413	314	18	0	0	0		
(14) Wind	WSAvg	4.3	5.4	4.8	5.3	4.4	4.2	3.8	4.0	3.6	3.6	3.6	4.1	4.8		
(15) Precipitation	PrecAvg	22.7	1.2	1.0	1.4	1.4	2.3	3.1	3.1	2.9	1.8	1.6	1.5	1.5		
	PrecMax	34.8	2.3	2.4	3.2	2.7	5.8	4.9	6.5	9.2	3.9	4.3	3.3	3.1		
	PrecMin	14.7	0.4	0.3	0.3	0.4	0.4	1.7	1.2	0.9	0.7	0.2	0.1	0.6		
	PrecStd	3.9	0.6	0.6	0.8	0.7	1.1	0.9	1.1	1.7	0.7	0.9	0.7	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.3	57.2	65.8	77.2	82.5	89.8	93.4	93.4	82.6	73.2	58.9	52.2		
		MCWB	48.3	46.3	51.6	57.8	64.4	69.3	67.5	67.4	65.8	59.7	53.8	48.2		
	2%	DB	49.6	50.3	59.4	72.0	78.4	84.4	88.2	87.8	76.6	66.4	54.4	49.7		
		MCWB	45.8	44.5	49.2	55.6	62.5	66.5	66.6	67.2	63.2	57.6	50.4	46.6		
	5%	DB	46.1	46.7	55.3	68.2	73.6	80.7	84.5	82.6	72.0	62.6	51.8	46.4		
		MCWB	43.3	42.8	46.9	54.2	59.7	64.8	65.6	65.5	61.1	55.8	48.6	44.0		
	10%	DB	42.7	43.5	50.9	64.1	69.7	77.0	80.7	78.6	68.2	59.1	48.7	43.1		
		MCWB	40.4	39.9	45.1	52.4	57.6	63.0	65.1	64.4	59.6	54.3	46.2	41.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.3	48.0	53.4	60.5	66.7	71.7	71.0	71.1	67.0	61.6	54.2	49.4		
		MCDB	52.3	54.5	60.8	74.6	79.4	85.6	83.7	83.5	77.4	68.4	57.8	51.9		
	2%	WB	45.9	45.3	50.4	57.2	63.6	68.5	69.0	69.1	64.9	59.2	51.3	46.8		
		MCDB	48.8	49.4	57.5	68.9	75.0	79.9	81.7	81.7	74.6	64.8	54.0	49.1		
	5%	WB	42.9	43.0	47.9	55.0	61.4	66.3	67.5	67.3	62.6	57.0	49.0	43.7		
		MCDB	45.0	46.7	53.6	65.7	71.3	78.1	79.6	78.6	70.6	62.0	51.5	45.7		
	10%	WB	40.1	39.9	45.4	53.1	59.2	64.1	66.2	65.5	60.7	54.9	46.6	41.5		
		MCDB	42.2	43.2	50.4	62.5	67.5	74.3	78.3	76.0	66.7	59.3	48.6	43.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	12.5	15.7	20.4	19.8	20.2	21.4	20.7	17.4	15.5	9.1	8.6		
		MCDBR	12.0	19.0	26.0	29.5	27.7	28.0	29.4	29.0	24.3	21.7	13.8	13.0		
		MCWBR	9.6	13.4	15.7	14.8	13.5	12.0	10.2	11.2	12.3	13.6	10.2	10.2		
	5% WB	MCDBR	11.4	18.3	22.5	26.3	24.7	25.6	23.9	24.2	21.9	20.7	12.5	12.0		
		MCWBR	9.7	13.2	14.7	14.0	12.7	11.7	9.9	10.5	11.6	13.4	9.7	9.9		
(40) Clear-Sky Solar Irradiance	taub		0.299	0.321	0.361	0.401	0.404	0.405	0.416	0.409	0.380	0.353	0.324	0.295		
	taud		2.390	2.353	2.308	2.243	2.268	2.292	2.265	2.303	2.356	2.420	2.453	2.424		
	Ebn at Noon		238	260	267	267	271	271	266	262	258	245	227	223		
	Edh at Noon		20	27	34	40	41	40	41	37	32	25	20	17		
(44) All-Sky Solar Radiation	RadAvg		273	549	869	1326	1557	1704	1627	1435	1023	615	294	210		
	RadStd		50	79	120	171	183	147	166	145	140	75	33	27		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (61 neighbors)		+0.76	N/A	N/A	N/A	+0.59	+0.58	N/A	N/A	+99	+41

Nomenclature: See separate page