

PLZEN-MIKULKA, Czech Republic

WMO: 114500

Lat: 49.7647N

Lon: 13.3789E

Elev: 1219

StdP: 14.06

Time Zone: 1.00 (EUC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.5	15.6	4.9	7.4	13.5	9.9	9.5	18.5	24.1	43.1	21.4	43.1	4.6	10	0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.4	89.1	66.6	85.3	65.5	81.8	64.3	68.7	83.5	67.2	81.1	65.7	77.9	6.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.4	94.7	71.2	62.9	89.7	70.3	61.5	85.4	69.5	33.6	83.2	32.3	81.5	31.2	77.8	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
19.0	16.5	14.4	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			7.0	95.8	6.9	3.2	2.0	98.1	-2.0	99.9	-5.9	101.7	-10.9	104.0
			6.5	71.6	6.9	1.8	1.5	72.9	-2.6	74.0	-6.5	75.0	-11.5	76.4
				DB										
				WB										

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.4	31.7	33.0	40.5	50.1	56.8	63.9	67.5	66.1	58.4	49.2	40.4	34.1
	DBStd	14.47	8.33	7.93	7.55	7.17	6.94	6.63	6.19	6.03	6.37	6.49	6.51	7.26
	HDD50	2343	568	475	302	86	19	1	0	0	6	96	296	494
	HDD65	6008	1033	895	760	447	266	99	47	59	214	490	739	959
	CDD50	2122	0	0	7	90	231	418	542	498	259	71	6	0
	CDD65	314	0	0	0	1	14	66	124	92	17	0	0	0
	CDH74	3462	0	0	0	32	204	741	1311	984	187	3	0	0
	CDH80	1154	0	0	0	3	43	227	497	346	38	0	0	0
Wind	WSAvg	6.7	7.7	7.1	7.6	6.7	6.7	6.3	6.4	6.1	5.9	6.0	6.9	7.4
Precipitation	PrecAvg	20.6	1.1	0.9	1.2	1.3	2.2	2.8	2.9	2.5	1.7	1.5	1.4	1.2
	PrecMax	30.2	2.0	2.1	3.2	2.6	4.9	4.5	5.7	7.3	3.5	4.3	3.4	2.5
	PrecMin	13.0	0.3	0.1	0.2	0.3	0.6	0.9	0.7	0.8	0.5	0.2	0.1	0.2
	PrecStd	3.4	0.5	0.6	0.7	0.6	1.1	0.9	1.1	1.4	0.7	0.8	0.8	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.8	57.0	67.2	78.0	85.0	91.0	95.0	94.1	84.6	73.2	59.6	51.9
		MCWB	47.3	46.0	51.3	58.0	64.1	66.8	67.7	66.7	65.6	59.0	53.1	47.7
	2%	DB	49.3	50.8	61.6	73.2	79.8	86.0	89.9	87.6	79.0	67.2	56.1	48.8
		MCWB	45.2	44.4	48.6	55.5	62.4	66.0	66.5	66.7	62.7	57.0	50.9	45.6
	5%	DB	45.7	47.2	57.0	69.5	74.9	82.0	85.7	83.6	75.0	63.5	52.9	45.9
		MCWB	42.4	41.9	46.5	53.8	59.8	64.1	65.3	65.3	61.0	55.5	48.9	42.9
	10%	DB	42.6	43.9	52.3	65.0	70.6	78.0	81.4	79.6	70.5	59.5	50.0	43.5
		MCWB	39.9	39.8	45.2	52.0	57.2	62.8	64.3	63.9	59.4	54.0	47.1	41.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.6	48.1	52.8	59.4	66.8	70.8	70.0	70.6	66.7	60.8	54.5	48.5
		MCDB	51.8	53.6	64.0	74.7	80.5	84.8	86.7	84.3	80.6	68.1	59.1	50.9
	2%	WB	45.6	44.7	50.1	56.4	63.5	67.8	68.2	68.8	64.3	58.3	51.7	45.9
		MCDB	48.7	49.8	58.9	69.7	76.0	82.5	84.3	82.5	75.8	64.6	55.1	48.4
	5%	WB	42.6	42.2	47.8	54.5	60.9	65.7	66.9	66.7	62.3	56.5	49.5	43.2
		MCDB	45.3	46.7	54.9	67.0	72.6	78.3	81.2	79.0	72.2	62.0	52.3	45.6
	10%	WB	40.0	39.9	45.5	52.7	58.9	63.8	65.6	65.2	60.7	54.4	46.9	41.2
		MCDB	42.5	43.9	51.7	63.4	68.3	75.2	77.9	76.2	68.3	59.3	49.6	43.3
Mean Daily Temperature Range	5% DB	MDBR	8.9	12.3	16.5	20.9	20.1	20.5	21.4	21.1	19.1	15.5	9.4	8.2
		MCDBR	11.5	18.1	26.7	29.3	27.8	28.6	29.6	28.8	26.6	22.3	13.7	11.5
		MCWBR	8.8	11.6	14.8	13.7	12.1	11.3	9.6	10.3	11.6	12.5	9.2	8.6
	5% WB	MCDBR	11.1	17.0	23.1	26.4	25.6	25.0	24.7	24.5	23.7	20.0	12.0	10.8
MCWBR		9.0	11.5	13.6	12.9	11.7	10.7	8.9	9.7	10.8	11.8	8.5	8.4	
Clear-Sky Solar Irradiance	taub	0.298	0.320	0.360	0.399	0.402	0.404	0.415	0.408	0.378	0.351	0.323	0.294	
	taud	2.395	2.362	2.313	2.245	2.271	2.294	2.266	2.305	2.360	2.422	2.456	2.429	
	Ebn at Noon	238	260	267	267	272	272	266	262	258	245	227	223	
	Edh at Noon	20	27	33	40	41	40	41	37	32	25	19	17	
All-Sky Solar Radiation	RadAvg	272	545	863	1320	1553	1699	1622	1428	1019	612	293	209	
	RadStd	50	79	120	170	183	146	167	144	139	75	33	27	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (63 neighbors)	+0.74	N/A	N/A	N/A	+0.59	+0.59	N/A	N/A	+90	+34

Nomenclature: See separate page