

MILESOVKA, Czech Republic

WMO: 114640

Lat: 50.5550N

Lon: 13.9308E

Elev: 2764

StdP: 13.29

Time Zone: 1.00 (EUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 8.6	(c) 12.6	(d) 2.0	(e) 6.7	(f) 12.5	(g) 7.8	(h) 9.1	(i) 15.2	(j) 50.1	(k) 36.8	(l) 45.0	(m) 33.4	(n) 17.1	(o) 120	(p) 0.878

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 16.8	(c) 82.9	(d) 66.0	(e) 79.1	(f) 64.5	(g) 75.4	(h) 62.8	(i) 67.8	(j) 79.9	(k) 65.8	(l) 76.7	(m) 63.9	(n) 73.6	(o) 9.4	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.5	97.4	74.1	61.7	91.1	71.1	60.0	85.8	68.6	33.9	80.0	32.1	77.1	30.6	74.0	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	DB	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
40.7	36.4	32.8 <td>4.8</td> <td>90.8</td> <td>5.4</td> <td>3.6</td> <td>0.9</td> <td>93.3</td> <td>-2.3</td> <td>95.5</td> <td>-5.4</td> <td>97.5</td> <td>-9.3</td> <td>100.1</td>		4.8	90.8	5.4	3.6	0.9	93.3	-2.3	95.5	-5.4	97.5	-9.3	100.1	
			WB	4.2	72.4	5.4	1.8	0.3	73.6	-2.8	74.7	-5.9	75.7	-9.8	77.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.8	26.5	28.5	35.4	46.0	53.6	59.3	62.7	62.4	54.0	44.3	35.2	28.7
	DBStd	15.12	7.73	8.11	8.38	8.87	7.84	7.79	7.36	6.90	7.14	7.33	6.84	7.21
	HDD50	3381	728	602	457	179	53	12	1	3	36	206	445	659
	HDD65	7532	1193	1022	919	570	360	205	134	133	337	641	894	1124
	CDD50	1487	0	0	3	59	165	290	396	387	156	30	1	0
	CDD65	162	0	0	0	1	7	32	63	52	7	0	0	0
	CDH74	1087	0	0	0	7	63	246	420	320	31	0	0	0
	CDH80	266	0	0	0	0	7	61	113	83	2	0	0	0
	WSAvg	17.2	20.4	19.4	18.2	15.8	16.0	14.8	14.7	14.5	15.7	17.9	18.8	20.3
Precipitation	PrecAvg	27.3	1.8	1.6	1.9	1.5	2.6	3.1	3.5	3.3	2.2	1.9	2.0	2.0
	PrecMax	39.2	3.5	2.9	6.2	3.1	5.2	6.4	6.3	9.0	5.0	3.9	4.2	4.2
	PrecMin	16.2	0.2	0.4	0.6	0.1	0.5	1.4	0.9	0.4	0.8	0.4	0.0	0.6
	PrecStd	4.5	0.9	0.7	1.1	0.7	1.3	1.2	1.3	1.9	1.1	0.9	1.0	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.9	50.3	61.0	74.1	80.0	86.5	88.7	88.0	78.4	66.0	53.4	45.7
		MCWB	42.6	41.8	48.0	56.7	63.8	69.3	68.8	66.9	63.1	56.7	50.0	42.5
	2%	DB	42.8	44.9	54.6	67.9	75.0	80.9	82.9	81.6	72.4	60.4	49.5	43.0
		MCWB	41.1	40.2	45.2	53.7	61.0	66.1	65.9	65.5	61.2	54.3	46.8	40.4
	5%	DB	39.6	41.8	50.0	63.1	70.1	75.9	78.6	77.2	67.7	56.5	46.9	40.4
		MCWB	38.3	38.3	42.7	51.3	58.4	63.4	64.6	64.1	58.7	52.4	45.3	38.8
	10%	DB	36.7	38.7	45.9	58.7	65.5	71.4	74.4	72.9	63.6	53.5	44.1	37.9
		MCWB	35.7	36.3	41.2	49.2	55.4	61.2	62.8	61.9	56.9	50.8	42.6	36.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.0	44.1	49.5	58.0	66.4	70.8	70.2	69.3	65.0	58.2	50.4	44.3
		MCDB	44.9	47.0	58.6	72.0	78.0	82.6	84.3	81.2	74.0	63.1	52.4	44.9
	2%	WB	41.2	41.4	46.2	54.8	62.3	67.2	67.5	66.9	61.9	55.0	47.7	41.6
		MCDB	42.2	43.9	52.0	65.9	72.2	78.1	80.0	78.6	70.5	59.1	49.0	42.5
	5%	WB	38.3	38.9	43.9	52.3	59.2	64.5	65.5	64.9	59.6	53.0	45.5	39.0
		MCDB	39.4	41.1	48.6	61.7	68.7	74.4	76.7	75.2	66.5	56.0	46.8	39.9
	10%	WB	35.7	36.5	41.7	49.9	56.4	61.8	63.4	62.9	57.5	51.1	43.0	37.0
		MCDB	36.7	38.4	45.6	57.4	64.1	70.2	72.9	71.5	62.9	53.4	44.0	37.7
Mean Daily Temperature Range	5% DB	MDBR	7.2	9.1	12.1	16.8	17.7	17.4	16.8	16.9	13.5	9.8	6.9	6.8
		MCDBR	9.0	11.8	17.9	22.7	23.8	23.8	22.7	22.5	19.9	14.2	9.5	8.5
		MCWBR	7.7	8.4	11.0	12.0	13.3	13.2	11.4	11.1	10.9	9.3	7.3	7.3
	5% WB	MCDBR	8.5	10.8	16.1	21.6	22.6	22.7	20.9	20.5	18.7	13.1	8.9	7.7
		MCWBR	7.7	8.4	10.5	11.7	13.3	13.1	11.3	11.0	10.7	9.0	7.4	7.3
Clear-Sky Solar Irradiance	taub		0.283	0.303	0.341	0.378	0.380	0.378	0.391	0.385	0.353	0.332	0.308	0.278
	taud		2.419	2.407	2.348	2.282	2.301	2.324	2.288	2.326	2.398	2.449	2.473	2.440
	Ebn at Noon		242	266	273	273	278	279	272	268	266	251	230	226
	Edh at Noon		19	25	32	38	39	39	39	36	30	24	18	16
All-Sky Solar Radiation	RadAvg		255	501	810	1285	1547	1667	1579	1384	989	577	273	193
	RadStd		46	75	120	167	183	141	179	134	136	79	34	21

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+112	N/A
(47) Regional (53 neighbors)	+0.74	N/A	N/A	N/A	+0.61	+0.63	N/A	N/A	+90	+29

Nomenclature: See separate page