

KOCELOVICE, Czech Republic

WMO: 114870

Lat: 49.4672N

Lon: 13.8386E

Elev: 1716

StdP: 13.81

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.8	13.6	4.0	7.2	10.5	8.9	9.2	15.9	32.1	43.6	28.7	41.3	5.2	50	0.585

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	85.5	65.3	81.7	64.4	78.3	63.3	67.5	79.8	66.0	77.9	64.6	75.2	7.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.7	94.0	70.5	62.2	89.2	69.2	60.9	85.0	68.3	32.8	79.7	31.7	78.2	30.6	75.5	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.7	21.0	18.1	DB	3.4	91.3	6.0	3.3	-1.0	93.7	-4.5	95.6	-7.9	97.4	-12.3	99.8	(4)
(5)			WB	2.8	70.4	5.9	1.6	-1.5	71.6	-5.0	72.6	-8.3	73.5	-12.6	74.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.0	29.2	31.7	38.2	47.0	55.0	61.2	64.7	64.2	55.7	47.1	37.8	31.3	(6)	
	DBStd	14.52	8.61	8.65	7.50	7.57	6.67	6.76	6.07	6.10	6.21	6.89	6.73	7.94	(7)	
	HDD50	2803	644	514	370	142	28	2	0	0	16	139	368	580	(8)	
	HDD65	6754	1109	934	831	540	316	153	83	89	284	555	815	1045	(9)	
	CDD50	1710	0	0	3	52	183	337	456	440	188	49	2	0	(10)	
	CDD65	189	0	0	0	0	6	38	74	65	6	0	0	0	(11)	
	CDH74	1881	0	0	0	6	78	389	702	640	65	1	0	0	(12)	
	CDH80	501	0	0	0	0	10	92	205	184	10	0	0	0	(13)	
(14) Wind	WSAvg	8.0	9.4	9.2	9.2	8.3	7.8	6.9	7.1	6.5	6.8	7.4	8.2	9.0	(14)	
(15) Precipitation	PrecAvg	24.3	1.3	1.1	1.6	1.4	2.6	3.2	3.4	3.1	1.8	1.8	1.6	1.3	(15)	
	PrecMax	37.0	2.6	2.5	4.0	3.1	4.7	6.0	5.5	9.3	3.5	3.5	2.9	3.1	(16)	
	PrecMin	16.2	0.4	0.1	0.4	0.3	0.4	1.1	0.9	0.9	0.6	0.4	0.1	0.4	(17)	
	PrecStd	4.0	0.7	0.7	0.9	0.7	1.1	1.2	1.3	1.7	0.8	0.9	0.7	0.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.0	54.7	63.4	74.2	80.7	87.4	90.5	90.8	80.5	70.0	57.6	50.9	(19)	
		MCWB	46.1	45.4	49.8	57.0	63.0	66.7	66.1	65.7	63.4	58.0	52.1	46.1	(20)	
	2%	DB	47.9	49.8	58.0	68.7	75.7	82.7	85.4	85.0	74.9	64.7	53.6	47.7	(21)	
		MCWB	43.6	43.9	47.6	54.4	60.6	65.3	65.3	64.9	61.4	56.3	49.2	44.5	(22)	
	5%	DB	44.3	46.8	53.7	64.8	71.6	78.5	81.5	80.7	70.9	60.8	50.6	44.7	(23)	
		MCWB	41.0	42.3	45.5	52.5	58.7	63.7	64.4	63.9	59.6	54.7	47.2	41.6	(24)	
	10%	DB	40.7	43.5	49.5	60.6	67.8	74.7	77.6	76.9	66.9	57.2	47.4	41.6	(25)	
		MCWB	38.2	39.9	43.8	50.3	56.9	62.1	63.4	62.7	57.9	52.9	45.1	39.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.1	47.2	51.0	57.8	65.5	70.1	69.3	68.8	65.1	60.0	52.7	47.2	(27)	
		MCDB	50.8	52.0	60.0	70.7	77.0	82.4	82.7	82.7	75.5	66.3	56.2	49.9	(28)	
	2%	WB	44.1	44.8	48.6	55.3	62.3	67.3	67.3	66.8	63.0	57.4	50.1	44.8	(29)	
		MCDB	47.4	48.8	55.6	66.6	72.5	78.5	79.7	79.8	71.8	62.8	53.1	47.7	(30)	
	5%	WB	41.1	42.7	46.6	53.3	59.9	65.1	65.9	65.4	61.0	55.4	47.6	41.9	(31)	
		MCDB	44.1	46.9	52.4	63.0	69.3	75.3	77.7	77.3	68.6	59.7	50.0	44.2	(32)	
	10%	WB	38.3	39.9	44.4	51.3	57.8	63.1	64.5	63.9	59.0	53.4	45.2	39.6	(33)	
		MCDB	40.6	43.5	49.1	59.4	66.1	72.4	74.7	74.3	65.1	57.0	47.3	41.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	10.9	13.6	17.2	17.5	17.9	18.5	18.9	15.9	13.1	8.7	8.0	(35)	
		MCDBR	12.0	15.2	21.9	24.8	24.5	25.3	26.0	26.1	23.0	19.3	13.7	12.2	(36)	
	5% WB	MCWBR	9.3	10.3	12.9	12.3	11.6	10.8	9.3	9.7	10.5	11.3	9.9	9.4	(37)	
		MCWBR	11.3	14.1	19.4	22.7	22.1	22.6	22.2	22.7	19.9	17.7	12.7	11.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.293	0.314	0.354	0.392	0.395	0.396	0.407	0.400	0.371	0.345	0.317	0.289	(40)	
		taud	2.398	2.370	2.322	2.261	2.286	2.309	2.281	2.318	2.370	2.431	2.462	2.440	(41)	
	Ebn at Noon		242	264	270	271	274	274	269	265	261	249	231	228	(42)	
		Edh at Noon	20	27	33	39	40	39	40	37	31	25	19	17	(43)	
(44) All-Sky Solar Radiation	RadAvg		282	563	886	1338	1572	1721	1642	1455	1036	620	299	216	(44)	
	RadStd		51	79	126	173	182	144	166	147	139	78	35	27	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
		+0.77	N/A	N/A	N/A	N/A	N/A	-256	-353	+142	N/A	(46)
(47)	Regional (71 neighbors)	+0.81	N/A	N/A	N/A	+0.61	+0.59	N/A	N/A	+99	+38	(47)

Nomenclature: See separate page