

KOCELOVICE, Czech Republic

WMO: 114870

Lat: 49.4672N

Lon: 13.8386E

Elev: 523

StdP: 95.20

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.9	-10.2	-15.6	1.0	-11.9	-12.8	1.3	-9.0	14.3	6.4	12.8	5.1	2.3	50	0.585

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	29.7	18.5	27.6	18.0	25.7	17.4	19.7	26.5	18.9	25.5	18.1	24.0	3.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	13.4	21.4	16.8	12.7	20.7	16.0	12.1	20.2	58.4	26.5	55.8	25.7	53.2	24.1	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.4	8.1	DB	-15.9	33.0	3.4	1.8	-18.3	34.3	-20.3	35.3	-22.2	36.4	-24.6	37.7	(4)
(5)			WB	-16.2	21.4	3.3	0.9	-18.6	22.0	-20.5	22.5	-22.4	23.0	-24.8	23.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	-1.5	-0.2	3.4	8.3	12.8	16.2	18.2	17.9	13.2	8.4	3.2	-0.4	(6)	
	DBStd	8.07	4.78	4.81	4.17	4.21	3.71	3.76	3.37	3.39	3.45	3.83	3.74	4.41	(7)	
	HDD10.0	1557	358	286	206	79	16	1	0	0	9	77	204	322	(8)	
	HDD18.3	3752	616	519	462	300	176	85	46	49	158	308	453	581	(9)	
	CDD10.0	950	0	0	2	29	102	187	253	244	104	27	1	0	(10)	
	CDD18.3	105	0	0	0	0	3	21	41	36	3	0	0	0	(11)	
	CDH23.3	1045	0	0	0	3	43	216	390	356	36	1	0	0	(12)	
	CDH26.7	278	0	0	0	0	6	51	114	102	6	0	0	0	(13)	
(14) Wind	WSAvg	3.6	4.2	4.1	4.1	3.7	3.5	3.1	3.2	2.9	3.0	3.3	3.7	4.0	(14)	
(15) Precipitation	PrecAvg	617	34	27	41	36	67	82	86	79	46	45	40	34	(15)	
	PrecMax	941	67	64	102	80	119	153	139	237	90	89	73	80	(16)	
	PrecMin	411	11	3	9	8	9	29	23	23	14	9	2	9	(17)	
	PrecStd	101	17	17	22	17	27	30	34	42	20	22	17	16	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	12.6	17.4	23.4	27.1	30.8	32.5	32.7	27.0	21.1	14.2	10.5	(19)	
		MCWB	7.8	7.5	9.9	13.9	17.2	19.3	19.0	18.7	17.4	14.4	11.2	7.8	(20)	
	2%	DB	8.8	9.9	14.4	20.4	24.3	28.2	29.7	29.4	23.9	18.2	12.0	8.7	(21)	
		MCWB	6.5	6.6	8.6	12.4	15.9	18.5	18.5	18.3	16.3	13.5	9.5	7.0	(22)	
	5%	DB	6.8	8.2	12.0	18.2	22.0	25.8	27.5	27.0	21.6	16.0	10.3	7.0	(23)	
		MCWB	5.0	5.7	7.5	11.4	14.8	17.6	18.0	17.7	15.3	12.6	8.5	5.4	(24)	
	10%	DB	4.9	6.4	9.7	15.9	19.9	23.7	25.3	25.0	19.4	14.0	8.6	5.3	(25)	
		MCWB	3.4	4.4	6.6	10.2	13.8	16.7	17.5	17.0	14.4	11.6	7.3	4.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.4	8.4	10.6	14.3	18.6	21.2	20.7	20.5	18.4	15.5	11.5	8.5	(27)	
		MCDB	10.4	11.1	15.6	21.5	25.0	28.0	28.2	28.2	24.2	19.1	13.4	9.9	(28)	
	2%	WB	6.7	7.1	9.2	13.0	16.8	19.6	19.6	19.3	17.2	14.1	10.0	7.1	(29)	
		MCDB	8.5	9.3	13.1	19.2	22.5	25.8	26.5	26.5	22.1	17.1	11.7	8.7	(30)	
	5%	WB	5.1	6.0	8.1	11.8	15.5	18.4	18.8	18.5	16.1	13.0	8.7	5.5	(31)	
		MCDB	6.7	8.3	11.3	17.2	20.7	24.1	25.4	25.2	20.3	15.4	10.0	6.8	(32)	
	10%	WB	3.5	4.4	6.9	10.7	14.4	17.3	18.0	17.7	15.0	11.9	7.3	4.2	(33)	
		MCDB	4.8	6.4	9.5	15.2	18.9	22.5	23.7	23.5	18.4	13.9	8.5	5.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.6	6.1	7.6	9.6	9.7	9.9	10.3	10.5	8.9	7.3	4.8	4.4	(35)	
		MCDBR	6.7	8.4	12.2	13.8	13.6	14.1	14.4	14.5	12.8	10.7	7.6	6.8	(36)	
	5% WB	MCWBR	5.2	5.7	7.2	6.8	6.4	6.0	5.1	5.4	5.9	6.3	5.5	5.2	(37)	
		MCWBR	6.3	7.8	10.8	12.6	12.3	12.6	12.3	12.6	11.0	9.8	7.1	6.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.293	0.314	0.354	0.392	0.395	0.396	0.407	0.400	0.371	0.345	0.317	0.289	(40)	
		taud	2.398	2.370	2.322	2.261	2.286	2.309	2.281	2.318	2.370	2.431	2.462	2.440	(41)	
	Ebn at Noon		763	832	851	853	864	864	847	835	823	784	728	718	(42)	
		Edh at Noon	64	84	105	124	126	124	126	116	99	79	61	54	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.89	1.77	2.79	4.22	4.96	5.42	5.18	4.59	3.27	1.96	0.94	0.68	(44)	
	RadStd		0.16	0.25	0.40	0.55	0.57	0.46	0.52	0.46	0.44	0.25	0.11	0.09	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.43	N/A	N/A	N/A	N/A	N/A	-142	-196	+79	N/A	(46)
(47)	Regional (71 neighbors)	+0.45	N/A	N/A	N/A	+0.34	+0.33	N/A	N/A	+55	+21	(47)

Nomenclature: See separate page