

USTI NAD LABEM, Czech Republic

WMO: 115020

Lat: 50.6833N

Lon: 14.0411E

Elev: 1242

StdP: 14.05

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.1	15.5	4.2	7.2	13.4	9.1	9.2	18.4	31.2	42.8	26.8	38.1	6.3	40	0.541

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.8	85.1	66.8	81.6	65.3	78.3	63.9	68.6	80.9	66.9	78.3	65.3	75.8	7.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.3	94.5	73.6	62.7	89.2	71.5	61.3	84.7	70.1	33.5	80.9	32.1	78.2	30.8	75.9	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.4	18.7	16.1	7.6	91.0	5.1	4.1	3.9	94.0	1.0	96.4	-1.9	98.7	-5.5	101.7		
			6.7	71.9	4.9	2.4	3.2	73.7	0.3	75.1	-2.5	76.5	-6.0	78.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.4	30.0	32.9	39.5	49.3	56.7	62.4	66.2	65.8	57.6	48.2	39.2	32.1	(6)
(7)		DBStd	14.72	8.26	8.06	7.53	8.35	7.06	6.76	6.59	6.15	6.32	6.81	6.57	7.72	(7)
(8)		HDD50	2568	619	479	332	113	19	1	0	0	7	116	328	554	(8)
(9)		HDD65	6324	1084	898	790	472	271	129	66	65	236	520	775	1018	(9)
(10)		CDD50	1991	0	1	7	93	228	373	501	489	234	61	4	0	(10)
(11)		CDD65	272	0	0	0	2	14	51	102	89	14	0	0	0	(11)
(12)		CDH74	1874	0	0	0	10	91	361	756	590	66	0	0	0	(12)
(13)		CDH80	473	0	0	0	0	8	82	223	154	6	0	0	0	(13)
(14)	Wind	WSAvg	7.1	7.8	7.7	8.2	7.7	7.3	7.2	6.8	6.3	6.5	6.3	6.7	7.4	(14)
(15)	Precipitation	PrecAvg	23.6	1.4	1.2	1.4	1.3	2.4	2.8	3.3	3.0	1.9	1.7	1.7	1.6	(15)
(16)		PrecMax	35.8	2.8	2.2	4.8	2.7	4.4	6.0	5.8	9.4	4.6	3.4	3.5	3.3	(16)
(17)		PrecMin	13.1	0.2	0.2	0.4	0.1	0.4	1.1	0.9	0.4	0.7	0.2	0.0	0.5	(17)
(18)		PrecStd	4.2	0.7	0.6	0.9	0.6	1.1	1.3	1.3	1.7	1.0	0.8	0.8	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.6	54.2	62.7	75.2	81.0	87.6	90.7	89.9	80.4	68.9	57.8	51.4	(19)
(20)		MCWB	46.9	47.3	50.0	57.4	63.8	69.6	68.0	68.2	63.5	58.3	52.3	47.5	(20)	
(21)		2%	DB	47.4	50.1	58.1	70.3	76.6	82.2	85.6	84.0	75.4	63.7	53.8	47.1	(21)
(22)		MCWB	43.8	44.5	47.6	55.0	61.6	65.6	66.8	66.7	61.7	55.7	49.4	43.9	(22)	
(23)		5%	DB	43.9	46.7	53.9	66.1	72.4	78.3	82.0	80.1	71.5	60.2	50.9	44.3	(23)
(24)		MCWB	40.8	42.3	45.9	53.4	59.4	64.1	65.3	65.1	60.1	54.3	47.5	41.8	(24)	
(25)		10%	DB	40.8	43.4	50.1	62.3	68.7	74.5	77.9	76.7	67.7	57.4	48.2	41.7	(25)
(26)		MCWB	38.2	39.7	44.0	51.4	57.1	62.5	63.9	63.5	58.6	53.2	45.6	39.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.5	48.5	51.6	59.0	66.4	71.7	70.8	70.3	66.6	60.1	53.1	47.6	(27)
(28)		MCDWB	50.5	53.3	59.9	72.1	78.3	83.4	84.7	84.7	76.1	65.7	57.0	50.7	(28)	
(29)		2%	WB	44.2	45.5	48.8	56.2	63.3	68.2	68.1	68.2	63.4	57.3	50.3	44.4	(29)
(30)		MCDWB	46.9	49.3	55.6	67.9	73.9	78.2	81.5	80.5	71.4	61.1	53.1	46.5	(30)	
(31)		5%	WB	41.0	42.7	46.9	54.0	60.7	65.5	66.5	66.4	61.2	55.3	47.9	42.0	(31)
(32)		MCDWB	43.7	46.0	52.3	64.3	70.1	75.5	78.6	77.3	69.2	59.3	50.3	44.1	(32)	
(33)		10%	WB	38.5	39.8	44.6	52.1	58.4	63.2	65.0	64.7	59.4	53.5	45.7	39.7	(33)
(34)		MCDWB	40.7	43.0	49.5	61.2	66.5	72.6	75.8	74.3	66.6	56.8	47.9	41.5	(34)	
(35)	Mean Daily Temperature Range		MDBR	7.0	9.0	11.7	15.0	15.6	15.7	15.8	16.1	13.7	10.4	7.0	6.5	(35)
(36)		5% DB	MCDBR	9.8	11.8	17.9	20.1	20.6	21.8	21.5	21.1	19.3	14.5	10.1	8.9	(36)
(37)			MCWBR	7.7	8.1	10.2	10.0	10.3	10.3	8.7	8.9	9.0	8.1	7.1	7.2	(37)
(38)			MCDBR	9.6	10.9	15.6	18.8	18.8	19.9	19.1	18.8	17.2	13.2	9.2	8.5	(38)
(39)		5% WB	MCWBR	8.0	8.2	9.7	9.7	10.2	10.5	8.6	8.7	8.9	8.1	7.2	7.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.305	0.328	0.371	0.414	0.415	0.412	0.428	0.422	0.384	0.359	0.332	0.300	(40)	
(41)		taud	2.370	2.347	2.265	2.190	2.222	2.259	2.221	2.259	2.337	2.386	2.411	2.395	(41)	
(42)		Ebn at Noon	229	254	261	261	267	268	261	257	254	239	216	213	(42)	
(43)		Edh at Noon	20	27	35	42	42	41	42	39	32	26	20	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	252	493	804	1286	1552	1668	1579	1385	990	575	272	189	(44)	
(45)		RadStd	43	76	118	168	182	140	182	134	135	78	35	20	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (53 neighbors)	+0.72	N/A	N/A	+0.59	+0.61	N/A	N/A	+90	+29	(47)

Nomenclature: See separate page