

PRAHA-RUZYNE, Czech Republic

WMO: 115180

Lat: 50.1003N

Lon: 14.2556E

Elev: 1199

StdP: 14.07

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.2	14.0	4.0	7.0	11.5	9.1	9.1	15.8	33.7	41.8	29.8	39.5	5.3	340	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	86.2	66.8	82.5	65.5	79.2	64.3	68.6	81.3	67.1	79.0	65.6	76.6	7.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.4	94.7	73.5	62.9	89.7	71.3	61.5	85.4	70.0	33.5	81.8	32.2	79.3	31.0	76.9	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.3	21.6	18.7	DB	4.1	92.1	6.4	3.7	-0.5	94.8	-4.3	97.0	-7.9	99.1	-12.5	101.8
			WB	3.4	72.1	6.3	1.9	-1.1	73.5	-4.8	74.6	-8.3	75.7	-12.9	77.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.1	30.0	32.8	39.3	48.3	56.0	61.9	65.7	65.2	57.1	48.2	39.1	32.4
	DBStd	14.51	8.88	8.71	7.54	7.61	6.59	6.60	6.06	5.81	6.14	6.80	6.77	8.25
	HDD50	2581	619	482	336	120	20	1	0	0	9	117	332	545
	HDD65	6398	1084	902	795	502	288	136	67	69	246	522	777	1010
	CDD50	1884	0	1	6	68	205	359	487	471	223	60	4	0
	CDD65	225	0	0	0	0	8	43	89	75	10	0	0	0
	CDH74	2236	0	0	0	13	106	443	853	724	96	1	0	0
	CDH80	617	0	0	0	1	12	114	267	208	15	0	0	0
(14) Wind	WSAvg	8.7	10.1	9.9	10.1	8.7	8.1	7.7	7.8	7.5	8.0	8.1	8.5	9.6
(15) Precipitation	PrecAvg	19.2	0.8	0.7	1.1	1.2	2.7	2.7	2.8	2.6	1.5	1.3	1.1	1.0
	PrecMax	27.8	2.3	1.8	3.5	3.2	6.5	5.6	8.9	6.8	3.7	4.3	3.2	2.0
	PrecMin	12.0	0.2	0.0	0.2	0.1	0.7	0.6	0.2	0.6	0.2	0.2	0.3	0.1
	PrecStd	3.5	0.4	0.4	0.6	0.7	1.4	1.3	1.7	1.4	0.9	0.9	0.6	0.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.5	54.8	64.8	75.5	81.9	88.7	91.6	91.4	82.2	71.2	58.6	51.5
		MCWB	47.3	46.6	51.8	58.1	64.4	68.4	66.9	67.8	64.8	59.5	52.8	47.5
	2%	DB	48.4	50.9	59.0	70.4	77.0	83.2	86.4	85.3	76.5	65.3	54.7	48.7
		MCWB	44.8	45.3	48.4	55.7	62.1	66.6	66.6	66.3	62.4	57.1	50.1	45.4
	5%	DB	45.1	47.8	54.7	66.2	72.7	79.1	82.6	81.3	72.4	61.6	51.7	45.8
		MCWB	41.8	43.3	46.6	53.7	59.9	64.4	65.5	65.2	60.7	55.2	48.0	42.9
	10%	DB	41.6	44.5	50.6	62.2	69.1	75.2	78.7	77.7	68.4	58.3	48.5	42.8
		MCWB	39.0	40.7	44.6	51.4	57.9	62.9	64.5	63.8	59.0	53.8	45.6	40.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.2	48.3	52.4	59.8	66.6	71.5	70.4	70.2	65.9	60.7	53.6	48.3
		MCDB	52.0	53.4	61.9	73.7	78.6	84.1	85.0	83.7	77.8	68.1	58.2	50.7
	2%	WB	44.9	45.8	49.8	56.6	63.4	68.1	68.3	68.2	63.6	58.2	50.7	45.8
		MCDB	48.0	50.0	57.0	68.0	73.9	79.7	81.0	80.9	73.4	63.7	54.1	48.6
	5%	WB	42.0	43.4	47.6	54.5	61.1	65.8	66.9	66.6	61.9	56.1	48.3	42.9
		MCDB	44.9	47.3	53.5	64.7	70.9	76.7	78.9	78.4	70.4	60.7	51.4	45.6
	10%	WB	39.2	40.9	45.1	52.2	59.0	63.7	65.5	64.9	60.0	54.0	45.9	40.5
		MCDB	41.5	44.5	50.2	60.8	67.6	73.2	76.4	75.2	67.3	58.0	48.2	42.6
(35) Mean Daily Temperature Range	5% DB	MDBR	8.6	11.2	14.2	18.2	18.6	18.8	19.1	19.4	16.7	13.7	9.3	8.2
		MCDBR	11.1	14.8	21.8	25.1	25.1	25.5	26.0	25.6	23.4	18.8	13.4	11.0
		MCWBR	8.9	10.3	13.2	13.0	13.0	11.8	10.2	10.5	11.5	11.5	9.7	8.9
	5% WB	MCDBR	10.8	13.7	19.3	23.2	22.8	23.2	22.5	22.4	21.1	17.6	12.6	10.7
		MCWBR	9.1	10.0	12.4	12.7	12.6	11.5	9.7	10.0	11.0	11.4	9.6	9.0
(40) Clear-Sky Solar Irradiance	taub		0.302	0.322	0.363	0.404	0.405	0.405	0.419	0.413	0.379	0.355	0.328	0.297
	taud		2.400	2.382	2.308	2.231	2.258	2.284	2.250	2.288	2.356	2.408	2.440	2.431
	Ebn at Noon		235	259	265	266	271	271	265	260	257	242	222	220
	Edh at Noon		20	26	34	40	41	40	41	38	32	25	19	17
(44) All-Sky Solar Radiation	RadAvg		269	527	842	1311	1570	1695	1607	1420	1012	590	281	201
	RadStd		47	75	128	171	181	140	177	141	137	82	35	22

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.86	N/A	N/A	N/A	+0.72	N/A	N/A	-295	+162	+65
(47)	Regional (61 neighbors)	+0.77	N/A	N/A	N/A	+0.59	+0.58	N/A	N/A	+97	+34

Nomenclature: See separate page