

PRAHA-LIBUS, Czech Republic

WMO: 115200

Lat: 50.0078N

Lon: 14.4469E

Elev: 991

StdP: 14.18

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.0	15.5	5.7	7.7	12.9	10.1	9.6	18.3	18.6	43.2	16.5	42.0	3.3	0	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	88.5	67.1	84.6	65.8	81.3	64.5	69.1	83.0	67.5	80.4	66.1	77.8	5.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.8	95.2	72.7	63.4	90.7	71.4	62.0	86.3	70.3	33.7	83.3	32.5	80.4	31.3	78.1	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.9	12.9	11.4	5.9	94.3	6.5	4.1	1.3	97.3	-2.5	99.7	-6.2	101.9	-10.9	104.9
			5.3	72.1	6.4	1.8	0.7	73.4	-3.1	74.4	-6.7	75.4	-11.4	76.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.6	31.5	34.3	40.7	49.7	57.7	63.9	67.5	66.9	58.4	49.4	40.3	33.8	
	DBStd	14.64	8.88	8.59	7.39	7.71	6.75	6.76	6.11	5.95	6.30	6.97	6.74	8.15	
	HDD50	2325	573	442	297	98	13	0	0	5	97	297	503		
	HDD65	5950	1037	860	753	459	242	102	44	215	483	740	967		
	CDD50	2176	0	2	9	90	251	417	542	523	256	79	7	0	
	CDD65	328	0	0	0	1	16	68	120	106	16	1	0	0	
	CDH74	3256	0	0	0	26	183	664	1193	1031	156	3	0	0	
	CDH80	1017	0	0	0	2	32	195	422	336	30	0	0	0	
Wind	WSAvg	5.2	5.9	5.8	6.0	5.4	5.2	4.8	4.7	4.3	4.4	4.7	5.0	5.6	
Precipitation	PrecAvg	20.5	1.0	0.8	1.1	1.2	2.5	3.2	3.0	2.8	1.8	1.3	1.3	1.1	
	PrecMax	30.4	2.2	2.0	3.6	2.8	6.0	7.7	6.8	7.3	4.3	3.3	3.0	2.1	
	PrecMin	11.7	0.3	0.1	0.2	0.0	0.6	0.7	0.2	0.3	0.2	0.3	0.2	0.0	
	PrecStd	3.9	0.5	0.5	0.6	0.7	1.2	1.5	1.6	1.6	1.0	0.8	0.6	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.2	56.5	66.3	77.6	84.0	90.5	93.6	93.5	84.2	72.9	60.3	53.0	
		MCWB	47.8	46.4	51.1	58.3	64.3	69.1	68.0	67.7	64.9	59.6	53.4	48.0	
	2%	DB	50.1	52.6	60.6	72.2	79.1	85.3	88.8	87.4	78.3	67.1	56.1	50.2	
		MCWB	45.1	45.7	48.8	55.7	61.9	66.9	66.9	66.5	62.6	57.7	50.8	46.0	
	5%	DB	46.7	49.3	56.5	68.0	74.7	81.2	84.6	83.4	74.2	63.5	53.1	47.3	
		MCWB	42.6	43.7	47.2	54.1	59.9	64.6	65.9	65.4	61.2	56.2	48.7	43.5	
	10%	DB	43.3	46.1	52.4	63.9	71.0	77.4	80.8	79.8	70.2	59.9	50.0	44.2	
		MCWB	39.9	41.4	45.3	51.7	58.1	63.0	64.6	64.1	59.5	54.3	46.4	41.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.9	48.6	52.7	59.5	66.5	71.7	70.9	70.7	66.5	61.4	54.5	49.0
			MCDB	53.3	54.1	62.7	74.2	79.7	87.0	86.3	85.0	78.7	68.8	59.0	52.1
2%		WB	45.7	46.4	50.2	57.0	63.6	68.6	68.8	68.7	64.2	59.1	51.5	46.5	
		MCDB	49.5	51.4	58.3	69.1	75.3	81.3	83.1	82.4	74.5	65.2	55.2	50.1	
5%		WB	42.9	44.0	48.2	54.8	61.3	66.3	67.4	67.1	62.5	56.9	49.2	43.7	
		MCDB	46.4	48.9	55.2	66.3	72.1	78.1	80.0	79.8	71.2	62.2	52.4	47.0	
10%		WB	40.2	41.6	45.8	52.8	59.4	64.2	66.0	65.6	60.7	54.9	46.8	41.4	
		MCDB	43.2	46.0	51.7	62.5	69.2	74.1	77.4	76.6	68.9	59.4	49.6	44.0	
Mean Daily Temperature Range	5% DB	MDBR	8.5	11.2	14.1	17.9	18.7	18.5	19.1	19.6	16.9	13.7	9.2	8.0	
		MCDBR	11.3	14.9	22.6	25.1	25.1	25.7	26.4	26.4	24.2	19.5	13.0	10.8	
		MCWBR	8.6	9.7	12.8	11.9	11.2	10.1	8.8	9.3	10.5	10.9	8.8	8.2	
	5% WB	MCDBR	11.0	13.6	19.7	23.4	22.6	23.5	22.6	22.7	20.8	17.9	12.2	10.4	
		MCWBR	8.8	9.4	11.9	11.7	10.7	10.1	8.5	9.0	9.9	10.7	8.9	8.3	
Clear-Sky Solar Irradiance	taub	0.306	0.327	0.369	0.410	0.412	0.412	0.426	0.420	0.385	0.360	0.332	0.302		
	taud	2.389	2.368	2.292	2.211	2.242	2.271	2.237	2.274	2.341	2.393	2.426	2.422		
	Ebn at Noon	233	257	263	264	269	269	263	258	255	240	220	218		
	Edh at Noon	20	27	34	41	42	41	42	38	32	26	20	17		
All-Sky Solar Radiation	RadAvg	272	533	850	1318	1578	1704	1614	1431	1019	592	283	204		
	RadStd	48	75	131	172	180	139	178	142	137	85	35	22		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.99	N/A	N/A	+1.44	+1.01	+0.86	N/A	-342	+198	+76
(47)	Regional (66 neighbors)	+0.79	N/A	N/A	N/A	+0.59	+0.56	N/A	N/A	+99	+36

Nomenclature: See separate page