

PRAHA-LIBUS, Czech Republic

WMO: 115200

Lat: 50.0078N

Lon: 14.4469E

Elev: 302

StdP: 97.75

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.7	-9.2	-14.6	1.1	-10.6	-12.2	1.4	-7.6	8.3	6.2	7.4	5.6	1.5	0	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	31.4	19.5	29.2	18.8	27.4	18.0	20.6	28.3	19.7	26.9	19.0	25.4	2.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	13.6	22.6	17.4	13.0	21.9	16.7	12.3	21.3	60.6	28.5	57.7	26.9	55.0	25.6	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.6	5.8	5.1	-14.5	34.6	3.6	2.3	-17.1	36.3	-19.2	37.6	-21.2	38.9	-23.8	40.5		
(5)			-14.8	22.3	3.6	1.0	-17.4	23.0	-19.5	23.6	-21.5	24.1	-24.1	24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.8	-0.3	1.3	4.8	9.9	14.3	17.7	19.7	19.4	14.6	9.7	4.6	1.0	(6)
(7)		DBStd	8.13	4.94	4.77	4.11	4.28	3.75	3.76	3.39	3.30	3.50	3.87	3.74	4.53	(7)
(8)		HDD10.0	1292	318	246	165	54	7	0	0	0	3	54	165	279	(8)
(9)		HDD18.3	3306	576	478	418	255	134	57	24	27	119	268	411	537	(9)
(10)		CDD10.0	1209	0	1	5	50	139	232	301	291	142	44	4	0	(10)
(11)		CDD18.3	182	0	0	0	1	9	38	67	59	9	1	0	0	(11)
(12)		CDH23.3	1809	0	0	0	14	102	369	663	573	87	2	0	0	(12)
(13)		CDH26.7	565	0	0	0	1	18	108	234	187	17	0	0	0	(13)
(14)	Wind	WSAvg	2.3	2.6	2.6	2.7	2.4	2.3	2.2	2.1	1.9	2.0	2.1	2.2	2.5	(14)
(15)	Precipitation	PrecAvg	521	25	21	29	30	63	81	76	72	46	33	32	27	(15)
(16)		PrecMax	773	56	50	92	71	152	195	172	186	108	84	75	53	(16)
(17)		PrecMin	296	7	3	6	1	14	18	5	7	4	7	6	1	(17)
(18)		PrecStd	100	12	12	16	17	31	38	40	41	26	20	15	14	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	13.6	19.0	25.3	28.9	32.5	34.2	34.2	29.0	22.7	15.7	11.6	(19)
(20)			MCWB	8.8	8.0	10.6	14.6	17.9	20.6	20.0	19.9	18.3	15.3	11.9	8.9	(20)
(21)		2%	DB	10.0	11.4	15.9	22.3	26.2	29.6	31.6	30.8	25.7	19.5	13.4	10.1	(21)
(22)			MCWB	7.3	7.6	9.3	13.2	16.6	19.4	19.4	19.1	17.0	14.3	10.5	7.8	(22)
(23)		5%	DB	8.2	9.6	13.6	20.0	23.7	27.3	29.2	28.6	23.4	17.5	11.7	8.5	(23)
(24)			MCWB	5.9	6.5	8.4	12.3	15.5	18.1	18.8	18.5	16.2	13.4	9.3	6.4	(24)
(25)		10%	DB	6.3	7.8	11.3	17.7	21.7	25.2	27.1	26.5	21.2	15.5	10.0	6.8	(25)
(26)			MCWB	4.4	5.2	7.4	10.9	14.5	17.2	18.1	17.8	15.3	12.4	8.0	5.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	9.2	11.5	15.3	19.2	22.1	21.6	21.5	19.2	16.3	12.5	9.4	(27)
(28)			MCDWB	11.8	12.3	17.0	23.4	26.5	30.5	30.2	29.5	25.9	20.5	15.0	11.2	(28)
(29)		2%	WB	7.6	8.0	10.1	13.9	17.6	20.3	20.4	20.4	17.9	15.0	10.8	8.1	(29)
(30)			MCDWB	9.7	10.8	14.6	20.6	24.0	27.4	28.4	28.0	23.6	18.5	12.9	10.0	(30)
(31)		5%	WB	6.0	6.7	9.0	12.7	16.3	19.1	19.7	19.5	16.9	13.8	9.5	6.5	(31)
(32)			MCDWB	8.0	9.4	12.9	19.1	22.3	25.6	26.7	26.5	21.8	16.8	11.3	8.3	(32)
(33)		10%	WB	4.5	5.3	7.7	11.5	15.2	17.9	18.9	18.7	16.0	12.7	8.2	5.2	(33)
(34)			MCDWB	6.2	7.8	11.0	17.0	20.7	23.4	25.2	24.8	20.5	15.2	9.8	6.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.7	6.2	7.8	10.0	10.4	10.3	10.6	10.9	9.4	7.6	5.1	4.4	(35)
(36)			MCDBR	6.3	8.3	12.6	13.9	14.0	14.3	14.7	14.7	13.4	10.8	7.2	6.0	(36)
(37)			MCWBR	4.8	5.4	7.1	6.6	6.2	5.6	4.9	5.1	5.9	6.1	4.9	4.5	(37)
(38)		5% WB	MCDWB	6.1	7.6	11.0	13.0	12.6	13.1	12.5	12.6	11.6	9.9	6.8	5.8	(38)
(39)			MCWBR	4.9	5.2	6.6	6.5	5.9	5.6	4.7	5.0	5.5	5.9	5.0	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.306	0.327	0.369	0.410	0.412	0.412	0.426	0.420	0.385	0.360	0.332	0.302	(40)	
(41)		taud	2.389	2.368	2.292	2.211	2.242	2.271	2.237	2.274	2.341	2.393	2.426	2.422	(41)	
(42)		Ebn at Noon	735	809	830	831	847	848	828	814	804	758	695	687	(42)	
(43)		Edh at Noon	64	84	107	130	131	129	131	121	102	81	63	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.86	1.68	2.68	4.15	4.98	5.37	5.09	4.51	3.21	1.87	0.89	0.64	(44)	
(45)		RadStd	0.15	0.24	0.41	0.54	0.57	0.44	0.56	0.45	0.43	0.27	0.11	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.55	N/A	N/A	+0.80	+0.56	+0.48	N/A	-190	+110	+42
(47) Regional (66 neighbors)		+0.44	N/A	N/A	N/A	+0.33	+0.31	N/A	N/A	+55	+20

Nomenclature: See separate page