

TEMELIN, Czech Republic

WMO: 115380

Lat: 49.1978N

Lon: 14.3422E

Elev: 1667

StdP: 13.83

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.2	14.1	4.3	7.3	11.3	9.4	9.5	16.0	28.9	42.4	25.6	39.9	5.2	40	0.565

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	85.9	65.7	82.2	64.8	78.9	63.7	68.1	80.2	66.5	78.2	65.1	75.8	7.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.1	95.4	72.0	62.6	90.2	70.2	61.2	85.7	69.0	33.3	80.1	32.0	78.5	30.9	76.0	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.6	19.3	16.7	DB	2.6	91.5	7.0	3.7	-2.4	94.2	-6.5	96.3	-10.4	98.3	-15.5	101.0	(4)
			WB	2.0	71.5	6.9	2.5	-2.9	73.3	-7.0	74.8	-10.8	76.2	-15.9	78.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	47.7	29.5	32.2	38.9	47.8	55.7	61.9	65.5	65.1	56.5	47.9	38.8	31.8	(6)
(7)		DBStd	14.69	8.74	8.71	7.75	7.79	6.81	6.87	6.21	6.13	6.27	7.00	7.00	7.99	(7)
(8)		HDD50	2688	637	500	351	130	24	2	0	0	13	125	340	566	(8)
(9)		HDD65	6543	1102	920	810	516	297	140	72	75	264	531	785	1031	(9)
(10)		CDD50	1851	0	1	6	65	200	358	481	469	207	59	5	0	(10)
(11)		CDD65	229	0	0	0	1	8	46	88	78	8	0	0	0	(11)
(12)		CDH74	2062	0	0	0	11	81	412	780	701	76	1	0	0	(12)
(13)		CDH80	560	0	0	0	0	9	104	229	206	12	0	0	0	(13)
(14)	Wind	WSAvg	7.6	8.3	8.4	8.7	8.1	7.8	7.2	7.2	6.6	6.8	6.9	7.3	8.0	(14)
(15)	Precipitation	PrecAvg	24.7	1.2	0.9	1.5	1.5	2.8	3.6	3.6	3.2	2.1	1.7	1.5	1.1	(15)
(16)		PrecMax	40.4	2.8	2.1	3.7	3.3	4.5	7.4	6.4	12.7	5.2	4.0	2.6	2.2	(16)
(17)		PrecMin	17.9	0.3	0.2	0.6	0.2	0.2	1.1	1.1	0.8	0.3	0.3	0.0	0.2	(17)
(18)		PrecStd	4.5	0.6	0.6	0.7	0.8	1.0	1.4	1.5	2.2	1.0	0.9	0.6	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.0	56.2	64.7	75.5	80.7	88.1	91.0	90.9	81.0	70.3	59.6	51.2	(19)
(20)		MCWB	46.1	45.8	49.9	58.2	62.8	66.7	67.1	65.0	63.8	57.8	52.8	46.4	(20)	
(21)		2%	DB	47.6	51.0	59.2	69.5	76.1	83.1	85.7	85.4	75.6	65.2	54.9	47.6	(21)
(22)		MCWB	43.0	44.3	48.4	54.9	61.5	66.0	65.8	65.1	61.9	56.9	49.8	44.2	(22)	
(23)		5%	DB	44.1	47.5	54.6	65.4	72.2	78.8	81.9	81.2	71.3	61.4	51.3	44.9	(23)
(24)		MCWB	40.7	42.3	46.1	52.9	59.6	64.1	65.0	64.2	60.3	55.0	47.9	42.0	(24)	
(25)		10%	DB	41.0	43.8	50.4	61.5	68.5	75.0	78.3	77.5	67.4	58.1	48.2	42.1	(25)
(26)		MCWB	38.4	39.7	44.0	51.0	57.7	62.4	63.9	63.2	58.4	53.5	45.6	39.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.0	47.5	51.6	59.2	65.7	70.2	70.8	69.2	65.6	60.3	53.8	46.8	(27)
(28)		MDCB	50.9	53.5	60.7	72.4	76.9	83.0	83.1	81.9	75.3	66.2	57.7	49.9	(28)	
(29)		2%	WB	43.8	45.0	48.9	56.1	62.6	67.7	68.0	67.2	63.3	57.9	50.7	44.8	(29)
(30)		MDCB	47.1	49.9	57.1	67.2	73.5	78.7	80.4	79.9	72.3	63.0	54.1	47.5	(30)	
(31)		5%	WB	41.0	42.5	47.0	53.8	60.4	65.4	66.4	65.8	61.3	55.9	48.2	42.2	(31)
(32)		MDCB	43.7	47.2	53.6	63.2	70.3	75.9	78.0	77.7	68.9	60.3	50.9	44.4	(32)	
(33)		10%	WB	38.5	39.8	44.6	51.8	58.4	63.4	65.0	64.3	59.6	54.0	45.9	39.9	(33)
(34)		MDCB	40.8	43.6	49.7	60.5	66.9	73.0	75.6	74.6	66.0	57.7	47.9	41.9	(34)	
(35)	Mean Daily Temperature Range	MDBR	8.6	11.2	13.8	17.1	17.1	17.5	18.1	18.4	15.6	13.1	8.7	8.3	(35)	
(36)		5% DB	MCDBR	12.4	16.4	21.9	23.7	23.4	24.3	24.6	24.7	22.0	18.4	13.5	11.9	(36)
(37)		MCWBR	9.3	10.9	12.7	12.0	11.7	10.5	9.4	9.3	10.1	11.0	9.2	9.1	(37)	
(38)		5% WB	MCDBR	11.7	15.3	19.6	21.9	21.2	21.6	21.2	21.3	19.1	16.7	12.3	11.3	(38)
(39)		MCWBR	9.2	10.7	11.9	11.6	11.1	10.1	9.0	9.2	9.7	10.5	9.0	9.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.292	0.313	0.353	0.391	0.395	0.396	0.407	0.401	0.372	0.345	0.318	0.290	(40)	
(41)		taud	2.401	2.376	2.325	2.263	2.287	2.311	2.282	2.316	2.367	2.427	2.458	2.447	(41)	
(42)		Ebn at Noon	244	265	271	271	274	274	269	265	261	249	232	229	(42)	
(43)		Edh at Noon	21	27	33	39	40	39	40	37	32	25	20	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	296	577	903	1347	1585	1729	1654	1469	1045	628	309	228	(44)	
(45)		RadStd	51	78	130	174	183	144	167	147	138	81	37	27	(45)	

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (84 neighbors)	+0.86	N/A	N/A	N/A	+0.61	+0.58	N/A	N/A	+108	+41	(47)

Nomenclature: See separate page