

TEMELIN, Czech Republic

WMO: 115380

Lat: 49.1978N

Lon: 14.3422E

Elev: 508

StdP: 95.37

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.7	-9.9	-15.4	1.0	-11.5	-12.6	1.4	-8.9	12.9	5.8	11.4	4.4	2.3	40	0.565

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	29.9	18.7	27.9	18.2	26.0	17.6	20.1	26.8	19.2	25.7	18.4	24.3	3.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	13.6	22.2	17.0	12.9	21.2	16.2	12.2	20.6	59.6	26.7	56.5	25.9	53.9	24.5	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	8.6	7.5	-16.3	33.1	3.9	2.0	-19.1	34.5	-21.4	35.7	-23.6	36.9	-26.4	38.3		
(5)			-16.6	22.0	3.8	1.4	-19.4	23.0	-21.6	23.8	-23.8	24.6	-26.6	25.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	-1.4	0.1	3.8	8.8	13.2	16.6	18.6	18.4	13.6	8.8	3.8	-0.1	(6)
(7)		DBStd	8.16	4.86	4.84	4.31	4.33	3.78	3.82	3.45	3.40	3.48	3.89	3.89	4.44	(7)
(8)		HDD10.0	1493	354	278	195	72	13	1	0	0	7	69	189	314	(8)
(9)		HDD18.3	3635	612	511	450	287	165	78	40	42	147	295	436	573	(9)
(10)		CDD10.0	1028	0	1	3	36	111	199	267	261	115	33	3	0	(10)
(11)		CDD18.3	127	0	0	0	1	4	26	49	43	4	0	0	0	(11)
(12)		CDH23.3	1146	0	0	0	6	45	229	433	389	42	1	0	0	(12)
(13)		CDH26.7	311	0	0	0	0	5	58	127	114	7	0	0	0	(13)
(14)	Wind	WSAvg	3.4	3.7	3.8	3.9	3.6	3.5	3.2	3.2	2.9	3.1	3.1	3.3	3.6	(14)
(15)	Precipitation	PrecAvg	627	30	23	39	37	71	91	91	81	54	43	38	29	(15)
(16)		PrecMax	1026	72	53	93	85	114	189	163	323	132	101	66	57	(16)
(17)		PrecMin	455	8	4	14	4	5	27	27	20	7	8	1	6	(17)
(18)		PrecStd	114	15	14	19	20	26	36	37	56	26	23	15	14	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	13.5	18.1	24.2	27.1	31.2	32.8	32.7	27.2	21.3	15.4	10.7	(19)
(20)			MCWB	7.8	7.7	9.9	14.5	17.1	19.3	19.5	18.3	17.6	14.3	11.5	8.0	(20)
(21)		2%	DB	8.7	10.5	15.1	20.8	24.5	28.4	29.8	29.7	24.2	18.4	12.7	8.7	(21)
(22)			MCWB	6.1	6.8	9.1	12.7	16.4	18.9	18.8	18.4	16.6	13.8	9.9	6.8	(22)
(23)		5%	DB	6.7	8.6	12.6	18.6	22.4	26.0	27.7	27.3	21.9	16.3	10.7	7.2	(23)
(24)			MCWB	4.8	5.7	7.9	11.6	15.3	17.8	18.3	17.9	15.7	12.8	8.8	5.5	(24)
(25)		10%	DB	5.0	6.5	10.2	16.4	20.3	23.9	25.7	25.3	19.7	14.5	9.0	5.6	(25)
(26)			MCWB	3.5	4.3	6.7	10.6	14.3	16.9	17.7	17.3	14.6	12.0	7.6	4.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	8.6	10.9	15.1	18.7	21.2	21.6	20.7	18.7	15.7	12.1	8.2	(27)
(28)			MCDWB	10.5	12.0	15.9	22.5	24.9	28.3	28.4	27.7	24.1	19.0	14.3	9.9	(28)
(29)		2%	WB	6.5	7.2	9.4	13.4	17.0	19.8	20.0	19.6	17.4	14.4	10.4	7.1	(29)
(30)			MCDWB	8.4	10.0	14.0	19.6	23.1	25.9	26.9	26.6	22.4	17.2	12.3	8.6	(30)
(31)		5%	WB	5.0	5.9	8.3	12.1	15.8	18.6	19.1	18.8	16.3	13.3	9.0	5.6	(31)
(32)			MCDWB	6.5	8.4	12.0	17.3	21.3	24.4	25.6	25.4	20.5	15.7	10.5	6.9	(32)
(33)		10%	WB	3.6	4.4	7.0	11.0	14.7	17.5	18.3	18.0	15.3	12.2	7.7	4.4	(33)
(34)			MCDWB	4.9	6.4	9.8	15.8	19.4	22.8	24.2	23.7	18.9	14.3	8.8	5.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.8	6.2	7.7	9.5	9.5	9.7	10.1	10.2	8.7	7.3	4.8	4.6	(35)
(36)			MCDBR	6.9	9.1	12.2	13.2	13.0	13.5	13.7	13.7	12.2	10.2	7.5	6.6	(36)
(37)			MCWBR	5.2	6.1	7.1	6.7	6.5	5.8	5.2	5.1	5.6	6.1	5.1	5.1	(37)
(38)		5% WB	MCDWR	6.5	8.5	10.9	12.2	11.8	12.0	11.8	11.8	10.6	9.3	6.8	6.3	(38)
(39)			MCWBR	5.1	5.9	6.6	6.5	6.2	5.6	5.0	5.1	5.4	5.8	5.0	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.292	0.313	0.353	0.391	0.395	0.396	0.407	0.401	0.372	0.345	0.318	0.290	(40)	
(41)		taud	2.401	2.376	2.325	2.263	2.287	2.311	2.282	2.316	2.367	2.427	2.458	2.447	(41)	
(42)		Ebn at Noon	769	835	853	854	865	864	847	835	823	786	731	723	(42)	
(43)		Edh at Noon	65	84	105	124	126	124	126	116	100	80	62	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.93	1.82	2.85	4.25	5.00	5.45	5.21	4.63	3.29	1.98	0.97	0.72	(44)	
(45)		RadStd	0.16	0.24	0.41	0.55	0.58	0.45	0.53	0.46	0.44	0.26	0.12	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (84 neighbors)		+0.48	N/A	N/A	N/A	+0.34	+0.32	N/A	N/A	+60	+23

Nomenclature: See separate page