

PRAHA-KBELY, Czech Republic

WMO: 115670

Lat: 50.1233N

Lon: 14.5381E

Elev: 937

StdP: 14.21

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.2	14.8	4.8	7.3	12.3	10.0	9.5	17.3	25.5	43.1	23.2	41.6	3.5	70	0.518

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	86.6	67.4	83.0	66.1	80.0	65.0	69.6	81.4	68.0	78.9	66.5	76.6	6.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.0	99.2	73.1	64.4	93.8	71.6	62.9	88.8	70.5	34.1	81.5	32.8	79.0	31.6	76.7	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.7	17.9	15.6	DB	4.9	93.3	6.2	3.7	0.5	95.9	-3.1	98.1	-6.6	100.2	-11.1	102.9	(4)
(5)			WB	4.3	73.3	6.1	2.4	0.0	75.0	-3.6	76.4	-7.0	77.7	-11.4	79.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.3	30.9	34.0	40.4	49.6	57.6	63.6	67.0	66.7	58.3	49.2	40.1	33.3	(6)
(7)		DBStd	14.66	9.21	8.46	7.44	7.40	6.48	6.33	5.84	5.76	6.11	6.77	6.73	8.32	(7)
(8)		HDD50	2380	593	451	306	96	11	0	0	0	5	98	303	517	(8)
(9)		HDD65	6025	1058	869	764	464	241	100	46	48	216	491	747	981	(9)
(10)		CDD50	2128	0	2	8	83	248	410	528	517	253	73	6	0	(10)
(11)		CDD65	296	0	0	0	1	13	59	109	99	14	1	0	0	(11)
(12)		CDH74	2547	0	0	0	17	142	497	914	853	122	2	0	0	(12)
(13)		CDH80	714	0	0	0	1	19	126	285	262	21	0	0	0	(13)
(14)	Wind	WSAvg	6.7	7.7	7.6	7.7	6.7	6.3	6.0	6.3	5.7	5.9	6.3	6.6	7.6	(14)
(15)	Precipitation	PrecAvg	21.9	1.1	1.0	1.3	1.1	2.4	3.0	3.1	2.8	1.9	1.4	1.4	1.3	(15)
(16)		PrecMax	32.6	2.3	2.0	4.0	2.5	5.3	6.9	5.2	7.0	3.8	3.1	3.0	2.3	(16)
(17)		PrecMin	14.2	0.3	0.1	0.3	0.1	0.6	0.8	0.2	1.1	0.5	0.2	0.0	0.3	(17)
(18)		PrecStd	4.0	0.6	0.5	0.8	0.6	1.1	1.1	1.2	1.5	1.0	0.7	0.7	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.0	56.0	65.7	76.6	82.6	88.8	91.7	92.6	82.9	72.1	59.9	52.2	(19)
(20)			MCWB	48.4	47.5	52.0	60.0	65.6	69.8	68.5	67.6	65.0	59.6	54.2	47.8	(20)
(21)		2%	DB	50.1	52.4	60.3	71.2	78.2	83.7	86.5	86.2	77.3	66.2	55.6	49.4	(21)
(22)			MCWB	46.0	46.4	49.7	56.5	63.0	67.5	67.1	66.9	63.1	57.8	51.4	45.7	(22)
(23)		5%	DB	46.7	49.4	56.0	67.1	74.0	79.6	82.7	82.3	73.4	62.6	52.6	46.5	(23)
(24)			MCWB	43.2	44.5	47.6	54.6	60.8	65.1	66.0	65.8	61.3	56.3	48.9	43.4	(24)
(25)		10%	DB	43.1	45.9	51.9	62.9	70.3	76.0	79.1	78.7	69.6	59.2	49.8	43.8	(25)
(26)			MCWB	40.3	41.7	45.6	52.1	58.6	63.6	64.9	64.7	60.0	54.8	47.1	41.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.7	49.3	53.7	60.6	67.5	72.4	71.4	71.0	67.3	61.8	55.2	48.8	(27)
(28)			MCDWB	53.5	53.8	62.3	74.7	79.3	83.7	85.0	82.4	77.8	67.7	59.1	51.3	(28)
(29)		2%	WB	46.5	47.1	50.8	57.7	64.4	69.3	69.1	69.1	64.6	59.3	51.9	46.1	(29)
(30)			MCDWB	49.7	51.6	58.0	68.7	74.3	80.0	81.4	80.5	73.9	64.3	55.0	49.0	(30)
(31)		5%	WB	43.4	44.6	48.5	55.5	62.1	66.9	67.6	67.5	62.7	57.1	49.5	43.6	(31)
(32)			MCDWB	46.3	48.9	54.4	65.4	71.6	76.6	78.7	78.1	71.0	61.7	52.0	45.9	(32)
(33)		10%	WB	40.5	41.9	46.2	53.4	60.1	64.7	66.2	66.0	60.9	55.2	47.1	41.4	(33)
(34)			MCDWB	42.8	45.6	51.4	61.8	68.6	73.3	76.1	75.7	68.2	59.2	49.2	43.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.7	11.1	14.3	17.8	17.8	17.2	17.3	18.3	16.2	13.3	9.4	8.3	(35)
(36)			MCDBR	11.8	14.6	22.4	24.8	24.3	24.0	24.3	24.6	23.1	18.6	13.0	11.5	(36)
(37)			MCWBR	9.2	9.8	13.2	12.8	11.8	10.6	9.0	9.1	10.7	11.2	9.3	8.9	(37)
(38)		5% WB	MCDWR	11.3	13.7	19.5	22.8	22.1	22.0	21.2	21.1	20.0	17.5	12.2	10.8	(38)
(39)			MCWBR	9.3	9.7	12.1	12.4	11.5	10.6	9.0	9.1	10.0	11.3	9.4	8.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.305	0.326	0.367	0.409	0.410	0.410	0.425	0.419	0.384	0.359	0.332	0.301	(40)	
(41)		taud	2.390	2.370	2.296	2.218	2.247	2.275	2.241	2.278	2.347	2.397	2.429	2.422	(41)	
(42)		Ebn at Noon	233	257	264	264	269	269	263	258	255	240	220	218	(42)	
(43)		Edh at Noon	20	26	34	41	42	41	42	38	32	26	20	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	269	524	841	1314	1578	1700	1607	1425	1015	587	279	200	(44)	
(45)		RadStd	47	75	131	171	180	139	180	141	137	85	35	21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+1.57	+1.12	N/A	N/A	N/A	N/A	+70
(47) Regional (60 neighbors)		+0.81	N/A	N/A	N/A	+0.61	+0.59	N/A	N/A	+104	+36

Nomenclature: See separate page