

KOSTELNI MYSLOVA, Czech RepublicWMO: **116360**Lat: **49.1592N**Lon: **15.4392E**Elev: **1878**StdP: **13.73**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.8	13.4	3.3	7.0	10.4	8.6	9.1	16.1	25.5	31.5	22.5	33.6	4.6	340	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	85.0	65.4	81.1	64.6	78.0	63.2	67.6	79.6	66.1	77.6	64.6	75.3	7.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.6	94.5	72.0	62.0	89.1	69.9	60.6	84.8	68.7	33.1	80.1	31.8	78.0	30.6	75.4	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.6	16.7	14.5	DB	3.4	90.2	5.0	4.0	-0.2	93.1	-3.1	95.4	-5.9	97.6	-9.6	100.5	(4)
			WB	2.8	70.5	4.9	1.7	-0.7	71.8	-3.6	72.8	-6.3	73.8	-9.9	75.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.7	28.0	30.8	37.8	47.1	55.0	61.3	64.9	64.6	55.9	46.9	37.6	29.9
	DBStd	14.94	8.11	8.43	7.57	7.72	6.69	6.64	6.20	6.26	6.38	6.94	7.10	7.47
	HDD50	2935	683	538	382	141	29	2	0	1	17	144	375	623
	HDD65	6869	1148	958	844	536	315	149	82	85	281	560	823	1088
	CDD50	1741	0	0	3	56	184	340	461	452	193	49	3	0
	CDD65	198	0	0	0	0	5	37	78	71	7	0	0	0
	CDH74	1728	0	0	0	3	42	314	692	623	54	0	0	0
	CDH80	432	0	0	0	0	3	61	191	170	7	0	0	0
Wind	WSAvg	6.5	7.5	7.2	7.3	6.9	6.4	5.5	5.4	5.4	5.7	6.3	7.3	7.2
Precipitation	PrecAvg	27.1	1.9	1.5	2.0	1.6	2.7	3.3	3.4	3.1	2.3	1.8	1.9	1.7
	PrecMax	38.3	4.1	3.5	5.0	3.2	5.6	6.7	7.3	9.6	5.6	3.9	4.0	3.3
	PrecMin	21.3	0.3	0.3	0.5	0.1	0.6	1.2	1.1	0.9	0.3	0.2	0.0	0.5
	PrecStd	4.1	1.1	0.9	1.0	0.8	1.1	1.4	1.3	1.8	1.2	1.0	0.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.4	54.0	62.8	72.8	78.5	86.2	89.7	89.9	79.9	69.2	57.5	49.2
		MCWB	45.1	44.9	49.1	56.8	61.8	66.3	66.1	65.5	62.8	57.8	51.2	45.1
	2%	DB	45.5	48.7	57.7	67.9	74.1	81.2	85.2	84.9	74.4	63.5	53.2	45.5
		MCWB	41.9	43.0	47.2	54.2	60.5	66.0	65.4	65.2	61.1	56.1	49.4	42.9
	5%	DB	42.1	45.3	52.9	64.0	70.8	77.5	81.2	80.6	70.5	59.9	50.2	42.3
		MCWB	39.4	40.9	45.0	52.1	58.6	63.6	64.3	64.0	59.5	54.1	47.6	40.3
	10%	DB	38.7	41.9	48.8	60.3	67.4	74.2	77.6	77.0	66.9	56.6	47.2	39.5
		MCWB	36.8	38.6	43.0	50.1	56.9	62.0	63.3	62.7	57.9	52.9	45.4	38.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.0	46.8	50.8	57.9	64.7	69.9	69.4	69.4	64.4	59.6	52.9	45.8
		MCDB	49.8	51.9	59.9	70.3	75.5	81.4	82.7	82.3	75.6	65.1	55.9	48.0
	2%	WB	42.5	43.8	48.1	55.4	62.1	67.4	67.4	66.9	62.3	57.0	50.3	43.1
		MCDB	44.8	47.8	55.6	66.1	71.4	78.2	79.4	79.6	71.6	61.7	52.6	45.2
	5%	WB	39.5	41.3	46.0	53.0	59.8	65.2	65.9	65.4	60.7	55.2	47.8	40.6
		MCDB	41.7	45.0	51.9	62.0	68.6	75.0	77.6	77.2	68.6	58.9	49.7	42.0
	10%	WB	36.9	38.6	43.7	51.0	57.8	63.1	64.4	63.8	59.0	53.3	45.5	38.2
		MCDB	38.7	41.5	48.0	59.3	65.6	71.9	75.2	74.4	65.4	56.3	47.1	39.4
Mean Daily Temperature Range	5% DB	MDBR	8.6	11.2	13.9	17.1	17.0	17.9	18.5	18.7	15.2	12.2	8.2	7.9
		MCDBR	12.1	15.6	21.2	22.2	21.6	22.9	24.5	24.3	21.2	17.3	12.7	11.5
		MCWBR	9.2	10.6	12.3	11.4	10.7	10.3	9.3	9.2	9.7	10.4	9.0	9.3
	5% WB	MCDBR	11.4	14.6	18.9	20.6	20.1	21.3	21.8	21.9	19.0	15.1	10.9	11.1
		MCWBR	9.1	10.5	11.8	11.1	10.7	10.2	9.1	9.1	9.3	9.7	8.4	9.3
Clear-Sky Solar Irradiance	taub	0.294	0.316	0.356	0.397	0.399	0.401	0.411	0.407	0.377	0.350	0.324	0.293	
	taud	2.372	2.349	2.299	2.234	2.266	2.290	2.263	2.292	2.344	2.398	2.421	2.421	
	Ebn at Noon	242	263	270	269	273	273	268	263	259	247	228	227	
	Edh at Noon	21	27	34	41	41	40	41	38	32	26	20	18	
All-Sky Solar Radiation	RadAvg	298	578	904	1348	1587	1728	1654	1472	1047	628	311	231	
	RadStd	51	77	131	174	183	143	167	147	138	82	37	27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.83	N/A	N/A	+1.40	+0.79	+0.83	-184	-281	+151	N/A
Regional (83 neighbors)		+0.90	N/A	N/A	N/A	+0.63	+0.54	N/A	-266	+113	+43

Nomenclature: See separate page