

PEC POD SNEZKOU, Czech Republic

WMO: 116430

Lat: 50.6919N

Lon: 15.7289E

Elev: 2692

StdP: 13.32

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.1	8.2	-1.3	5.7	7.7	2.8	7.0	10.4	17.5	25.9	14.8	28.3	2.0	220	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	78.1	62.6	74.6	61.0	71.6	59.8	64.2	74.0	62.6	71.7	61.1	69.2	7.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.9	88.3	67.3	59.4	83.5	65.7	57.9	79.0	64.4	30.9	73.5	29.6	71.6	28.5	69.4	70.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.3	12.2	10.9	-0.9	83.3	4.3	3.1	-4.0	85.5	-6.6	87.3	-9.0	89.1	-12.1	91.3		
(5)			-1.3	67.6	4.3	1.6	-4.4	68.8	-6.9	69.7	-9.3	70.7	-12.4	71.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.9	25.4	27.1	32.3	40.9	49.2	55.0	58.6	57.9	50.5	42.9	34.9	27.5
	DBStd	13.65	7.48	8.24	7.11	7.25	6.53	6.31	5.71	5.70	6.06	6.94	6.76	7.46
	HDD50	3816	763	641	549	283	95	21	2	6	68	237	454	697
	HDD65	8449	1228	1061	1014	724	490	304	211	230	436	686	903	1162
	CDD50	867	0	0	0	9	70	172	269	250	82	15	0	0
	CDD65	27	0	0	0	0	0	5	13	9	0	0	0	0
	CDH74	348	0	0	0	0	9	68	163	103	5	0	0	0
	CDH80	45	0	0	0	0	1	5	25	14	0	0	0	0
Wind	WSAvg	4.5	4.7	4.8	4.7	4.4	4.7	4.7	4.5	4.2	4.3	4.4	4.4	4.7
Precipitation	PrecAvg	38.8	3.4	2.8	3.0	1.9	3.0	3.8	4.6	3.9	3.2	2.7	3.1	3.5
	PrecMax	48.1	7.8	6.5	7.6	3.7	5.4	7.7	12.0	11.0	6.9	7.8	6.9	7.4
	PrecMin	27.5	0.4	0.6	1.0	0.2	1.4	1.6	1.3	1.5	0.9	0.6	0.1	1.6
	PrecStd	5.3	1.8	1.4	1.6	0.8	1.2	1.4	2.2	2.3	1.6	1.5	1.5	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.4	47.7	55.8	68.2	74.6	80.3	83.4	81.6	73.3	64.8	53.4	44.9
		MCWB	40.8	39.9	43.6	54.0	59.1	64.2	63.5	63.2	60.0	55.5	48.2	42.1
	2%	DB	40.2	43.2	50.2	62.5	70.1	75.9	78.6	76.6	69.0	59.5	49.6	41.5
		MCWB	38.5	38.9	41.1	50.2	57.2	62.1	62.6	62.2	57.9	52.8	46.8	40.0
	5%	DB	37.4	40.0	45.4	58.1	66.0	72.0	74.5	73.1	65.2	56.0	46.8	39.1
		MCWB	36.0	37.2	39.1	47.4	54.8	59.7	61.0	60.9	56.2	51.2	44.7	37.9
	10%	DB	35.0	37.3	41.8	54.1	62.2	68.2	71.0	69.8	61.2	53.0	44.3	36.7
		MCWB	33.7	34.9	37.9	45.6	52.6	57.9	60.0	59.4	54.7	49.8	42.6	35.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.5	43.3	45.6	54.8	61.4	66.4	66.5	65.7	62.1	56.7	49.6	43.1
		MCDB	42.4	45.5	52.7	66.0	71.5	77.5	76.3	74.9	70.1	61.3	51.7	43.9
	2%	WB	38.8	39.9	42.6	51.5	58.3	63.5	64.1	63.7	59.3	54.0	47.3	40.3
		MCDB	39.7	41.9	47.4	60.3	67.0	72.6	74.0	73.0	65.9	58.0	49.2	41.2
	5%	WB	36.0	37.5	40.5	48.6	56.1	61.1	62.5	62.1	57.3	52.0	44.9	37.9
		MCDB	37.0	39.4	44.4	56.2	64.0	69.4	71.9	70.7	63.1	55.2	46.5	38.8
	10%	WB	33.9	35.2	38.2	46.1	54.0	59.0	61.0	60.6	55.3	50.1	42.7	35.7
		MCDB	34.8	37.0	41.3	52.3	60.8	66.7	69.2	67.8	60.4	52.9	44.1	36.5
Mean Daily Temperature Range	5% DB	MDBR	10.6	11.8	13.0	17.1	17.6	17.3	17.3	18.1	15.2	12.7	9.7	9.9
		MCDBR	11.3	14.0	19.8	25.4	24.2	24.5	24.5	23.3	21.8	18.5	13.2	11.0
		MCWBR	9.3	10.0	11.9	13.7	12.6	12.4	11.0	10.8	11.7	11.7	9.9	9.1
	5% WB	MCDBR	9.5	11.4	16.8	23.4	21.9	22.0	21.5	20.7	19.1	16.2	11.8	9.2
		MCWBR	8.5	9.4	11.2	13.5	12.3	12.0	10.6	10.7	11.2	10.9	9.5	8.3
Clear-Sky Solar Irradiance	taub	0.295	0.320	0.364	0.411	0.409	0.405	0.423	0.416	0.377	0.352	0.324	0.290	
	taud	2.301	2.274	2.213	2.153	2.201	2.245	2.198	2.234	2.314	2.351	2.359	2.346	
	Ebn at Noon	231	255	262	262	268	270	263	258	256	240	217	215	
	Edh at Noon	21	28	36	43	43	42	43	40	33	26	20	18	
All-Sky Solar Radiation	RadAvg	253	488	808	1298	1574	1676	1584	1405	1001	574	272	186	
	RadStd	43	77	123	171	181	143	187	135	137	83	36	18	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (45 neighbors)	+0.81	N/A	N/A	N/A	+0.59	+0.58	N/A	N/A	+104	+38

Nomenclature: See separate page