

HRADEC KRALOVE, Czech RepublicWMO: **116480**Lat: **50.250N**Lon: **15.850E**Elev: **244**StdP: **98.43**Time Zone: **1.00 (EUC)**Period: **82-93**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.4	-12.7	-18.0	0.8	-16.1	-14.8	1.1	-12.3	12.8	0.6	11.3	0.3	1.6	0	0.551

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	29.3	19.1	27.5	18.5	25.8	17.7	20.2	27.3	19.2	25.4	18.5	24.1	3.1	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	13.2	22.4	17.1	12.6	21.6	16.3	11.9	20.7	59.0	27.7	55.7	25.4	53.1	24.3	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	9.3	8.2	7.3	-17.5	33.7	5.1	2.0	-21.1	35.1	-24.1	36.3	-26.9	37.4	-30.6	38.8	
(5)				-17.7	22.3	5.0	0.8	-21.4	22.9	-24.3	23.3	-27.2	23.8	-30.8	24.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.5	-1.4	-1.2	3.7	8.3	13.3	15.7	18.1	18.1	14.1	9.1	3.0	0.1
	DBStd	8.13	5.88	4.96	3.72	3.90	3.53	3.25	3.07	3.39	2.95	3.87	3.59	4.19
	HDD10.0	1539	354	315	198	78	12	1	0	0	2	63	209	307
	HDD18.3	3696	613	548	454	301	157	91	42	47	132	287	459	565
	CDD10.0	979	0	0	2	28	115	173	253	251	124	35	0	0
	CDD18.3	94	0	0	0	0	2	13	37	39	3	0	0	0
	CDH23.3	1021	0	0	0	5	43	133	392	402	44	1	0	0
	CDH26.7	248	0	0	0	0	3	21	103	117	4	0	0	0
Wind	WSAvg	2.8	2.9	3.1	3.3	3.1	3.0	2.7	2.6	2.3	2.5	2.8	2.9	2.8
Precipitation	PrecAvg	655	51	43	48	33	64	66	85	70	51	42	49	54
	PrecMax	828	99	115	134	59	131	131	169	157	116	130	96	111
	PrecMin	508	10	7	12	5	21	26	16	16	10	3	1	23
	PrecStd	92	23	23	31	14	28	25	41	35	30	26	22	21
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	12.5	16.8	24.0	26.6	29.0	32.1	33.1	26.8	22.1	12.7	10.2
		MCWB	8.3	8.6	10.3	12.9	16.9	19.2	19.9	20.8	18.0	15.5	10.0	7.5
	2%	DB	8.4	9.0	13.8	21.3	24.4	26.8	29.2	30.0	24.5	18.9	10.8	8.2
		MCWB	6.4	6.2	9.2	12.6	15.4	18.0	19.1	19.6	17.0	14.3	8.9	6.7
	5%	DB	6.6	6.1	11.2	18.4	22.7	24.9	27.5	27.6	22.5	16.9	9.3	7.0
		MCWB	5.1	4.3	7.6	11.4	14.8	17.3	18.6	18.5	16.2	12.7	7.6	6.0
	10%	DB	5.1	4.4	9.4	15.6	20.8	22.7	25.5	25.6	20.0	15.1	8.0	5.5
		MCWB	3.9	3.1	6.6	9.9	14.2	16.1	17.9	17.8	15.0	12.0	6.6	4.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	9.2	11.2	14.0	18.1	20.9	21.6	21.5	18.9	16.4	10.6	8.2
		MCDB	10.5	11.5	14.5	21.0	23.9	26.5	28.7	29.8	24.8	20.5	12.0	9.4
	2%	WB	6.6	6.4	9.4	12.9	16.7	19.2	20.2	20.1	17.7	14.8	9.1	7.1
		MCDB	8.0	8.8	12.9	20.1	22.4	24.9	27.2	27.8	22.6	18.3	10.4	8.0
	5%	WB	5.3	4.5	8.2	11.8	15.6	18.0	19.2	19.2	16.6	13.6	7.7	5.9
		MCDB	6.6	5.8	10.9	17.9	21.0	23.4	25.4	25.5	21.2	16.3	9.1	6.9
	10%	WB	3.9	3.2	6.8	10.4	14.7	16.8	18.4	18.4	15.5	12.3	6.7	4.5
		MCDB	5.0	4.3	9.0	14.9	19.3	21.3	24.0	24.1	19.6	14.6	7.8	5.5
Mean Daily Temperature Range	5% DB	MDBR	5.4	6.3	7.5	9.6	10.5	9.7	10.8	10.9	9.6	8.7	5.3	4.2
		MCDBR	6.1	8.1	11.7	14.5	14.5	14.1	15.2	15.5	13.7	11.5	7.4	5.2
		MCWBR	4.9	5.9	7.4	6.6	6.7	6.2	6.2	6.2	6.5	6.8	5.5	4.3
	5% WB	MCDBR	6.1	7.8	10.6	13.4	12.6	12.2	13.3	13.2	12.2	10.6	6.7	5.1
		MCWBR	5.0	6.1	7.0	6.5	6.2	6.0	5.9	5.8	6.3	6.8	5.2	4.3
Clear-Sky Solar Irradiance	taub	0.304	0.328	0.369	0.414	0.416	0.415	0.432	0.425	0.389	0.363	0.337	0.301	
	taud	2.337	2.308	2.259	2.197	2.235	2.268	2.227	2.263	2.334	2.375	2.394	2.380	
	Ebn at Noon	726	801	826	826	842	845	822	807	798	750	681	676	
	Edh at Noon	66	88	111	131	132	129	132	122	102	82	64	56	
All-Sky Solar Radiation	RadAvg	0.83	1.61	2.62	4.13	4.98	5.32	5.04	4.49	3.19	1.84	0.88	0.62	
	RadStd	0.15	0.24	0.41	0.53	0.58	0.46	0.57	0.43	0.44	0.27	0.11	0.06	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (51 neighbors)	+0.47	N/A	N/A	N/A	+0.36	+0.34	N/A	N/A	+61	+23

Nomenclature: See separate page