

PARDUBICE, Czech Republic

WMO: 116520

Lat: 50.0161N

Lon: 15.7403E

Elev: 755

StdP: 14.30

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.8	13.2	1.9	6.2	8.9	7.9	8.5	15.4	27.5	43.7	24.5	42.2	1.7	90	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	88.1	68.1	84.6	66.7	81.4	65.5	70.1	83.2	68.5	80.5	67.1	78.0	6.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.2	99.3	73.4	64.6	93.9	72.2	63.2	89.2	71.3	34.5	83.5	33.1	80.9	32.0	77.8	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	21.1	18.0	15.5	DB	1.6	94.1	7.8	2.9	-4.0	96.2	-8.5	97.9	-12.8	99.5	-18.5	101.7
(5)				WB	1.1	73.3	7.7	1.8	-4.4	74.6	-8.9	75.7	-13.2	76.7	-18.8	78.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.3	30.5	33.7	40.3	49.4	57.7	63.7	66.9	66.7	58.3	49.4	40.8	33.1
	DBStd	14.72	9.48	8.48	7.07	7.20	6.56	6.30	5.71	5.64	6.11	6.86	6.92	8.53
	HDD50	2386	606	457	306	97	11	0	0	0	5	96	283	525
	HDD65	6029	1070	876	765	470	241	98	47	47	215	484	726	990
	CDD50	2125	0	1	6	78	250	412	522	517	254	78	7	0
	CDD65	293	0	0	0	1	15	60	104	99	13	1	0	0
	CDH74	3234	0	0	0	28	210	667	1102	1058	166	3	0	0
	CDH80	983	0	0	0	2	37	187	378	347	32	0	0	0
Wind	WSAvg	6.1	6.7	6.8	7.0	6.3	6.0	5.6	5.8	5.0	5.3	5.6	6.0	6.5
Precipitation	PrecAvg	22.2	1.4	1.1	1.5	1.2	2.5	2.4	3.3	2.6	1.9	1.4	1.5	1.5
	PrecMax	28.4	2.3	2.9	4.1	2.3	4.6	5.2	8.1	5.3	4.3	3.5	2.8	2.5
	PrecMin	16.9	0.4	0.2	0.3	0.2	0.5	0.7	0.4	0.9	0.2	0.1	0.0	0.6
	PrecStd	3.1	0.6	0.6	0.9	0.6	1.1	1.0	1.6	1.1	1.2	0.7	0.7	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.0	56.2	65.7	77.5	84.3	90.5	93.0	93.3	84.2	73.0	61.6	52.9
		MCWB	49.0	48.0	52.5	59.6	64.4	70.3	69.3	68.6	65.3	60.1	54.9	48.2
	2%	DB	49.9	52.2	61.0	72.5	79.7	85.5	88.1	87.4	78.7	67.7	57.1	49.3
		MCWB	45.4	46.5	49.6	56.9	62.9	68.4	67.9	67.8	63.3	58.4	51.9	45.4
	5%	DB	46.4	49.0	56.6	68.1	75.6	81.2	84.3	83.8	74.5	64.3	54.0	46.7
		MCWB	42.8	44.3	47.6	54.7	60.9	65.7	66.6	66.5	62.0	56.9	50.0	43.3
	10%	DB	42.8	45.3	52.3	64.0	71.6	77.6	80.5	80.0	70.6	60.6	51.4	44.0
		MCWB	40.1	41.3	45.7	52.4	59.0	64.1	65.8	65.2	60.2	55.1	48.2	41.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.5	49.4	53.8	60.8	67.4	72.4	72.4	71.6	67.5	62.4	55.4	48.6
		MCDB	53.2	54.1	63.1	75.1	80.1	86.0	85.7	84.9	78.6	68.9	60.6	51.9
	2%	WB	45.9	47.2	51.0	58.2	64.4	69.5	69.9	69.7	65.0	59.8	52.8	45.9
		MCDB	49.3	51.6	58.7	70.3	75.2	81.9	82.6	83.2	75.1	66.0	56.4	49.0
	5%	WB	43.0	44.6	48.7	55.7	62.3	67.2	68.4	68.1	63.2	57.8	50.5	43.5
		MCDB	46.0	48.6	55.2	66.2	72.5	78.3	80.2	79.8	72.1	62.9	53.6	46.2
	10%	WB	40.2	41.6	46.3	53.4	60.4	65.3	66.9	66.6	61.3	55.8	48.3	41.5
		MCDB	42.7	45.1	51.4	62.3	69.5	75.3	77.5	77.0	69.2	60.1	51.0	43.9
Mean Daily Temperature Range	5% DB	MDBR	10.2	12.5	15.9	20.3	20.2	19.7	19.8	21.0	18.2	15.2	10.9	9.5
		MCDBR	13.3	17.0	25.5	28.5	27.3	26.9	27.7	28.1	25.8	21.6	15.6	12.3
		MCWBR	10.2	12.0	15.4	15.1	13.1	11.9	10.5	11.1	12.5	13.3	11.1	9.7
	5% WB	MCDBR	12.8	15.8	22.5	26.2	24.0	24.7	23.9	23.6	22.7	19.7	14.3	11.7
		MCWBR	10.2	11.7	14.4	14.3	12.3	11.7	10.0	10.3	11.7	12.9	10.7	9.5
Clear-Sky Solar Irradiance	taub	0.310	0.333	0.376	0.421	0.422	0.422	0.438	0.431	0.396	0.368	0.341	0.306	
	taud	2.342	2.310	2.247	2.169	2.209	2.245	2.207	2.242	2.308	2.353	2.379	2.377	
	Ebn at Noon	229	253	260	260	266	266	259	254	251	236	215	213	
	Edh at Noon	21	28	36	43	43	42	43	40	33	27	21	18	
All-Sky Solar Radiation	RadAvg	271	526	849	1319	1583	1702	1614	1436	1020	592	284	203	
	RadStd	47	75	134	170	183	143	179	140	140	86	36	22	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.90	N/A	N/A	+1.62	N/A	N/A	N/A	N/A	N/A	+83
(47)	Regional (54 neighbors)	+0.86	N/A	N/A	N/A	+0.63	+0.61	N/A	N/A	+110	+40

Nomenclature: See separate page