

PARDUBICE, Czech Republic

WMO: 116520

Lat: 50.0161N

Lon: 15.7403E

Elev: 230

StdP: 98.59

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.0	-10.4	-16.7	0.9	-12.8	-13.4	1.2	-9.2	12.3	6.5	10.9	5.7	0.8	90	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	31.2	20.1	29.2	19.3	27.4	18.6	21.2	28.4	20.3	27.0	19.5	25.5	3.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	14.2	23.0	18.1	13.4	22.3	17.3	12.7	21.8	62.3	28.6	59.2	27.2	56.5	25.5	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.4	8.1	6.9	DB	-16.9	34.5	4.3	1.6	-20.0	35.7	-22.5	36.6	-24.9	37.5	-28.0	38.7	(4)
			WB	-17.1	23.0	4.3	1.0	-20.2	23.7	-22.7	24.3	-25.1	24.8	-28.2	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	-0.8	1.0	4.6	9.6	14.3	17.6	19.4	19.3	14.6	9.7	4.9	0.6
	DBStd	8.18	5.27	4.71	3.93	4.00	3.64	3.50	3.17	3.14	3.40	3.81	3.84	4.74
	HDD10.0	1326	337	254	170	54	6	0	0	3	53	157	292	
	HDD18.3	3349	594	487	425	261	134	54	26	119	269	403	550	
	CDD10.0	1181	0	1	3	43	139	229	290	287	141	43	4	0
	CDD18.3	163	0	0	0	1	8	33	58	55	7	1	0	0
	CDH23.3	1797	0	0	0	16	117	371	612	588	92	2	0	0
	CDH26.7	546	0	0	0	1	21	104	210	193	18	0	0	0
Wind	WSAvg	2.7	3.0	3.0	3.1	2.8	2.7	2.5	2.6	2.3	2.4	2.5	2.7	2.9
Precipitation	PrecAvg	563	35	29	38	30	63	62	83	65	47	36	38	38
	PrecMax	721	59	74	105	58	116	133	207	134	108	88	70	63
	PrecMin	428	11	4	8	4	12	18	11	23	6	3	1	14
	PrecStd	78	14	16	22	14	28	26	41	29	30	19	17	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	13.4	18.7	25.3	29.0	32.5	33.9	34.0	29.0	22.8	16.5	11.6
		MCWB	9.4	8.9	11.4	15.3	18.0	21.3	20.7	20.3	18.5	15.6	12.7	9.0
	2%	DB	9.9	11.2	16.1	22.5	26.5	29.7	31.2	30.8	26.0	19.8	14.0	9.6
		MCWB	7.5	8.0	9.8	13.8	17.1	20.2	20.0	19.9	17.4	14.7	11.1	7.4
	5%	DB	8.0	9.4	13.7	20.1	24.2	27.4	29.0	28.8	23.6	17.9	12.2	8.1
		MCWB	6.0	6.8	8.7	12.6	16.0	18.7	19.2	19.2	16.7	13.8	10.0	6.3
	10%	DB	6.0	7.4	11.3	17.8	22.0	25.3	26.9	26.7	21.4	15.9	10.8	6.6
		MCWB	4.5	5.2	7.6	11.3	15.0	17.8	18.8	18.4	15.7	12.8	9.0	5.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	9.7	12.1	16.0	19.7	22.5	22.4	22.0	19.7	16.9	13.0	9.2
		MCDB	11.8	12.3	17.3	24.0	26.7	30.0	29.8	29.4	25.9	20.5	15.9	11.1
	2%	WB	7.7	8.4	10.6	14.5	18.0	20.8	21.1	20.9	18.4	15.4	11.5	7.7
		MCDB	9.6	10.9	14.8	21.3	24.0	27.7	28.1	28.4	23.9	18.9	13.5	9.4
	5%	WB	6.1	7.0	9.3	13.2	16.8	19.6	20.2	20.0	17.3	14.3	10.3	6.4
		MCDB	7.8	9.2	12.9	19.0	22.5	25.7	26.8	26.6	22.3	17.2	12.0	7.9
	10%	WB	4.6	5.3	7.9	11.9	15.8	18.5	19.4	19.2	16.3	13.2	9.1	5.3
		MCDB	5.9	7.3	10.8	16.8	20.8	24.0	25.3	25.0	20.6	15.6	10.5	6.6
Mean Daily Temperature Range	5% DB	MDBR	5.7	7.0	8.9	11.3	11.2	10.9	11.0	11.6	10.1	8.4	6.1	5.3
		MCDBR	7.4	9.4	14.2	15.9	15.2	15.0	15.4	15.6	14.3	12.0	8.6	6.8
		MCWBR	5.7	6.7	8.6	8.4	7.3	6.6	5.9	6.2	6.9	7.4	6.2	5.4
	5% WB	MCDBR	7.1	8.8	12.5	14.6	13.3	13.7	13.3	13.1	12.6	11.0	8.0	6.5
		MCWBR	5.7	6.5	8.0	7.9	6.8	6.5	5.5	5.7	6.5	7.2	5.9	5.3
Clear-Sky Solar Irradiance	taub	0.310	0.333	0.376	0.421	0.422	0.422	0.438	0.431	0.396	0.368	0.341	0.306	
	taud	2.342	2.310	2.247	2.169	2.209	2.245	2.207	2.242	2.308	2.353	2.379	2.377	
	Ebn at Noon	723	797	820	820	837	839	817	802	792	745	677	673	
	Edh at Noon	67	88	112	135	136	132	135	125	105	85	65	57	
All-Sky Solar Radiation	RadAvg	0.85	1.66	2.68	4.16	4.99	5.37	5.09	4.53	3.22	1.87	0.90	0.64	
	RadStd	0.15	0.23	0.42	0.54	0.58	0.45	0.56	0.44	0.44	0.27	0.11	0.07	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.50	N/A	N/A	+0.90	N/A	N/A	N/A	N/A	N/A	+46
(47)	Regional (54 neighbors)	+0.48	N/A	N/A	N/A	+0.35	+0.34	N/A	N/A	+61	+22

Nomenclature: See separate page