

PRIBYSLAV, Czech Republic

WMO: 116590

Lat: 49.5828N

Lon: 15.7625E

Elev: 536

StdP: 95.04

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.3	-11.1	-17.1	0.9	-13.6	-13.9	1.2	-10.3	14.2	1.8	12.7	0.5	2.2	120	0.629

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	28.9	19.2	27.0	18.6	25.2	17.8	20.2	26.8	19.3	25.5	18.4	24.0	4.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.8	23.4	17.1	13.0	21.9	16.2	12.3	20.9	60.5	26.8	57.2	25.6	54.2	24.1	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.5	10.1	8.8	-18.0	31.5	3.8	2.0	-20.7	32.9	-23.0	34.0	-25.1	35.1	-27.9	36.5		
			-18.3	22.1	3.8	1.1	-21.0	22.8	-23.2	23.4	-25.3	24.0	-28.1	24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-2.3	-0.9	2.8	7.9	12.3	15.5	17.6	17.4	12.8	8.1	3.3	-1.1
	DBStd	8.11	4.68	4.84	4.08	4.26	3.73	3.67	3.30	3.43	3.47	3.88	4.06	4.41
	HDD10.0	1664	382	306	223	87	19	3	0	1	12	84	203	345
	HDD18.3	3912	641	539	481	312	189	99	55	58	167	317	452	603
	CDD10.0	875	0	0	1	26	91	168	235	231	97	25	2	0
	CDD18.3	81	0	0	0	0	2	14	32	30	3	0	0	0
	CDH23.3	844	0	0	0	1	24	149	335	307	27	0	0	0
	CDH26.7	192	0	0	0	0	2	27	82	79	2	0	0	0
Wind	WSAvg	4.1	4.6	4.5	4.6	4.3	4.1	3.6	3.5	3.4	3.8	4.2	4.6	4.6
Precipitation	PrecAvg	702	45	38	51	39	75	78	98	84	64	42	46	44
	PrecMax	843	91	78	152	76	125	154	250	211	154	100	98	73
	PrecMin	528	13	10	15	4	10	24	32	29	15	5	0	16
	PrecStd	91	21	21	28	18	28	32	46	47	37	22	23	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.5	11.2	16.4	22.5	25.9	29.6	31.2	31.5	26.2	20.1	13.7	9.3
		MCWB	6.9	7.1	9.9	14.2	18.2	20.1	19.1	19.9	17.0	14.4	10.8	7.3
	2%	DB	7.1	8.7	13.6	20.0	23.5	27.0	28.9	29.0	23.5	17.5	11.9	7.3
		MCWB	5.4	6.1	8.6	12.6	16.6	19.2	19.0	19.1	16.4	13.6	9.9	6.0
	5%	DB	5.3	7.0	11.1	17.7	21.5	25.0	27.0	26.7	21.2	15.5	10.3	5.7
		MCWB	4.0	5.0	7.3	11.5	15.4	18.1	18.5	18.4	15.5	12.4	8.8	4.5
	10%	DB	3.7	5.1	8.9	15.5	19.5	23.0	25.1	24.7	19.1	13.8	8.9	4.3
		MCWB	2.6	3.4	6.2	10.4	14.2	17.0	17.7	17.5	14.4	11.6	7.7	3.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.3	7.9	10.7	14.9	19.1	21.4	21.5	21.3	18.4	15.5	11.5	7.6
		MCDB	8.9	10.2	15.5	21.2	24.6	27.6	27.8	28.4	24.0	18.8	12.9	8.8
	2%	WB	5.6	6.5	9.1	13.4	17.2	20.0	20.1	19.9	17.0	14.0	10.3	6.1
		MCDB	6.9	8.3	12.7	19.0	22.4	25.8	26.6	27.2	21.5	16.5	11.7	7.3
	5%	WB	4.1	5.1	7.9	12.0	15.9	18.7	19.1	19.0	16.0	13.0	8.9	4.7
		MCDB	5.2	6.8	10.7	16.6	20.7	23.8	25.3	25.5	20.4	15.1	10.1	5.5
	10%	WB	2.7	3.6	6.4	10.7	14.6	17.6	18.1	18.1	14.9	11.8	7.6	3.6
		MCDB	3.6	4.9	8.5	14.8	18.7	22.0	23.7	23.6	18.5	13.7	8.8	4.3
Mean Daily Temperature Range	5% DB	MDBR	4.8	6.0	7.5	9.7	9.9	10.3	10.8	10.9	8.9	6.9	4.6	4.2
		MCDBR	6.1	8.2	11.8	13.3	13.1	13.3	14.5	14.1	12.5	9.5	6.6	5.4
		MCWBR	4.9	5.8	7.4	7.4	7.4	6.8	6.3	6.3	6.5	6.0	4.8	4.5
	5% WB	MCDBR	5.8	7.4	10.8	11.9	12.0	12.2	12.7	12.7	11.3	8.8	5.9	5.2
		MCWBR	4.9	5.6	7.2	7.0	7.2	6.8	6.3	6.2	6.3	5.8	4.6	4.4
Clear-Sky Solar Irradiance	taub	0.295	0.318	0.359	0.402	0.403	0.404	0.416	0.411	0.380	0.353	0.327	0.294	
	taud	2.346	2.325	2.278	2.218	2.253	2.280	2.248	2.279	2.336	2.385	2.402	2.395	
	Ebn at Noon	751	821	843	841	856	856	838	823	812	769	706	702	
	Edh at Noon	67	87	109	129	130	128	130	121	103	82	64	56	
All-Sky Solar Radiation	RadAvg	0.89	1.74	2.77	4.21	5.02	5.43	5.17	4.61	3.27	1.91	0.93	0.68	
	RadStd	0.16	0.23	0.44	0.54	0.58	0.45	0.54	0.45	0.45	0.27	0.12	0.08	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.50	N/A	N/A	N/A	N/A	N/A	N/A	-157	+48	N/A
(47)	Regional (73 neighbors)	+0.49	N/A	N/A	N/A	+0.36	+0.33	N/A	-148	+64	+24

Nomenclature: See separate page