

USTI NAD ORLICI, Czech Republic

WMO: 116790

Lat: 49.9803N

Lon: 16.4222E

Elev: 1328

StdP: 14.00

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.1	12.0	1.1	6.1	8.9	6.2	7.9	13.5	30.2	38.1	26.7	37.4	4.1	70	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	86.1	67.0	82.5	65.7	79.3	64.3	68.8	81.5	67.3	79.2	65.7	76.5	7.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.7	96.2	73.1	63.2	91.1	71.3	61.8	86.6	69.9	33.7	81.4	32.4	79.5	31.2	76.8	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.9	19.8	17.2	DB	0.2	91.3	7.4	3.3	-5.1	93.6	-9.5	95.5	-13.6	97.4	-18.9	99.7	(4)
(5)			WB	-0.4	72.7	7.3	2.6	-5.6	74.6	-9.9	76.1	-13.9	77.6	-19.2	79.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.3	28.5	31.3	37.9	47.5	55.7	61.6	65.2	64.7	56.2	47.7	39.1	30.9
	DBStd	14.85	8.66	8.51	7.15	7.82	6.72	6.50	5.98	5.98	6.27	7.19	7.47	7.97
	HDD50	2800	666	525	378	135	22	2	0	0	14	132	333	593
	HDD65	6672	1131	945	840	525	295	140	74	78	270	538	778	1058
	CDD50	1811	0	0	2	62	200	351	471	457	202	60	6	0
	CDD65	206	0	0	0	1	8	40	80	70	7	0	0	0
	CDH74	2220	0	0	0	14	108	434	834	748	82	0	0	0
	CDH80	600	0	0	0	1	13	105	253	218	10	0	0	0
Wind	WSAvg	7.2	8.4	8.1	8.2	7.3	7.0	6.3	6.2	5.6	6.1	7.1	8.0	8.3
Precipitation	PrecAvg	27.9	1.9	1.6	2.0	1.6	2.8	3.0	4.0	3.0	2.4	1.7	1.9	2.0
	PrecMax	34.8	3.5	3.3	5.4	3.7	5.7	5.4	10.3	7.8	5.5	4.3	3.8	3.5
	PrecMin	22.2	0.7	0.4	0.4	0.2	0.7	0.6	1.0	1.3	0.7	0.2	0.0	0.8
	PrecStd	3.6	0.7	0.9	1.1	0.8	1.2	1.0	2.0	1.6	1.4	0.9	0.9	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.6	52.4	62.9	76.0	81.4	87.9	90.9	91.4	80.9	69.8	58.7	49.6
		MCWB	45.5	45.4	50.3	58.2	63.2	68.7	67.3	68.5	63.6	59.5	52.8	46.5
	2%	DB	46.0	48.3	57.9	70.0	77.0	83.3	86.2	85.5	76.2	65.0	55.0	46.4
		MCWB	42.7	43.9	47.6	54.8	61.4	66.6	67.1	66.5	62.3	56.9	51.0	43.6
	5%	DB	42.3	45.2	53.3	65.9	73.0	79.1	82.4	81.7	72.1	61.7	52.3	43.5
		MCWB	39.8	41.5	45.4	53.1	59.5	64.4	65.6	65.8	60.4	55.7	48.7	41.3
	10%	DB	39.4	42.1	49.0	61.8	69.2	75.3	78.7	77.9	67.9	58.4	49.6	40.8
		MCWB	37.5	39.2	43.5	51.1	57.6	62.7	64.5	63.9	58.5	53.8	46.7	39.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.3	46.8	51.8	59.2	65.8	70.9	71.1	70.4	66.0	60.9	53.7	46.8
		MCDB	49.7	50.5	59.7	72.4	78.0	84.0	83.3	84.0	76.2	67.2	56.9	49.2
	2%	WB	43.0	44.4	48.8	56.5	62.9	68.1	68.7	68.3	63.4	58.1	51.4	44.1
		MCDB	45.3	47.9	56.0	67.8	73.7	79.9	81.0	81.7	72.9	63.3	54.8	46.2
	5%	WB	40.0	41.9	46.4	54.0	60.8	65.9	67.2	66.8	61.6	56.2	49.0	41.4
		MCDB	42.2	44.8	51.6	63.7	70.9	76.6	79.1	78.6	69.5	60.8	51.8	43.2
	10%	WB	37.5	39.3	44.0	51.8	58.6	63.9	65.6	65.2	59.6	54.3	47.0	39.2
		MCDB	39.4	41.9	48.5	60.4	67.2	73.1	76.5	75.3	66.6	58.0	49.4	40.6
Mean Daily Temperature Range	5% DB	MDBR	8.5	11.1	14.2	18.5	19.3	19.4	19.8	20.8	17.2	13.2	8.8	7.6
		MCDBR	10.5	14.4	23.2	25.8	25.8	26.1	27.6	27.2	24.4	18.4	12.2	9.6
		MCWBR	8.5	10.5	14.1	13.2	12.8	11.9	11.0	11.1	11.8	11.3	8.8	8.0
	5% WB	MCDBR	10.3	13.0	19.8	23.1	23.4	24.0	23.8	23.7	21.2	16.7	10.9	9.2
		MCWBR	8.6	10.0	13.1	12.2	12.2	11.6	10.5	10.6	11.1	10.6	8.3	7.9
Clear-Sky Solar Irradiance	taub	0.302	0.326	0.367	0.413	0.413	0.412	0.427	0.421	0.388	0.361	0.335	0.300	
	taud	2.324	2.298	2.251	2.182	2.225	2.259	2.223	2.254	2.317	2.360	2.372	2.370	
	Ebn at Noon	233	255	263	263	268	269	262	258	254	239	217	216	
	Edh at Noon	22	28	36	43	43	41	42	39	33	27	21	18	
All-Sky Solar Radiation	RadAvg	268	510	850	1322	1591	1696	1616	1449	1025	595	290	202	
	RadStd	47	73	141	164	191	155	179	134	148	89	36	21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-232	+92	+34
(47)	Regional (55 neighbors)	+0.88	N/A	N/A	N/A	+0.63	+0.58	N/A	-275	+117	+45

Nomenclature: See separate page