

SVRATOUCH, Czech Republic

WMO: 116830

Lat: 49.7350N

Lon: 16.0342E

Elev: 740

StdP: 92.74

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -13.1	(c) -10.9	(d) -16.5	(e) 1.0	(f) -11.5	(g) -13.8	(h) 1.2	(i) -9.7	(j) 19.5	(k) -6.2	(l) 17.9	(m) -4.2	(n) 5.6	(o) 180	(p) 0.715

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.2	(c) 27.4	(d) 18.4	(e) 25.5	(f) 17.8	(g) 23.8	(h) 17.0	(i) 19.4	(j) 25.3	(k) 18.5	(l) 24.1	(m) 17.6	(n) 22.7	(o) 4.5	(p) 170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	13.6	21.6	16.5	12.9	20.6	15.7	12.2	19.8	58.6	25.5	55.4	24.2	52.6	22.7	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 16.0	(b) 13.8	(c) 12.0	(e) -15.7	(f) 29.9	(g) 3.0	(h) 2.1	(i) -17.9	(j) 31.4	(k) -19.7	(l) 32.6	(m) -21.4	(n) 33.8	(o) -23.6	(p) 35.3		
(a) 16.0	(b) 13.8	(c) 12.0	(e) -15.9	(f) 21.1	(g) 3.0	(h) 1.0	(i) -18.1	(j) 21.8	(k) -19.8	(l) 22.4	(m) -21.5	(n) 23.0	(o) -23.7	(p) 23.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-3.0	-1.8	1.7	7.2	11.7	15.0	17.1	17.1	12.2	7.4	2.5	-1.9
	DBStd	8.32	4.34	4.69	4.45	4.79	3.99	3.93	3.80	3.66	3.83	4.17	4.08	4.10
	HDD10.0	1851	404	330	257	107	29	5	1	1	20	102	226	369
	HDD18.3	4159	663	563	514	333	208	113	71	68	186	338	476	627
	CDD10.0	812	0	0	1	25	81	155	221	220	87	22	1	0
	CDD18.3	79	0	0	0	0	2	13	32	29	3	0	0	0
	CDH23.3	472	0	0	0	0	11	77	198	176	11	0	0	0
	CDH26.7	87	0	0	0	0	1	10	40	36	1	0	0	0
(14) Wind	WSAvg	5.7	6.6	6.3	6.1	5.6	5.4	4.6	4.6	4.5	5.1	6.1	6.9	6.5
(15) Precipitation	PrecAvg	681	43	36	51	41	71	76	92	77	62	42	46	44
	PrecMax	838	88	73	150	88	121	139	262	194	143	99	96	76
	PrecMin	527	9	9	14	3	12	16	30	21	15	5	1	17
	PrecStd	89	21	20	28	19	28	31	47	43	37	22	21	17
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.2	10.0	14.7	21.1	24.7	28.1	30.1	29.9	24.8	18.7	12.6	8.1
		MCWB	6.1	5.7	8.7	13.1	15.9	19.3	19.1	18.6	16.8	14.0	10.4	6.5
	2%	DB	6.2	7.5	12.1	18.6	22.2	25.8	27.5	27.3	22.0	16.5	10.9	6.3
		MCWB	4.8	5.1	7.5	11.5	15.1	18.3	18.5	18.2	15.7	12.8	9.4	5.4
	5%	DB	4.3	5.7	9.8	16.3	20.1	23.6	25.5	25.1	19.9	14.5	9.4	4.7
		MCWB	3.4	3.8	6.2	10.4	14.1	16.9	17.8	17.6	14.6	11.9	8.1	4.0
	10%	DB	2.7	4.1	7.8	14.3	18.1	21.6	23.6	23.3	17.9	13.0	7.9	3.3
		MCWB	2.0	2.7	5.2	9.4	13.2	16.1	17.2	16.7	13.8	11.3	7.1	2.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	7.0	9.5	13.6	17.3	20.6	20.6	20.2	17.7	14.8	10.9	7.1
		MCDB	7.7	8.6	13.5	19.7	23.0	26.3	26.2	26.3	22.8	17.2	11.7	7.6
	2%	WB	5.0	5.5	8.0	12.3	15.8	19.0	19.4	19.0	16.3	13.4	9.8	5.6
		MCDB	5.9	6.9	10.9	17.6	20.5	24.2	25.4	25.4	20.4	15.4	10.8	6.3
	5%	WB	3.5	4.2	6.8	11.0	14.7	17.7	18.5	18.1	15.3	12.4	8.3	4.1
		MCDB	4.2	5.4	9.2	15.2	19.0	22.4	24.1	23.7	18.8	14.1	9.1	4.6
	10%	WB	2.0	2.9	5.6	9.8	13.6	16.5	17.7	17.3	14.4	11.4	7.2	2.9
		MCDB	2.8	4.0	7.5	13.7	17.5	20.7	22.6	22.2	17.3	13.0	7.8	3.3
(35) Mean Daily Temperature Range	5% DB	MDBR	4.0	4.7	5.9	7.6	7.9	8.1	8.2	8.3	6.8	5.5	4.0	3.9
		MCDBR	5.4	6.2	8.7	9.7	10.2	10.5	10.8	10.8	9.4	7.6	5.6	5.0
		MCWBR	4.5	4.5	5.5	5.2	5.4	5.5	5.0	4.8	4.7	4.6	4.1	4.2
	5% WB	MCDBR	4.9	5.6	7.8	9.1	9.4	9.9	10.0	9.6	8.5	7.0	5.0	4.8
		MCWBR	4.3	4.5	5.3	5.2	5.4	5.4	5.0	4.8	4.7	4.5	4.1	4.4
(40) Clear-Sky Solar Irradiance	taub		0.287	0.309	0.347	0.388	0.389	0.389	0.402	0.397	0.367	0.343	0.318	0.285
	taud		2.364	2.345	2.306	2.248	2.278	2.302	2.269	2.299	2.358	2.406	2.418	2.406
	Ebn at Noon		763	833	856	854	869	869	850	836	825	782	716	714
	Edh at Noon		65	85	106	125	127	125	127	118	100	80	63	55
(44) All-Sky Solar Radiation	RadAvg		0.87	1.68	2.73	4.20	5.02	5.40	5.14	4.59	3.26	1.89	0.92	0.66
	RadStd		0.15	0.23	0.44	0.53	0.59	0.46	0.55	0.44	0.45	0.28	0.11	0.07

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (66 neighbors)	+0.49	N/A	N/A	N/A	+0.37	+0.34	N/A	-154	+67	+25

Nomenclature: See separate page