

NAMEST NAD OSLAVOU, Czech Republic

WMO: 116920

Lat: 49.1708N

Lon: 16.1206E

Elev: 1573

StdP: 13.88

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.4	14.6	3.9	7.1	12.6	9.3	9.4	17.0	29.8	38.0	26.6	36.0	6.3	340	0.564

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.1	85.0	66.9	81.6	65.5	78.5	64.4	68.9	79.8	67.3	78.0	65.8	75.8	8.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.3	99.0	73.2	63.6	93.3	71.5	62.1	88.2	70.1	34.0	79.9	32.6	78.0	31.4	76.1	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.3	20.3	17.7	DB	6.7	89.9	3.8	2.9	4.0	92.0	1.8	93.7	-0.4	95.4	-3.1	97.5	(4)
(5)			WB	6.0	73.2	3.8	3.2	3.3	75.5	1.1	77.3	-1.1	79.1	-3.8	81.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.8	28.7	32.1	38.9	48.5	56.3	62.7	65.9	66.0	57.0	47.7	38.9	30.3
	DBStd	15.04	7.76	7.90	7.53	7.53	6.69	6.62	6.26	6.13	6.35	6.76	7.26	7.51
	HDD50	2736	662	502	348	116	20	1	0	0	12	127	338	610
	HDD65	6523	1127	922	809	496	277	120	67	62	249	536	783	1075
	CDD50	1946	0	0	4	70	217	383	494	495	222	56	5	0
	CDD65	258	0	0	0	0	9	52	96	92	9	0	0	0
	CDH74	1925	0	0	0	1	57	360	746	704	57	0	0	0
	CDH80	453	0	0	0	0	3	67	195	185	3	0	0	0
Wind	WSAvg	8.0	8.4	8.7	9.0	8.4	7.9	7.4	7.8	7.0	7.4	7.5	8.0	8.1
Precipitation	PrecAvg	20.3	0.9	0.8	1.3	1.3	2.3	2.6	2.9	2.4	1.9	1.3	1.3	1.1
	PrecMax	30.4	1.9	2.3	3.5	2.8	4.9	5.7	7.8	5.4	4.6	2.7	2.5	1.7
	PrecMin	15.4	0.1	0.1	0.3	0.1	0.6	0.6	0.5	0.9	0.3	0.2	0.1	0.3
	PrecStd	3.4	0.5	0.6	0.8	0.7	0.9	1.2	1.5	1.2	1.2	0.7	0.6	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.6	53.7	62.1	72.5	79.2	86.3	89.1	89.5	79.6	68.3	58.6	48.5
		MCWB	46.0	45.6	49.6	57.2	62.6	67.7	67.8	67.9	63.5	58.4	53.5	46.1
	2%	DB	45.8	49.2	58.1	68.4	75.1	81.5	85.1	84.8	75.0	63.7	54.5	44.9
		MCWB	42.6	44.2	47.8	55.1	61.6	66.8	67.3	66.1	61.9	56.9	51.0	42.8
	5%	DB	42.0	46.0	53.9	64.7	71.8	78.2	81.7	81.1	71.1	60.4	51.2	42.2
		MCWB	39.8	41.8	45.7	53.0	60.0	64.8	65.5	65.0	60.4	55.2	48.9	40.3
	10%	DB	38.7	42.5	50.1	61.0	68.4	74.9	78.2	77.6	67.7	57.4	48.4	39.7
		MCWB	37.0	39.4	44.1	50.9	57.8	63.2	64.5	63.7	59.0	53.8	46.5	38.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.9	47.4	51.4	58.8	65.3	71.4	71.3	70.1	65.7	60.4	54.0	46.4
		MCDB	50.2	52.2	59.2	70.1	75.4	80.8	84.1	81.9	74.6	65.0	57.5	48.1
	2%	WB	43.2	44.8	48.9	56.4	62.9	68.4	69.0	68.0	63.4	57.9	51.6	43.2
		MCDB	45.3	48.5	55.9	66.6	72.5	78.0	80.2	80.1	72.0	61.8	53.7	44.8
	5%	WB	39.9	42.3	46.9	53.9	61.0	66.3	67.3	66.5	61.6	56.1	49.1	40.6
		MCDB	41.9	45.5	52.6	62.6	69.7	75.6	78.0	77.8	69.0	59.5	50.9	41.9
	10%	WB	37.1	39.6	44.7	51.9	59.1	64.3	65.7	65.1	60.0	54.3	46.7	38.6
		MCDB	38.5	42.2	49.1	59.8	66.7	72.7	75.6	75.3	66.4	57.3	48.2	39.7
Mean Daily Temperature Range	5% DB	MDBR	7.8	10.0	12.8	15.9	15.9	16.6	17.1	17.2	14.2	11.1	8.0	7.2
		MCDBR	11.1	14.3	19.3	20.4	20.0	20.7	22.2	21.9	19.5	15.3	11.3	10.1
		MCWBR	9.1	9.9	11.2	10.4	10.0	9.3	8.5	8.4	9.2	9.5	8.1	8.6
	5% WB	MCDDBR	10.8	13.3	17.0	19.2	18.7	18.7	19.8	19.7	17.2	13.7	10.3	9.7
MCWBR		9.0	9.9	11.1	10.4	10.2	9.3	8.7	8.5	9.1	9.3	7.8	8.5	
Clear-Sky Solar Irradiance	taub	0.300	0.322	0.361	0.405	0.405	0.406	0.416	0.413	0.384	0.357	0.333	0.299	
	taud	2.361	2.343	2.290	2.212	2.248	2.276	2.250	2.275	2.327	2.376	2.391	2.403	
	Ebn at Noon	239	261	268	266	271	271	266	261	257	244	223	224	
	Edh at Noon	21	28	35	41	42	41	41	38	33	27	21	18	
All-Sky Solar Radiation	RadAvg	286	550	897	1361	1610	1746	1669	1492	1059	623	308	221	
	RadStd	46	72	138	161	188	146	171	143	143	86	35	23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.06	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+135	+77
Regional (77 neighbors)		+0.94	N/A	N/A	N/A	+0.68	+0.58	-220	-283	+124	+49

Nomenclature: See separate page