

DUKOVANY, Czech Republic

WMO: 116930

Lat: 49.0956N

Lon: 16.1344E

Elev: 402

StdP: 96.59

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.0	-9.5	-15.6	1.0	-10.7	-12.8	1.3	-8.2	14.5	4.3	13.2	3.0	3.5	350	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	30.5	19.4	28.6	18.8	26.8	18.0	20.6	27.7	19.7	26.5	18.9	25.1	4.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	13.8	22.9	17.4	13.1	22.0	16.6	12.4	21.4	61.0	27.8	57.9	26.6	55.1	25.2	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.8	10.3	9.0	-14.4	33.2	3.0	1.8	-16.5	34.5	-18.3	35.6	-19.9	36.6	-22.1	37.9		
(5)			-14.8	22.3	2.9	0.9	-16.9	23.0	-18.6	23.5	-20.2	24.0	-22.3	24.7	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.1	-1.6	0.2	4.0	9.4	13.7	17.2	19.4	19.2	14.3	9.1	4.1	-0.6
	DBStd	8.38	4.33	4.60	4.17	4.27	3.65	3.67	3.39	3.39	3.49	3.85	4.00	4.12
	HDD10.0	1472	359	275	188	62	9	1	0	0	5	65	180	328
	HDD18.3	3539	617	508	443	268	150	66	29	31	127	287	427	587
	CDD10.0	1133	0	0	3	43	123	215	291	284	134	37	3	0
	CDD18.3	158	0	0	0	0	5	30	61	56	6	0	0	0
	CDH23.3	1488	0	0	0	4	51	287	591	504	49	1	0	0
	CDH26.7	417	0	0	0	0	6	67	189	149	5	0	0	0
Wind	WSAvg	4.2	4.3	4.5	4.6	4.5	4.3	4.0	4.1	3.7	4.0	3.9	4.1	4.1
Precipitation	PrecAvg	515	24	21	33	33	59	67	73	62	48	34	33	27
	PrecMax	771	48	59	88	72	125	144	197	136	116	69	64	44
	PrecMin	392	3	2	7	2	16	14	12	22	7	4	3	7
	PrecStd	87	12	14	21	18	22	30	38	31	30	17	14	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.6	12.2	17.7	23.7	27.2	31.2	33.1	32.9	27.2	21.2	15.4	9.7
		MCWB	7.8	8.1	10.3	14.5	17.5	19.9	19.9	19.5	17.6	14.8	12.1	8.2
	2%	DB	7.8	9.9	15.2	21.2	24.7	28.7	30.7	30.3	24.7	18.5	13.0	7.8
		MCWB	5.8	6.8	9.1	13.2	16.7	19.6	19.5	19.1	16.7	13.9	10.7	6.3
	5%	DB	5.7	8.1	12.6	19.0	22.7	26.7	28.8	28.1	22.6	16.6	11.0	6.1
		MCWB	4.2	5.6	7.8	11.7	15.6	18.3	18.7	18.4	15.8	13.0	9.4	4.9
	10%	DB	4.0	6.1	10.4	16.9	20.8	24.7	26.8	26.1	20.5	14.8	9.5	4.6
		MCWB	2.8	4.3	6.9	10.7	14.5	17.4	18.1	17.7	15.1	12.3	8.1	3.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.4	8.7	11.5	15.4	19.0	21.9	21.9	21.2	19.3	16.0	12.5	8.4
		MCDB	10.6	11.7	16.1	22.2	24.8	28.4	28.7	28.8	24.2	19.1	14.8	9.6
	2%	WB	6.2	7.3	9.7	13.8	17.5	20.4	20.5	20.2	17.8	14.6	11.1	6.6
		MCDB	7.6	9.5	13.7	20.1	23.3	26.7	27.9	27.8	22.6	17.2	12.8	7.7
	5%	WB	4.4	5.9	8.5	12.4	16.3	19.2	19.6	19.2	16.7	13.5	9.5	5.0
		MCDB	5.5	7.8	11.9	17.7	21.4	24.8	26.7	26.2	21.0	15.9	10.9	5.9
	10%	WB	2.9	4.4	7.2	11.2	15.1	18.1	18.7	18.4	15.7	12.5	8.3	3.8
		MCDB	3.8	6.0	9.9	15.9	19.7	23.3	25.1	24.6	19.8	14.6	9.3	4.6
Mean Daily Temperature Range	5% DB	MDBR	4.6	6.1	7.8	9.9	10.0	10.7	11.1	10.7	8.8	6.9	4.8	4.2
		MCDBR	6.6	8.5	11.9	13.1	12.9	13.6	14.4	13.6	12.0	9.7	6.9	6.1
		MCWBR	5.3	5.9	6.9	6.5	6.4	5.8	5.1	5.0	5.5	5.6	4.8	5.0
	5% WB	MCDBR	6.4	8.0	10.7	11.9	11.9	12.4	12.8	12.2	10.5	8.5	6.5	5.7
MCWBR		5.3	5.9	6.8	6.3	6.5	6.0	5.1	5.1	5.4	5.3	4.8	4.9	
Clear-Sky Solar Irradiance	taub	0.303	0.326	0.365	0.409	0.410	0.411	0.421	0.418	0.389	0.361	0.337	0.302	
	taud	2.361	2.341	2.284	2.200	2.238	2.266	2.241	2.266	2.318	2.367	2.385	2.401	
	Ebn at Noon	749	818	839	835	851	851	834	819	805	763	699	700	
	Edh at Noon	68	87	109	132	133	130	131	123	105	85	67	58	
All-Sky Solar Radiation	RadAvg	0.91	1.74	2.84	4.31	5.08	5.52	5.28	4.72	3.35	1.98	0.98	0.70	
	RadStd	0.14	0.23	0.43	0.50	0.59	0.46	0.54	0.45	0.45	0.27	0.11	0.07	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (75 neighbors)		+0.53	N/A	N/A	N/A	+0.39	+0.33	-123	-160	+70	+28

Nomenclature: See separate page