

KUCCHAROVICE, Czech Republic

WMO: 116980

Lat: 48.8811N

Lon: 16.0853E

Elev: 339

StdP: 97.32

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.7	-9.1	-15.5	1.0	-10.6	-12.6	1.3	-7.8	13.2	3.5	12.2	2.9	3.3	10	0.567

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	31.2	19.8	29.2	19.1	27.5	18.4	21.0	28.4	20.1	27.2	19.2	25.7	4.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	13.9	23.6	17.6	13.2	22.6	16.8	12.5	22.0	62.0	28.1	58.9	27.2	56.0	25.8	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.6	8.4	DB	-14.2	34.1	3.2	2.0	-16.5	35.5	-18.4	36.6	-20.2	37.8	-22.5	39.2	(4)
(5)			WB	-14.7	22.7	3.1	1.1	-16.9	23.5	-18.7	24.2	-20.4	24.8	-22.7	25.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	-1.1	0.8	4.7	10.0	14.4	17.9	20.1	19.8	15.0	9.7	4.7	-0.1	(6)	
	DBStd	8.45	4.51	4.59	4.19	4.24	3.60	3.63	3.30	3.31	3.46	3.79	3.99	4.18	(7)	
	HDD10.0	1363	343	259	170	51	6	0	0	0	3	54	165	312	(8)	
	HDD18.3	3348	601	492	423	249	130	51	19	22	110	269	410	570	(9)	
	CDD10.0	1258	0	1	5	52	142	239	314	304	152	44	5	0	(10)	
	CDD18.3	201	0	0	0	1	8	39	76	68	9	0	0	0	(11)	
	CDH23.3	1847	0	0	0	8	73	362	720	612	69	2	0	0	(12)	
	CDH26.7	549	0	0	0	0	9	92	243	194	9	0	0	0	(13)	
(14) Wind	WSAvg	3.9	4.1	4.1	4.3	4.1	3.9	3.5	3.6	3.4	3.6	3.7	3.9	3.9	(14)	
(15) Precipitation	PrecAvg	494	22	18	31	33	56	67	68	62	50	33	30	25	(15)	
	PrecMax	726	52	55	85	75	110	131	207	138	125	73	63	42	(16)	
	PrecMin	371	3	2	5	1	15	20	10	19	10	6	3	7	(17)	
	PrecStd	84	12	13	19	18	21	29	38	31	30	18	14	10	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	13.5	18.5	24.5	28.0	31.9	33.6	33.7	27.9	22.1	16.2	10.5	(19)	
		MCWB	8.7	8.6	10.7	14.6	17.5	20.5	20.2	20.2	18.1	15.7	12.4	8.3	(20)	
	2%	DB	8.8	10.8	15.9	21.8	25.3	29.3	31.4	30.9	25.4	19.0	13.6	8.5	(21)	
		MCWB	6.3	7.4	9.5	13.5	16.9	19.7	19.9	19.4	17.1	14.1	10.9	6.7	(22)	
	5%	DB	6.7	8.7	13.3	19.6	23.4	27.3	29.5	28.8	23.2	17.0	11.6	6.7	(23)	
		MCWB	4.8	6.1	8.2	12.2	16.0	18.8	19.1	18.9	16.1	13.1	9.7	5.1	(24)	
	10%	DB	4.8	6.8	11.2	17.5	21.5	25.4	27.5	26.9	21.2	15.1	10.0	5.2	(25)	
		MCWB	3.3	4.5	7.2	11.1	14.7	17.7	18.4	18.1	15.4	12.3	8.5	4.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	9.2	11.7	15.2	19.4	22.2	22.1	21.6	19.0	16.2	12.9	8.6	(27)	
		MCDB	11.5	12.6	16.9	22.8	25.8	29.2	29.8	29.8	25.3	19.7	15.8	10.1	(28)	
	2%	WB	6.6	7.6	10.0	13.9	17.9	20.9	20.8	20.5	17.9	14.7	11.3	6.8	(29)	
		MCDB	8.4	10.3	14.6	20.8	23.9	27.4	28.8	28.2	23.9	17.6	13.2	8.3	(30)	
	5%	WB	5.0	6.2	8.8	12.7	16.6	19.6	20.0	19.6	16.9	13.7	9.9	5.3	(31)	
		MCDB	6.5	8.6	12.7	18.5	22.0	25.5	27.4	26.8	21.5	16.3	11.4	6.4	(32)	
	10%	WB	3.3	4.7	7.5	11.6	15.4	18.4	19.1	18.8	16.0	12.7	8.6	4.2	(33)	
		MCDB	4.6	6.5	10.7	16.8	20.4	24.0	25.7	25.1	20.2	14.8	9.8	5.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	6.2	8.0	10.1	10.0	10.8	11.3	10.9	8.9	7.0	4.9	4.3	(35)	
		MCDBR	6.8	8.7	12.0	13.4	13.0	13.7	14.6	14.0	12.3	9.5	7.1	6.5	(36)	
	5% WB	MCWBR	5.2	6.1	6.8	6.6	6.2	5.8	5.1	5.1	5.5	5.5	4.9	5.1	(37)	
		MCWBR	6.6	8.4	11.0	12.2	12.1	12.4	13.0	12.4	10.9	8.5	6.5	6.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.306	0.328	0.367	0.411	0.411	0.414	0.423	0.420	0.391	0.363	0.338	0.305	(40)	
		taud	2.372	2.349	2.287	2.200	2.237	2.263	2.241	2.265	2.315	2.367	2.389	2.407	(41)	
	Ebn at Noon		750	817	838	835	850	849	834	817	803	763	700	702	(42)	
		Edh at Noon	68	87	109	132	133	130	131	123	106	85	67	58	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.93	1.77	2.87	4.34	5.10	5.55	5.32	4.75	3.38	2.02	1.01	0.72	(44)	
	RadStd		0.14	0.23	0.42	0.50	0.58	0.46	0.54	0.46	0.44	0.26	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+43
(47) Regional (83 neighbors)		+0.54	N/A	N/A	N/A	+0.40	+0.33	-123	-162	+76	+33

Nomenclature: See separate page