

BRNO-TURANY, Czech Republic

WMO: 117230

Lat: 49.1531N

Lon: 16.6889E

Elev: 806

StdP: 14.27

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.8	15.0	3.9	6.9	12.2	8.8	8.9	17.1	25.4	37.3	23.0	32.2	7.7	70	0.550

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	88.3	68.7	85.0	67.6	81.8	66.2	70.8	84.0	69.2	81.8	67.6	79.2	8.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.4	100.1	76.4	64.8	94.5	74.5	63.3	89.7	73.2	35.1	84.4	33.7	82.0	32.4	79.3	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.3	19.3	17.2	DB	6.4	93.2	6.2	3.3	2.0	95.6	-1.7	97.5	-5.1	99.4	-9.6	101.7	(4)
(5)			WB	5.6	73.8	6.0	1.8	1.3	75.1	-2.2	76.1	-5.6	77.1	-9.9	78.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.9	29.9	33.2	40.7	50.8	65.2	68.6	68.4	59.3	49.8	40.7	31.9	(6)	
(7)		DBStd	15.45	8.15	8.10	7.51	7.52	6.41	6.47	5.94	6.11	6.12	6.83	7.43	7.54	(7)
(8)		HDD50	2422	623	470	296	80	8	0	0	0	3	90	290	562	(8)
(9)		HDD65	5924	1088	890	752	428	210	76	32	34	188	471	729	1026	(9)
(10)		CDD50	2375	0	0	9	104	280	457	577	570	284	84	10	0	(10)
(11)		CDD65	403	0	0	0	2	17	83	144	139	18	0	0	0	(11)
(12)		CDH74	3620	0	0	0	21	166	720	1326	1244	139	4	0	0	(12)
(13)		CDH80	1078	0	0	0	2	19	191	437	409	20	0	0	0	(13)
(14)	Wind	WSAvg	7.8	7.6	8.0	8.9	9.0	8.3	7.4	7.4	6.8	7.5	7.3	7.6	7.2	(14)
(15)	Precipitation	PrecAvg	19.8	0.9	0.9	1.1	1.2	2.6	2.8	2.7	2.3	1.7	1.3	1.4	1.1	(15)
(16)		PrecMax	27.6	3.1	2.8	2.9	3.2	15.8	6.5	8.9	6.3	4.8	4.3	3.3	2.4	(16)
(17)		PrecMin	14.2	0.1	0.0	0.1	0.1	0.2	0.7	0.4	0.4	0.3	0.2	0.5	0.1	(17)
(18)		PrecStd	3.3	0.5	0.6	0.7	0.7	2.1	1.1	1.5	1.4	1.1	0.9	0.7	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.0	55.4	65.8	76.8	82.7	89.8	92.8	93.5	82.8	71.9	62.2	50.6	(19)
(20)			MCWB	46.9	47.2	51.6	60.0	64.8	70.1	69.7	69.8	65.4	60.4	54.9	46.7	(20)
(21)		2%	DB	46.8	50.9	61.2	72.0	78.5	85.3	88.3	88.3	78.0	67.0	57.1	46.7	(21)
(22)			MCWB	42.9	45.5	50.0	56.9	63.4	69.1	68.6	68.2	63.7	58.4	52.2	43.4	(22)
(23)		5%	DB	42.9	47.3	56.6	67.8	75.0	81.5	85.1	84.4	74.2	63.6	53.6	43.7	(23)
(24)			MCWB	39.8	42.9	47.1	54.7	61.7	66.7	67.3	67.3	62.1	56.7	49.9	41.2	(24)
(25)		10%	DB	40.1	44.0	52.7	64.2	71.3	78.1	81.5	80.8	70.7	60.3	50.8	41.2	(25)
(26)			MCWB	37.7	40.4	45.7	52.9	59.6	64.9	66.0	65.7	60.4	55.1	47.7	38.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.8	49.3	53.4	61.3	67.4	73.1	72.9	72.3	67.6	61.9	56.0	47.1	(27)
(28)			MCD B	51.0	54.4	62.4	74.5	79.1	85.7	87.5	85.8	78.7	68.9	61.0	50.1	(28)
(29)		2%	WB	43.4	46.1	50.9	58.3	64.6	70.3	70.6	70.2	65.3	59.7	52.8	44.0	(29)
(30)			MCD B	46.3	50.2	58.9	69.9	75.7	81.9	84.2	84.1	74.8	65.3	56.5	46.2	(30)
(31)		5%	WB	40.2	43.3	48.6	55.9	62.7	68.2	69.0	68.7	63.4	57.7	50.3	41.6	(31)
(32)			MCD B	42.4	46.8	55.2	65.7	72.7	79.3	81.5	81.9	71.9	62.7	53.3	43.5	(32)
(33)		10%	WB	37.9	40.6	46.4	53.8	60.8	66.1	67.3	67.0	61.5	55.5	48.1	39.4	(33)
(34)			MCD B	39.8	43.7	51.7	62.6	70.0	76.1	78.4	78.6	69.3	59.6	50.4	40.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.5	11.2	15.0	18.2	18.1	18.7	19.3	19.4	16.6	13.7	9.6	8.0	(35)
(36)			MCDBR	11.5	15.9	23.0	23.6	23.6	23.6	25.1	24.3	22.0	18.3	13.1	10.7	(36)
(37)			MCWBR	8.8	11.4	13.4	12.2	11.7	10.6	9.5	9.2	10.4	10.9	9.1	8.5	(37)
(38)		5% WB	MCDBR	10.9	15.1	20.0	21.6	21.0	21.7	22.3	22.4	19.6	16.7	12.1	10.2	(38)
(39)			MCWBR	8.7	11.4	12.8	11.6	11.3	10.7	9.5	9.4	10.1	10.6	8.9	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.314	0.337	0.377	0.423	0.422	0.422	0.434	0.430	0.401	0.373	0.349	0.312	(40)	
(41)		taud	2.340	2.317	2.257	2.166	2.208	2.244	2.217	2.242	2.291	2.341	2.354	2.376	(41)	
(42)		Ebn at Noon	232	254	262	260	266	266	261	256	251	237	215	216	(42)	
(43)		Edh at Noon	22	29	36	43	43	42	43	40	34	28	22	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	280	534	893	1371	1625	1758	1680	1505	1068	622	307	216	(44)	
(45)		RadStd	43	70	142	152	191	148	173	141	146	88	33	22	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.40	N/A	N/A	+1.94	N/A	N/A	-256	-373	+211	+108	(46)
(47)	Regional (72 neighbors)	+0.99	N/A	N/A	+1.44	+0.76	+0.65	-230	-302	+139	+59	(47)

Nomenclature: See separate page