

HOLESOV, Czech Republic

WMO: 117740

Lat: 49.3207N

Lon: 17.5696E

Elev: 734

StdP: 14.31

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 7.5	(c) 12.4	(d) 2.0	(e) 6.3	(f) 9.0	(g) 6.8	(h) 8.0	(i) 14.1	(j) 22.6	(k) 34.5	(l) 20.3	(m) 34.8	(n) 5.4	(o) 40	(p) 0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 20.9	(c) 88.0	(d) 68.8	(e) 84.5	(f) 67.5	(g) 81.4	(h) 66.1	(i) 70.4	(j) 83.5	(k) 68.9	(l) 81.4	(m) 67.4	(n) 78.8	(o) 8.3	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.1	98.8	74.9	64.6	93.7	73.2	63.3	89.3	72.2	34.7	83.8	33.4	81.5	32.2	78.9	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 20.3	(b) 17.5	(c) 15.3	(e) 1.5	(f) 92.3	(g) 6.7	(h) 3.2	(i) -3.3	(j) 94.6	(k) -7.2	(l) 96.4	(m) -10.9	(n) 98.2	(o) -15.8	(p) 100.6		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.1	29.4	32.8	39.8	49.8	57.6	63.8	67.3	66.9	58.4	49.5	41.0	32.0
	DBStd	15.20	9.12	8.66	7.53	7.68	6.56	6.30	6.03	5.99	6.31	7.19	7.92	8.11
	HDD50	2501	638	483	323	96	11	0	0	0	6	100	285	559
	HDD65	6118	1103	902	781	459	243	97	46	48	213	482	720	1024
	CDD50	2173	0	0	7	88	247	415	535	524	258	84	15	0
	CDD65	317	0	0	0	2	14	62	116	107	15	1	0	0
	CDH74	3306	0	0	0	24	169	645	1243	1084	139	2	0	0
	CDH80	985	0	0	0	2	24	166	430	345	18	0	0	0
(14) Wind	WSAvg	6.5	6.8	7.2	7.6	7.5	6.7	6.1	5.7	5.5	5.8	6.1	6.6	6.8
(15) Precipitation	PrecAvg	25.8	1.4	1.4	1.6	1.7	2.8	3.2	3.4	2.7	2.5	1.7	1.8	1.6
	PrecMax	35.1	2.4	3.1	3.5	3.4	8.3	5.4	11.8	5.0	6.1	4.6	4.0	3.4
	PrecMin	18.0	0.2	0.2	0.4	0.2	1.2	0.9	0.4	0.7	0.6	0.1	0.0	0.5
	PrecStd	3.6	0.6	0.7	0.9	0.9	1.4	1.2	2.2	1.1	1.4	1.0	0.8	0.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.6	54.4	65.5	77.2	83.0	88.5	92.7	92.9	82.7	72.2	63.3	53.3
		MCWB	46.9	47.6	51.4	59.3	65.0	70.2	69.1	68.3	65.0	60.7	55.0	48.3
	2%	DB	47.1	50.1	60.2	72.4	78.5	84.9	88.6	87.5	77.9	67.9	59.1	48.3
		MCWB	43.9	44.9	49.2	56.6	63.2	68.4	68.8	68.2	63.6	58.7	52.8	44.7
	5%	DB	43.7	47.2	55.9	68.0	75.0	81.1	84.8	83.6	74.4	64.6	55.6	44.7
		MCWB	41.0	43.1	47.1	54.5	61.4	66.3	67.5	67.2	62.0	57.4	50.6	42.2
	10%	DB	40.8	44.3	51.9	64.0	71.1	77.4	81.3	80.2	70.5	60.8	52.4	42.0
		MCWB	38.6	41.1	45.4	52.5	59.4	64.5	66.2	65.9	60.5	55.4	48.7	40.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.4	48.4	52.6	60.6	67.4	73.2	72.6	71.8	67.8	62.0	56.3	48.6
		MCDB	50.6	52.5	61.7	74.2	80.1	85.2	85.9	84.9	78.6	69.1	61.7	52.6
	2%	WB	44.1	45.7	50.4	57.9	64.5	69.9	70.4	69.9	65.2	59.7	53.5	45.2
		MCDB	46.9	49.5	58.5	70.0	75.4	81.9	84.0	82.8	74.3	66.2	58.4	48.2
	5%	WB	41.3	43.5	48.2	55.6	62.5	67.6	68.9	68.2	63.4	57.8	51.1	42.5
		MCDB	43.5	46.8	54.3	65.7	72.8	77.8	81.8	81.1	71.5	63.4	55.0	44.5
	10%	WB	38.8	41.2	46.0	53.5	60.5	65.8	67.2	66.7	61.6	55.9	48.9	40.3
		MCDB	40.5	44.1	51.1	62.4	69.8	75.5	78.5	78.1	69.2	60.6	52.1	41.9
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	11.8	15.3	19.4	19.2	19.9	20.9	21.0	17.6	14.8	10.1	8.5
		MCDBR	11.3	15.6	23.4	26.4	25.2	26.0	27.4	26.4	24.1	20.3	14.1	10.6
		MCWBR	8.6	11.1	13.9	13.5	12.6	12.1	11.0	10.6	11.7	12.0	9.4	8.3
	5% WB	MCDBR	11.0	14.8	20.3	23.6	22.4	23.0	24.0	23.7	20.7	18.6	12.5	10.0
		MCWBR	8.7	10.9	13.0	12.5	11.9	11.5	10.5	10.2	10.7	11.6	8.7	8.1
(40) Clear-Sky Solar Irradiance	taub		0.315	0.339	0.379	0.428	0.426	0.426	0.438	0.433	0.404	0.375	0.350	0.313
	taud		2.303	2.284	2.238	2.155	2.203	2.241	2.212	2.240	2.289	2.341	2.349	2.356
	Ebn at Noon		229	252	260	259	265	265	259	255	250	236	213	214
	Edh at Noon		23	29	36	44	43	42	43	40	34	28	22	19
(44) All-Sky Solar Radiation	RadAvg		277	529	885	1354	1609	1736	1660	1489	1054	613	301	213
	RadStd		45	70	146	154	193	152	174	139	148	89	34	21

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	+0.85	N/A	N/A	N/A	+0.90	+0.68	N/A	N/A	+148	+74
Regional (68 neighbors)	+0.99	N/A	N/A	+1.48	+0.79	+0.68	-230	-301	+139	+59

Nomenclature: See separate page