

HOLESOV, Czech Republic

WMO: 117740

Lat: 49.3207N

Lon: 17.5696E

Elev: 224

StdP: 98.66

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.6	-10.9	-16.7	0.9	-12.8	-14.0	1.1	-10.0	10.1	1.4	9.1	1.5	2.4	40	0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	31.1	20.4	29.2	19.7	27.5	19.0	21.4	28.6	20.5	27.4	19.6	26.0	3.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	14.1	23.8	18.1	13.4	22.9	17.4	12.8	22.3	62.9	28.8	59.8	27.5	57.0	26.1	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
9.1	7.8	6.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-16.9	33.5	3.7	1.8	-19.6	34.8	-21.8	35.8	-23.8	36.8	-26.5	38.1
			-17.3	23.2	3.7	1.2	-19.9	24.0	-22.0	24.7	-24.1	25.4	-26.7	26.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	-1.4	0.4	4.3	9.9	14.2	17.7	19.6	19.4	14.7	9.7	5.0	0.0		
	DBStd	8.44	5.07	4.81	4.18	4.27	3.64	3.50	3.35	3.33	3.51	4.00	4.40	4.51		
	HDD10.0	1389	354	268	179	53	6	0	0	0	3	56	158	311		
	HDD18.3	3399	613	501	434	255	135	54	26	27	118	268	400	569		
	CDD10.0	1207	0	0	4	49	137	231	297	291	143	47	8	0		
	CDD18.3	176	0	0	0	1	8	34	64	59	8	1	0	0		
	CDH23.3	1837	0	0	0	13	94	358	691	602	77	1	0	0		
	CDH26.7	547	0	0	0	1	13	92	239	192	10	0	0	0		
(14) Wind	WSAvg	2.9	3.1	3.2	3.4	3.4	3.0	2.7	2.5	2.4	2.6	2.7	2.9	3.0		
(15) Precipitation	PrecAvg	655	35	35	40	43	71	82	87	68	63	44	46	41		
	PrecMax	892	61	80	89	86	212	137	299	126	156	116	101	86		
	PrecMin	457	6	5	9	5	30	23	9	18	16	3	1	13		
	PrecStd	92	15	19	23	22	36	30	57	27	35	26	21	19		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.9	12.5	18.6	25.1	28.3	31.4	33.7	33.8	28.2	22.3	17.4	11.8		
		MCWB	8.3	8.6	10.8	15.2	18.3	21.2	20.6	20.2	18.3	16.0	12.8	9.0		
	2%	DB	8.4	10.1	15.7	22.5	25.8	29.4	31.5	30.9	25.5	20.0	15.1	9.1		
		MCWB	6.6	7.1	9.6	13.7	17.3	20.2	20.4	20.1	17.5	14.8	11.6	7.1		
	5%	DB	6.5	8.4	13.3	20.0	23.9	27.3	29.3	28.7	23.5	18.1	13.1	7.1		
		MCWB	5.0	6.2	8.4	12.5	16.3	19.1	19.7	19.6	16.7	14.1	10.3	5.7		
	10%	DB	4.9	6.8	11.1	17.8	21.7	25.2	27.4	26.8	21.4	16.0	11.3	5.6		
		MCWB	3.7	5.0	7.4	11.4	15.2	18.1	19.0	18.8	15.8	13.0	9.3	4.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	9.1	11.5	15.9	19.7	22.9	22.5	22.1	19.9	16.7	13.5	9.2		
		MCDB	10.3	11.4	16.5	23.5	26.7	29.6	30.0	29.4	25.9	20.6	16.5	11.5		
	2%	WB	6.7	7.6	10.2	14.4	18.1	21.0	21.3	21.0	18.5	15.4	11.9	7.4		
		MCDB	8.3	9.7	14.7	21.1	24.1	27.7	28.9	28.2	23.5	19.0	14.7	9.0		
	5%	WB	5.2	6.4	9.0	13.1	16.9	19.8	20.5	20.1	17.4	14.3	10.6	5.9		
		MCDB	6.4	8.2	12.4	18.7	22.6	25.4	27.7	27.3	22.0	17.4	12.8	6.9		
	10%	WB	3.8	5.1	7.8	12.0	15.9	18.8	19.6	19.3	16.4	13.3	9.4	4.6		
		MCDB	4.7	6.7	10.6	16.9	21.0	24.2	25.8	25.6	20.7	15.9	11.2	5.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	6.5	8.5	10.8	10.7	11.1	11.6	11.7	9.8	8.2	5.6	4.7		
		MCDBR	6.3	8.7	13.0	14.7	14.0	14.4	15.2	14.7	13.4	11.3	7.9	5.9		
	5% WB	MCWBR	4.8	6.2	7.7	7.5	7.0	6.7	6.1	5.9	6.5	6.7	5.2	4.6		
		MCWBR	6.1	8.2	11.3	13.1	12.5	12.8	13.4	13.1	11.5	10.3	6.9	5.6		
(40) Clear-Sky Solar Irradiance	taub		0.315	0.339	0.379	0.428	0.426	0.426	0.438	0.433	0.404	0.375	0.350	0.313		
		taud	2.303	2.284	2.238	2.155	2.203	2.241	2.212	2.240	2.289	2.341	2.349	2.356		
	Ebn at Noon		722	794	821	816	835	836	818	803	787	743	673	674		
		Edh at Noon	71	92	114	138	137	133	135	126	108	87	69	60		
(44) All-Sky Solar Radiation	RadAvg		0.87	1.67	2.79	4.27	5.07	5.47	5.23	4.69	3.32	1.93	0.95	0.67		
	RadStd		0.14	0.22	0.46	0.48	0.61	0.48	0.55	0.44	0.47	0.28	0.11	0.07		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.47	N/A	N/A	N/A	+0.50	+0.38	N/A	N/A	+82	+41
(47) Regional (68 neighbors)		+0.55	N/A	N/A	+0.82	+0.44	+0.38	-128	-167	+77	+33

Nomenclature: See separate page