

OSTRAVA MOSNOV, Czech Republic

WMO: 117820

Lat: 49.6919N

Lon: 18.1128E

Elev: 257

StdP: 98.27

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.5	-11.5	-17.2	0.9	-14.0	-14.2	1.1	-11.1	12.1	1.3	11.1	0.3	2.4	20	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	30.8	20.3	28.8	19.7	27.0	18.8	21.2	28.3	20.4	27.1	19.6	25.6	4.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.3	23.5	18.2	13.5	22.8	17.4	12.8	22.1	62.8	28.4	59.8	27.3	56.9	25.8	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.1	8.9	8.0	-18.1	33.4	3.9	1.8	-20.9	34.7	-23.2	35.7	-25.4	36.7	-28.2	38.0		
			-18.4	23.0	3.9	0.9	-21.2	23.7	-23.5	24.2	-25.6	24.7	-28.5	25.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.2	-1.5	0.2	3.9	9.3	13.8	17.4	19.4	19.0	14.2	9.5	4.9	0.0	(6)
(7)		DBStd	8.39	5.22	5.11	4.41	4.21	3.55	3.42	3.13	3.15	3.34	4.04	4.47	4.82	(7)
(8)		HDD10.0	1428	355	275	193	61	8	0	0	4	59	162	311		(8)
(9)		HDD18.3	3474	613	508	448	272	146	58	26	30	129	273	404	568	(9)
(10)		CDD10.0	1143	0	0	3	40	125	222	290	278	131	44	8	1	(10)
(11)		CDD18.3	148	0	0	0	1	5	30	57	49	5	1	0	0	(11)
(12)		CDH23.3	1596	0	0	0	14	89	325	592	507	66	2	0	0	(12)
(13)		CDH26.7	460	0	0	0	1	11	88	196	153	11	0	0	0	(13)
(14)	Wind	WSAvg	3.5	4.5	4.1	3.9	3.3	3.1	2.9	2.9	2.7	3.0	3.4	3.9	4.6	(14)
(15)	Precipitation	PrecAvg	797	41	41	49	55	91	97	113	80	79	55	53	44	(15)
(16)		PrecMax	1103	82	88	110	114	310	188	453	163	203	123	102	107	(16)
(17)		PrecMin	525	12	9	19	9	32	27	24	15	21	6	0	14	(17)
(18)		PrecStd	128	16	19	26	27	53	36	85	38	44	33	24	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	12.9	18.6	25.4	28.0	31.9	33.2	33.4	28.3	22.8	17.9	13.4	(19)
MCWB			8.1	8.5	10.8	15.1	18.3	20.9	20.6	20.7	18.5	16.4	12.6	9.5	(20)	
2%		DB	8.6	10.7	15.6	22.4	25.9	29.3	31.0	30.3	25.1	20.4	15.6	9.6	(21)	
		MCWB	6.5	7.2	9.3	13.8	17.4	20.1	20.4	20.1	17.3	14.8	11.3	7.2	(22)	
5%		DB	6.8	9.0	13.2	19.6	23.8	27.0	28.9	28.1	23.2	18.3	13.6	7.6	(23)	
		MCWB	4.9	6.4	8.3	12.3	16.2	19.1	19.8	19.7	16.5	13.9	10.2	5.8	(24)	
10%		DB	5.1	7.0	10.8	17.4	21.5	24.9	26.8	26.2	21.0	16.0	11.4	5.9	(25)	
		MCWB	3.6	4.9	7.1	11.1	15.2	18.0	18.9	18.7	15.6	12.8	9.0	4.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	9.0	11.4	15.8	19.5	22.5	22.6	22.1	19.6	17.0	13.0	9.6	(27)
MCDWB			10.4	12.2	17.1	23.7	26.4	29.5	30.1	28.9	26.3	21.3	17.1	12.8	(28)	
2%		WB	6.7	7.7	9.9	14.4	18.1	20.9	21.2	21.0	18.2	15.4	11.7	7.4	(29)	
		MCDWB	8.4	10.1	14.5	21.2	24.0	27.5	28.3	28.2	23.0	19.2	15.1	9.3	(30)	
5%		WB	5.0	6.4	8.7	13.0	16.9	19.7	20.4	20.1	17.1	14.2	10.5	5.9	(31)	
		MCDWB	6.5	8.7	12.5	18.8	22.5	25.5	27.0	26.9	21.9	17.6	13.0	7.3	(32)	
10%		WB	3.7	5.0	7.4	11.6	15.7	18.6	19.5	19.2	16.1	13.0	9.2	4.6	(33)	
		MCDWB	5.0	6.8	10.4	16.3	20.5	23.7	25.5	24.8	20.2	15.7	11.3	5.8	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.1	6.4	8.3	10.7	10.9	10.7	11.0	11.4	9.7	8.2	6.0	4.9	(35)
MCDBR			6.2	8.7	13.1	15.3	15.2	14.5	15.3	14.9	13.9	11.9	9.6	6.8	(36)	
MCWBR			4.8	6.1	7.9	8.2	7.7	6.7	6.3	6.3	7.0	7.2	6.2	5.1	(37)	
5% WB		MCDBR	5.9	7.9	11.5	14.0	13.6	12.9	13.4	13.3	12.0	10.7	8.4	6.4	(38)	
		MCWBR	4.8	5.8	7.3	7.8	7.3	6.5	6.0	6.0	6.4	6.8	5.7	5.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.313	0.339	0.381	0.434	0.430	0.430	0.444	0.436	0.405	0.374	0.346	0.310	(40)	
(41)		taud	2.286	2.263	2.222	2.137	2.193	2.230	2.200	2.231	2.284	2.342	2.354	2.350	(41)	
(42)		Ebn at Noon	716	789	816	809	831	832	812	799	783	741	673	670	(42)	
(43)		Edh at Noon	71	93	116	140	138	134	137	127	108	86	68	59	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.87	1.62	2.71	4.09	4.90	5.24	5.04	4.55	3.21	1.92	0.95	0.67	(44)	
(45)		RadStd	0.15	0.24	0.45	0.49	0.62	0.52	0.58	0.42	0.48	0.28	0.13	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.75	N/A	N/A	+1.14	+0.69	+0.66	-156	-227	+108	+49
(47)	Regional (47 neighbors)	+0.54	N/A	N/A	+0.80	+0.42	+0.36	-124	-163	+75	+31

Nomenclature: See separate page