

JASLOVSKE BOHUNICE, Slovakia

WMO: 118190

Lat: 48.4861N

Lon: 17.6641E

Elev: 178

StdP: 99.20

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.1	-8.4	-15.6	1.0	-9.8	-12.5	1.3	-6.3	11.4	0.4	10.4	0.4	4.9	310	0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	33.3	20.9	31.4	20.1	29.6	19.5	21.9	30.2	21.1	29.1	20.3	27.8	3.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.3	14.3	25.0	18.5	13.6	24.0	17.7	13.0	23.3	64.6	30.2	61.8	28.9	59.0	27.8	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.9	8.6	7.7	-13.3	35.5	2.4	1.4	-15.1	36.4	-16.5	37.3	-17.8	38.0	-19.5	39.0		
			-13.8	23.2	2.4	0.8	-15.5	23.8	-16.9	24.3	-18.3	24.8	-20.0	25.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	-0.4	1.4	6.1	11.4	15.1	19.3	21.3	20.9	16.3	10.7	6.2	1.0
	DBStd	8.48	4.40	4.21	4.12	4.08	3.68	3.34	3.40	3.71	3.49	3.71	3.90	3.85
	HDD10.0	1173	323	242	132	32	5	0	0	1	37	122	279	
	HDD18.3	3032	582	476	381	209	111	29	12	15	81	236	363	538
	CDD10.0	1469	0	1	9	74	163	278	349	337	189	59	9	0
	CDD18.3	287	0	0	0	2	11	57	103	94	19	0	0	0
	CDH23.3	3235	0	0	0	41	127	646	1164	1066	187	4	0	0
	CDH26.7	1201	0	0	0	6	14	208	470	462	41	0	0	0
Wind	WSAvg	3.4	3.5	3.8	4.0	4.0	3.6	3.1	3.1	2.9	3.2	3.2	3.4	3.3
Precipitation	PrecAvg	579	31	28	35	43	59	65	67	53	58	45	50	45
	PrecMax	881	57	56	78	93	176	126	138	115	150	121	103	97
	PrecMin	365	4	1	2	0	19	13	10	5	13	5	22	10
	PrecStd	102	16	15	22	25	39	30	34	31	37	30	20	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	12.7	20.2	27.3	28.4	32.8	35.1	35.9	30.2	23.7	17.4	11.2
		MCWB	8.6	8.0	11.3	16.1	18.0	21.4	21.1	19.8	18.8	16.1	12.6	8.6
	2%	DB	8.5	10.6	17.8	24.1	26.3	31.1	33.0	33.9	27.7	21.3	14.8	8.9
		MCWB	6.9	7.4	10.4	14.9	17.5	20.5	20.8	20.6	18.1	15.2	11.7	7.0
	5%	DB	6.6	8.8	15.3	21.7	24.7	29.1	31.1	31.7	25.6	19.1	13.1	7.4
		MCWB	5.0	6.3	9.3	13.6	16.6	19.9	19.8	20.3	17.2	14.3	10.7	5.8
	10%	DB	5.2	7.1	13.1	19.3	22.8	27.2	29.5	29.2	23.1	17.0	11.5	6.0
		MCWB	4.0	5.3	8.3	12.6	15.7	19.1	19.3	19.5	16.3	13.3	9.4	4.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	9.1	12.1	16.7	19.8	23.1	22.4	22.5	19.9	16.8	13.3	8.9
		MCDB	10.0	12.4	18.0	24.5	26.1	30.6	31.0	30.7	27.6	21.6	16.0	10.9
	2%	WB	7.0	7.6	11.0	15.4	18.4	21.8	21.6	21.7	18.8	15.8	12.1	7.3
		MCDB	8.2	9.9	16.6	23.0	24.9	28.9	30.4	30.2	25.6	20.4	14.7	8.7
	5%	WB	5.3	6.6	9.9	14.2	17.3	20.7	20.9	20.9	17.9	14.8	10.8	6.0
		MCDB	6.4	8.6	14.5	20.2	23.0	27.4	29.0	29.5	23.7	18.5	12.7	7.3
	10%	WB	4.0	5.4	8.7	13.1	16.3	19.7	20.2	20.0	17.0	13.7	9.7	4.8
		MCDB	5.1	7.0	12.7	18.6	21.3	26.0	27.5	28.0	22.1	16.5	11.4	6.0
Mean Daily Temperature Range	5% DB	MDBR	5.3	6.5	9.9	11.4	11.1	12.0	12.7	12.3	10.6	8.7	5.9	4.7
		MCDBR	5.7	9.4	14.3	15.3	14.1	14.9	15.6	15.8	14.0	12.1	8.1	6.5
		MCWBR	4.3	6.7	8.0	7.4	6.7	6.2	5.4	5.5	5.9	6.9	5.6	5.1
	5% WB	MCDBR	5.6	8.5	12.4	13.7	12.4	13.7	13.3	14.2	12.4	11.5	7.4	6.3
		MCWBR	4.6	6.3	7.3	6.9	6.3	6.1	5.0	5.5	5.6	6.8	5.3	5.1
Clear-Sky Solar Irradiance	taub	0.322	0.345	0.383	0.428	0.425	0.426	0.436	0.435	0.408	0.379	0.356	0.320	
	taud	2.340	2.316	2.251	2.150	2.203	2.241	2.213	2.232	2.274	2.328	2.339	2.367	
	Ebn at Noon	731	798	823	819	838	839	822	804	788	746	679	682	
	Edh at Noon	71	91	114	140	138	134	135	128	111	90	72	62	
All-Sky Solar Radiation	RadAvg	0.94	1.74	2.92	4.44	5.24	5.72	5.48	4.90	3.50	2.09	1.06	0.74	
	RadStd	0.12	0.24	0.41	0.45	0.58	0.45	0.54	0.47	0.45	0.26	0.11	0.08	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (79 neighbors)	+0.57	N/A	N/A	N/A	+0.46	+0.41	-127	-172	+84	+36

Nomenclature: See separate page