

MOCHOVCE, Slovakia

WMO: 118560

Lat: 48.2889N

Lon: 18.4550E

Elev: 261

StdP: 98.23

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.7	-8.5	-14.7	1.1	-7.5	-12.0	1.4	-6.0	15.3	-0.1	13.2	0.9	2.2	110	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	33.2	21.0	31.2	20.4	29.4	19.6	22.1	30.6	21.3	29.4	20.5	27.8	3.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.5	14.7	25.5	18.6	13.9	24.3	17.8	13.2	23.5	65.9	30.7	63.0	29.3	59.9	27.9	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 12.1	10.4	8.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			-13.4	23.6	3.4	0.9	-15.9	24.3	-17.9	24.8	-19.8	25.4	-22.3	26.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	-0.5	1.9	6.4	12.0	15.6	19.8	21.5	21.4	16.6	10.9	6.4	0.7		
	DBStd	8.64	4.27	4.22	4.20	4.15	3.72	3.49	3.51	3.79	3.76	3.87	3.94	3.85		
	HDD10.0	1152	327	227	123	27	4	0	0	0	1	37	118	288		
	HDD18.3	2973	585	461	371	193	99	24	12	13	78	232	359	546		
	CDD10.0	1549	0	0	12	86	177	293	356	353	199	64	9	0		
	CDD18.3	329	0	0	0	3	14	68	110	107	26	1	0	0		
	CDH23.3	3254	0	0	0	42	154	641	1101	1103	210	4	0	0		
	CDH26.7	1183	0	0	0	5	20	205	427	477	49	0	0	0		
(14) Wind	WSAvg	3.4	3.7	3.7	3.6	3.6	3.1	2.8	2.8	2.7	3.0	3.6	4.6	3.8		
(15) Precipitation	PrecAvg	662	39	39	41	50	69	68	70	60	57	52	60	56		
	PrecMax	1039	77	83	109	108	186	154	150	140	158	119	124	152		
	PrecMin	423	2	1	4	2	27	13	11	3	8	5	31	9		
	PrecStd	121	21	20	27	27	38	35	36	40	36	33	27	34		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	13.6	20.2	27.1	28.9	33.0	34.9	36.0	30.3	23.7	16.5	10.1		
		MCWB	7.5	7.9	11.2	16.7	17.4	21.1	22.0	20.8	19.0	15.8	12.2	8.1		
	2%	DB	8.0	10.6	18.0	24.3	26.9	31.0	33.0	33.9	28.1	21.4	14.5	8.2		
		MCWB	6.6	6.8	10.5	15.0	17.6	20.6	20.9	21.2	18.3	15.1	11.1	6.7		
	5%	DB	6.3	8.7	15.4	21.9	25.1	29.0	30.8	31.6	25.8	19.1	13.0	7.0		
		MCWB	4.9	6.2	9.0	13.4	16.8	20.1	20.0	20.5	17.6	14.1	10.2	5.8		
	10%	DB	4.7	7.5	13.2	19.7	23.2	27.2	29.1	29.3	23.4	16.8	11.5	5.7		
		MCWB	3.7	5.5	7.9	12.6	15.5	19.2	19.3	19.8	16.4	13.1	9.6	4.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	9.3	12.2	17.1	19.5	23.4	22.6	22.8	20.1	16.7	13.0	8.5		
		MCDB	9.2	12.3	18.0	25.4	26.7	30.3	31.3	31.6	27.6	21.2	15.3	9.9		
	2%	WB	6.7	7.6	10.8	15.4	18.3	22.1	21.9	22.0	19.1	15.7	11.7	7.1		
		MCDB	7.7	9.3	16.5	23.2	25.0	29.3	30.3	31.2	26.2	20.1	13.7	8.1		
	5%	WB	5.2	6.7	9.8	14.2	17.3	20.7	21.2	21.2	18.2	14.8	10.8	5.9		
		MCDB	6.1	8.4	14.5	20.5	23.6	27.2	29.2	29.8	24.2	18.3	12.4	6.9		
	10%	WB	3.9	5.7	8.5	13.0	16.2	19.7	20.2	20.3	17.2	13.6	9.7	4.8		
		MCDB	4.7	7.4	12.5	18.8	21.9	26.0	27.1	28.2	22.5	16.3	11.3	5.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	6.7	9.3	10.9	11.2	11.0	11.8	12.0	10.4	8.4	5.8	4.6		
		MCDBR	5.7	8.5	13.3	14.3	13.9	13.5	14.4	15.0	13.1	11.3	8.0	5.6		
	5% WB	MCWBR	4.3	5.7	7.2	6.9	6.1	5.6	5.3	5.3	5.9	5.1	4.6			
		MCWBR	5.3	7.8	11.6	13.0	12.4	12.0	12.9	13.6	11.6	10.3	6.6	5.4		
(40) Clear-Sky Solar Irradiance	taub		0.317	0.339	0.376	0.422	0.418	0.418	0.430	0.428	0.401	0.373	0.350	0.316		
		taud	2.356	2.327	2.270	2.171	2.225	2.260	2.227	2.247	2.291	2.347	2.362	2.387		
	Ebn at Noon		743	808	832	826	846	846	829	811	796	756	691	694		
		Edh at Noon	70	90	112	137	135	131	134	126	109	88	71	61		
(44) All-Sky Solar Radiation	RadAvg		0.97	1.76	2.97	4.37	5.23	5.70	5.50	4.94	3.52	2.16	1.11	0.76		
	RadStd		0.14	0.28	0.48	0.45	0.60	0.48	0.50	0.49	0.47	0.25	0.14	0.08		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (67 neighbors)		+0.59	N/A	N/A	+0.85	+0.50	+0.44	-126	-174	+89	+41	

Nomenclature: See separate page