

DUDINCE, Slovakia

WMO: 118800

Lat: 48.167N

Lon: 18.867E

Elev: 459

StdP: 14.45

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.6	12.4	1.3	6.0	8.6	6.9	8.0	15.5	15.1	39.4	13.5	38.5	1.1	80	0.460

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.3	91.6	70.9	88.2	69.3	85.2	68.1	72.9	86.8	71.1	84.2	69.6	82.2	5.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.6	106.8	78.4	66.8	100.4	76.3	65.3	95.2	74.7	36.8	86.8	35.2	84.8	33.9	82.2	81.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.8	11.7	9.9	-1.4	95.6	8.6	3.2	-7.6	97.8	-12.7	99.7	-17.5	101.4	-23.8	103.7
			-1.9	75.6	8.5	2.5	-8.0	77.3	-13.0	78.8	-17.8	80.2	-24.1	82.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.6	29.5	33.3	41.4	51.9	60.1	66.2	69.6	69.4	60.4	50.8	41.8	31.8		
	DBStd	15.82	8.58	8.00	7.20	6.92	6.10	6.10	5.98	5.82	6.17	7.18	7.35	8.38		
	HDD50	2347	634	468	275	59	4	0	0	0	2	80	260	565		
	HDD65	5720	1099	887	731	395	174	58	23	24	163	439	697	1030		
	CDD50	2571	0	0	10	115	317	487	607	602	314	106	13	0		
	CDD65	470	0	0	0	1	22	95	165	161	26	0	0	0		
	CDH74	6044	0	0	0	62	412	1267	2045	1886	359	13	0	0		
	CDH80	2203	0	0	0	6	78	429	847	761	82	0	0	0		
(14) Wind	WSAvg	3.7	3.3	3.5	4.3	4.2	3.9	3.8	4.0	3.4	3.5	3.2	3.6	3.3		
(15) Precipitation	PrecAvg	25.1	1.7	1.5	1.5	1.7	2.5	2.8	3.1	2.4	2.1	2.0	2.1	1.9		
	PrecMax	43.4	3.2	4.6	3.7	4.4	7.0	7.6	6.1	6.7	5.5	4.1	4.6	4.8		
	PrecMin	16.5	0.1	0.1	0.0	0.2	0.6	0.5	0.4	0.2	0.0	0.0	0.3	0.4		
	PrecStd	5.2	0.8	0.9	1.0	0.9	1.5	1.6	1.6	1.7	1.4	1.1	0.9	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.6	57.9	68.6	79.7	85.8	92.4	96.2	96.8	87.0	75.5	63.8	50.8		
		MCWB	46.3	48.2	53.3	61.3	66.3	71.3	71.4	71.6	68.1	62.6	56.1	47.2		
	2%	DB	46.5	52.6	63.6	75.2	82.1	88.3	91.8	91.6	82.0	71.5	58.6	47.3		
		MCWB	43.4	46.1	50.9	58.5	65.1	70.0	70.9	70.9	65.6	60.6	52.7	44.3		
	5%	DB	43.2	48.7	59.2	71.1	78.8	85.0	88.2	87.6	78.2	67.6	55.6	44.7		
		MCWB	40.8	43.6	48.8	56.2	63.6	68.6	69.2	69.1	63.7	59.1	51.3	42.5		
	10%	DB	40.4	45.0	54.9	67.2	75.1	81.5	84.9	84.0	74.3	63.3	52.8	42.3		
		MCWB	38.3	41.4	46.5	54.4	61.9	66.9	68.0	67.7	62.1	56.6	49.5	40.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.3	49.7	54.9	62.7	68.8	74.2	74.8	75.1	69.8	64.5	57.2	47.8		
		MCDB	49.9	56.1	64.5	77.6	80.9	87.6	88.5	89.5	83.1	72.2	62.2	50.2		
	2%	WB	43.9	46.6	52.1	59.9	66.5	71.7	72.7	73.0	67.4	62.1	54.2	44.9		
		MCDB	45.7	51.5	60.9	72.1	78.7	85.0	87.1	86.6	78.4	69.8	57.7	46.7		
	5%	WB	41.1	44.1	49.9	57.6	64.7	69.9	71.0	71.0	65.4	59.8	51.8	42.8		
		MCDB	43.0	47.7	57.2	68.5	76.3	81.8	84.3	83.9	75.1	66.3	54.7	44.4		
	10%	WB	38.6	41.7	47.6	55.5	63.0	68.1	69.3	69.2	63.5	57.5	49.7	40.7		
		MCDB	40.2	44.8	53.7	65.6	73.5	79.4	81.8	81.7	71.8	62.2	52.6	42.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.0	15.6	19.8	23.3	23.4	23.7	24.3	24.4	22.0	19.1	12.8	10.5		
		MCDBR	13.2	20.8	28.2	30.8	30.1	29.3	29.9	30.2	29.0	25.2	17.8	11.8		
	5% WB	MCWBR	10.0	14.4	16.6	15.7	14.2	12.8	11.4	11.6	13.7	14.9	12.0	9.1		
		MCWBR	12.5	18.5	24.4	27.6	26.5	26.1	26.7	27.1	24.5	22.8	15.3	11.0		
(40) Clear-Sky Solar Irradiance	taub		0.325	0.348	0.387	0.437	0.430	0.431	0.444	0.442	0.413	0.384	0.359	0.324		
	taud		2.340	2.299	2.238	2.130	2.197	2.235	2.200	2.218	2.263	2.318	2.340	2.368		
	Ebn at Noon		232	253	260	257	265	265	259	253	248	236	216	217		
	Edh at Noon		23	30	37	45	44	43	44	41	36	29	23	20		
(44) All-Sky Solar Radiation	RadAvg		312	564	949	1394	1673	1820	1760	1582	1124	696	358	242		
	RadStd		45	89	153	142	190	151	154	156	148	80	43	26		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.33	N/A	N/A	+2.16	+1.22	N/A	-322	-437	+245	+124
(47) Regional (56 neighbors)		+1.08	N/A	N/A	+1.58	+0.95	+0.83	-229	-326	+166	+77

Nomenclature: See separate page