

SLIAC, Slovakia

WMO: 119030

Lat: 48.650N

Lon: 19.150E

Elev: 1033

StdP: 14.16

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.8	8.3	-1.6	5.2	5.1	3.4	6.8	11.5	19.6	32.6	16.4	35.0	0.8	0	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.7	89.2	68.8	85.9	67.3	82.6	65.6	70.5	84.5	68.7	81.7	67.2	79.3	6.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.0	99.6	76.2	64.4	94.0	73.7	62.8	88.9	72.0	35.0	84.8	33.5	81.7	32.2	79.4	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.4	14.4	12.0	DB	-3.4	93.4	7.5	3.3	-8.8	95.7	-13.2	97.6	-17.4	99.5	-22.9	101.8
			WB	-3.8	73.2	7.4	1.5	-9.2	74.2	-13.5	75.1	-17.6	76.0	-23.0	77.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.6	27.0	31.3	39.5	50.0	58.4	64.8	67.8	67.2	58.5	49.0	39.7	29.4
	DBStd	16.02	9.02	8.22	6.90	6.95	6.08	5.99	5.83	5.73	6.16	7.15	7.48	8.71
	HDD50	2723	714	523	329	83	8	0	0	0	5	107	315	639
	HDD65	6303	1179	943	791	449	217	77	38	42	209	495	759	1104
	CDD50	2227	0	0	3	84	267	443	553	535	259	77	6	0
	CDD65	331	0	0	0	0	11	69	126	111	14	0	0	0
	CDH74	4039	0	0	0	33	249	859	1437	1248	208	5	0	0
	CDH80	1297	0	0	0	2	37	255	529	436	38	0	0	0
	WSAvg	3.8	3.0	3.5	4.6	5.0	4.6	4.3	4.1	3.4	3.5	3.0	3.4	2.9
	PrecAvg	27.6	1.8	1.6	1.7	1.9	2.6	3.3	3.0	2.6	2.2	2.2	2.6	2.1
(15) Precipitation	PrecMax	42.0	5.2	5.1	4.7	4.6	6.3	6.5	7.6	6.4	8.6	7.7	6.1	5.3
	PrecMin	19.5	0.0	0.0	0.1	0.0	0.0	0.5	0.5	0.2	0.1	0.0	0.0	0.2
	PrecStd	5.2	1.1	1.1	1.1	1.1	1.5	1.4	1.7	1.5	1.6	1.7	1.4	1.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.2	54.4	66.6	78.1	84.0	89.8	94.4	93.6	84.3	73.4	60.7	48.5
		MCWB	43.9	45.5	50.8	57.9	64.2	70.0	69.3	69.2	66.0	60.4	54.1	44.7
	2%	DB	44.2	49.4	61.2	73.4	80.2	86.3	89.6	88.6	79.5	68.2	55.8	45.0
		MCWB	40.9	43.3	48.0	55.9	62.2	67.7	68.6	68.3	63.1	58.3	50.7	42.5
	5%	DB	40.9	45.7	56.1	69.2	76.7	82.7	85.8	84.6	75.5	64.4	52.9	42.6
		MCWB	38.5	40.7	45.8	54.0	61.0	65.9	67.1	66.9	61.6	56.2	49.0	40.5
	10%	DB	38.0	42.4	51.6	64.9	73.1	79.1	82.3	81.0	71.6	60.4	50.1	39.7
		MCWB	36.0	38.6	43.8	51.7	58.9	64.1	66.0	65.2	59.8	54.6	47.3	37.8
	0.4%	WB	45.4	47.3	52.4	60.0	66.4	72.3	72.4	72.5	67.5	62.0	55.1	45.6
		MCDB	47.7	52.5	63.1	74.9	79.2	85.9	87.2	87.1	80.6	69.8	59.4	47.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.3	43.9	49.5	57.1	64.1	69.4	70.2	70.3	65.3	59.5	51.8	43.1
		MCDB	43.0	48.0	58.5	69.4	76.2	82.7	84.2	84.3	76.2	66.4	55.2	44.7
	5%	WB	38.5	41.3	46.9	54.9	62.3	67.5	68.6	68.2	63.1	57.3	49.6	40.5
		MCDB	40.2	44.9	54.4	66.3	73.5	79.3	81.6	80.9	71.9	62.8	52.1	41.8
	10%	WB	36.1	38.8	44.5	53.1	60.4	65.6	67.1	66.6	61.1	55.1	47.5	38.1
		MCDB	37.7	41.7	50.4	63.0	70.3	76.3	79.2	78.3	69.1	59.5	49.7	39.4
(35) Mean Daily Temperature Range	5% DB	MDBR	12.0	16.2	19.1	23.1	23.3	23.3	23.7	24.2	21.6	18.1	11.9	10.2
		MCDBR	11.4	19.4	28.8	31.8	30.1	29.3	29.8	30.0	28.4	24.0	16.5	11.2
		MCWBR	8.6	13.4	16.6	15.8	13.9	12.7	11.5	11.8	13.6	14.1	11.3	8.9
	5% WB	MCDBR	10.4	17.0	24.6	27.8	26.7	25.8	26.7	26.5	24.0	21.3	13.7	9.3
		MCWBR	8.2	12.2	15.1	14.2	13.1	12.0	11.2	11.5	12.1	12.9	9.8	8.0
(40) Clear-Sky Solar Irradiance	taub		0.304	0.328	0.370	0.421	0.417	0.419	0.431	0.428	0.398	0.369	0.342	0.305
	taud		2.342	2.294	2.257	2.180	2.236	2.268	2.236	2.256	2.310	2.368	2.383	2.392
	Ebn at Noon		239	259	265	262	268	268	262	257	253	241	221	223
	Edh at Noon		22	29	36	43	42	41	42	39	34	27	22	19
(44) All-Sky Solar Radiation	RadAvg		301	547	921	1352	1617	1757	1690	1523	1086	661	336	237
	RadStd		48	88	155	146	194	156	169	151	154	82	46	23

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.44	N/A	N/A	+2.50	+1.69	+1.46	-315	-446	+229	+112
(47)	Regional (53 neighbors)	+1.03	N/A	N/A	+1.62	+0.86	+0.74	-223	-311	+158	+74

Nomenclature: See separate page