

SLIAC, Slovakia

WMO: 119030

Lat: 48.650N

Lon: 19.150E

Elev: 315

StdP: 97.60

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.2	-13.1	-18.7	0.7	-15.0	-15.9	1.0	-11.4	8.8	0.3	7.3	1.6	0.4	0	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	31.8	20.4	29.9	19.6	28.1	18.7	21.4	29.1	20.4	27.6	19.6	26.3	2.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	14.2	24.6	18.0	13.4	23.2	17.1	12.7	22.2	63.5	29.4	60.0	27.6	57.0	26.4	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.4	5.4	DB	-19.6	34.1	4.2	1.8	-22.7	35.4	-25.1	36.5	-27.5	37.5	-30.5	38.8	(4)
(5)			WB	-19.9	22.9	4.1	0.8	-22.9	23.5	-25.3	24.0	-27.6	24.4	-30.5	25.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.2	-2.8	-0.4	4.2	10.0	14.6	18.2	19.9	19.6	14.7	9.5	4.3	-1.5	(6)	
	DBStd	8.90	5.01	4.56	3.83	3.86	3.38	3.33	3.24	3.18	3.42	3.97	4.16	4.84	(7)	
	HDD10.0	1513	397	291	183	46	4	0	0	0	3	59	175	355	(8)	
	HDD18.3	3502	655	524	439	249	121	43	21	23	116	275	422	613	(9)	
	CDD10.0	1237	0	0	2	47	148	246	307	297	144	43	3	0	(10)	
	CDD18.3	184	0	0	0	0	6	38	70	62	8	0	0	0	(11)	
	CDH23.3	2244	0	0	0	18	138	477	798	693	116	3	0	0	(12)	
	CDH26.7	721	0	0	0	1	21	142	294	242	21	0	0	0	(13)	
(14) Wind	WSAvg	1.7	1.3	1.6	2.1	2.2	2.1	1.9	1.8	1.5	1.5	1.3	1.5	1.3	(14)	
(15) Precipitation	PrecAvg	702	45	41	43	48	65	83	75	67	55	56	65	53	(15)	
	PrecMax	1066	131	130	119	116	160	165	193	162	218	196	155	135	(16)	
	PrecMin	495	1	1	2	0	0	12	13	4	3	1	1	5	(17)	
	PrecStd	132	28	27	28	29	37	35	43	37	41	42	36	31	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	12.4	19.2	25.6	28.9	32.1	34.7	34.2	29.1	23.0	15.9	9.2	(19)	
		MCWB	6.6	7.5	10.5	14.4	17.9	21.1	20.7	20.7	18.9	15.8	12.3	7.0	(20)	
	2%	DB	6.8	9.7	16.2	23.0	26.8	30.2	32.0	31.5	26.4	20.1	13.2	7.2	(21)	
		MCWB	4.9	6.3	8.9	13.3	16.8	19.8	20.3	20.2	17.3	14.6	10.4	5.8	(22)	
	5%	DB	4.9	7.6	13.4	20.7	24.8	28.2	29.9	29.2	24.2	18.0	11.6	5.9	(23)	
		MCWB	3.6	4.8	7.6	12.2	16.1	18.8	19.5	19.4	16.4	13.5	9.5	4.7	(24)	
	10%	DB	3.4	5.8	10.9	18.3	22.8	26.1	28.0	27.2	22.0	15.8	10.1	4.3	(25)	
		MCWB	2.2	3.7	6.5	10.9	15.0	17.8	18.9	18.5	15.5	12.5	8.5	3.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.4	8.5	11.3	15.5	19.1	22.4	22.5	22.5	19.7	16.7	12.8	7.5	(27)	
		MCDB	8.7	11.4	17.3	23.8	26.2	29.9	30.7	30.6	27.0	21.0	15.2	8.6	(28)	
	2%	WB	5.2	6.6	9.7	14.0	17.8	20.8	21.2	21.3	18.5	15.3	11.0	6.1	(29)	
		MCDB	6.1	8.9	14.7	20.8	24.6	28.2	29.0	29.1	24.5	19.1	12.9	7.1	(30)	
	5%	WB	3.6	5.2	8.3	12.7	16.8	19.7	20.3	20.1	17.3	14.1	9.8	4.7	(31)	
		MCDB	4.6	7.2	12.4	19.1	23.1	26.3	27.6	27.2	22.2	17.1	11.1	5.5	(32)	
	10%	WB	2.3	3.8	6.9	11.7	15.8	18.7	19.5	19.2	16.2	12.8	8.6	3.4	(33)	
		MCDB	3.1	5.4	10.2	17.2	21.3	24.6	26.2	25.7	20.6	15.3	9.9	4.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.7	9.0	10.6	12.8	13.0	13.0	13.2	13.5	12.0	10.0	6.6	5.7	(35)	
		MCDBR	6.3	10.8	16.0	17.7	16.7	16.3	16.6	16.6	15.8	13.3	9.2	6.2	(36)	
	5% WB	MCWBR	4.8	7.4	9.2	8.8	7.7	7.1	6.4	6.6	7.6	7.8	6.3	4.9	(37)	
		MCWBR	5.8	9.4	13.7	15.4	14.8	14.3	14.8	14.7	13.3	11.8	7.6	5.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.304	0.328	0.370	0.421	0.417	0.419	0.431	0.428	0.398	0.369	0.342	0.305	(40)	
		taud	2.342	2.294	2.257	2.180	2.236	2.268	2.236	2.256	2.310	2.368	2.383	2.392	(41)	
	Ebn at Noon		753	815	836	825	845	845	827	810	798	759	698	704	(42)	
		Edh at Noon	70	92	113	135	133	130	132	124	107	86	68	59	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.95	1.73	2.90	4.26	5.10	5.54	5.33	4.80	3.42	2.08	1.06	0.75	(44)	
	RadStd		0.15	0.28	0.49	0.46	0.61	0.49	0.53	0.47	0.49	0.26	0.14	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.80	N/A	N/A	+1.39	+0.94	+0.81	-175	-248	+127	+62	(46)
(47)	Regional (53 neighbors)	+0.57	N/A	N/A	+0.90	+0.48	+0.41	-124	-173	+88	+41	(47)

Nomenclature: See separate page