

LUCENEC, Slovakia

WMO: 119270

Lat: 48.333N

Lon: 19.733E

Elev: 705

StdP: 14.33

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.0	11.7	1.4	6.1	10.1	6.3	7.8	14.0	17.6	40.4	14.7	38.7	1.0	350	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.0	89.6	69.6	86.4	68.2	83.4	66.8	71.8	84.3	70.1	82.2	68.5	79.8	5.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.0	105.4	76.8	66.2	99.0	74.7	64.6	93.6	72.8	35.9	84.4	34.4	82.4	33.1	79.8	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.7	13.2	11.2	DB	-0.1	93.6	7.2	3.7	-5.3	96.3	-9.5	98.5	-13.6	100.6	-18.8	103.3	(4)
(5)			WB	-0.3	74.5	7.4	3.2	-5.6	76.7	-10.0	78.6	-14.1	80.4	-19.5	82.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.9	28.5	32.8	40.9	51.4	59.5	66.0	69.2	68.6	59.9	50.0	40.5	30.1	(6)	
	DBStd	15.96	8.44	7.98	7.16	6.72	5.91	5.73	5.37	5.41	6.11	7.02	7.28	8.54	(7)	
	HDD50	2504	667	483	288	62	4	0	0	0	2	90	291	617	(8)	
	HDD65	5933	1132	903	746	408	186	56	21	26	174	465	734	1082	(9)	
	CDD50	2457	0	0	8	105	300	479	594	575	299	90	7	0	(10)	
	CDD65	411	0	0	0	1	16	85	151	136	22	0	0	0	(11)	
	CDH74	4700	0	0	0	33	284	982	1665	1463	267	6	0	0	(12)	
	CDH80	1515	0	0	0	3	45	289	615	512	51	0	0	0	(13)	
	Wind	WSAvg	4.2	3.9	4.2	5.0	4.9	4.6	4.2	4.3	3.8	3.8	3.5	4.2	3.6	(14)
	Precipitation	PrecAvg	27.3	1.5	1.5	1.3	2.0	3.0	3.1	3.7	2.7	2.2	2.1	1.8	(15)	
(16)		PrecMax	47.8	4.2	5.4	3.1	4.8	8.0	6.3	7.1	6.0	5.5	4.4	4.5	(16)	
(17)		PrecMin	19.0	0.1	0.0	0.0	0.2	1.0	0.9	0.4	0.2	0.1	0.2	0.3	(17)	
(18)		PrecStd	5.5	0.9	1.1	0.9	1.1	1.6	1.4	1.8	1.7	1.3	1.2	1.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.4	56.9	68.1	77.7	84.5	90.5	94.9	94.3	85.1	73.8	61.2	49.4	(19)	
		MCWB	45.0	47.5	54.7	59.9	65.0	70.4	69.6	70.0	66.0	61.2	54.6	45.3	(20)	
	2%	DB	45.6	50.9	62.4	73.4	80.5	86.8	89.8	89.5	80.5	69.5	56.6	45.8	(21)	
		MCWB	42.2	44.9	50.5	57.1	63.2	68.8	69.4	69.4	64.1	59.0	51.1	43.6	(22)	
	5%	DB	42.4	47.0	57.6	69.6	77.1	83.5	86.4	85.7	76.8	65.9	53.3	42.9	(23)	
		MCWB	39.5	42.4	47.4	55.1	62.3	67.1	68.3	68.1	62.7	57.7	49.8	41.0	(24)	
	10%	DB	39.3	43.8	53.6	65.9	73.5	80.1	83.0	82.0	73.0	61.6	50.6	40.7	(25)	
		MCWB	37.1	40.4	45.6	53.3	60.4	65.7	67.0	66.5	60.9	55.6	48.2	39.2	(26)	
	0.4%	WB	46.0	48.3	55.8	63.2	67.6	73.4	73.9	74.5	68.6	63.7	55.9	46.0	(27)	
		MCDB	49.5	53.9	65.7	73.0	79.2	86.1	85.4	87.4	81.3	70.3	59.9	47.9	(28)	
(29) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	42.5	45.5	51.2	59.0	65.5	70.8	71.6	71.7	65.9	60.6	52.6	43.7	(29)	
		MCDB	44.9	49.9	59.7	70.4	76.5	82.9	84.9	83.5	76.1	67.1	55.1	45.2	(30)	
	5%	WB	39.9	43.1	48.7	56.6	63.6	68.7	69.9	69.8	64.2	58.4	50.3	41.4	(31)	
		MCDB	42.0	46.3	55.9	67.1	73.9	80.0	82.7	81.4	73.5	64.2	52.4	42.5	(32)	
	10%	WB	37.3	40.6	46.4	54.5	61.9	67.0	68.3	68.0	62.4	56.2	48.4	39.3	(33)	
		MCDB	38.9	43.3	52.5	63.7	71.5	77.3	79.6	79.0	70.4	60.9	50.5	40.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	14.2	18.5	21.9	22.2	22.4	23.0	23.3	20.9	17.9	12.0	9.4	(35)	
		MCDBR	12.1	19.0	27.0	29.2	28.3	27.6	28.7	28.9	27.2	23.7	16.9	10.9	(36)	
		MCWBR	9.2	13.2	16.5	15.0	13.2	11.6	10.9	11.2	12.4	14.1	11.9	9.0	(37)	
	5% WB	MCDBR	11.1	17.0	23.9	25.9	24.9	24.7	25.6	25.6	22.9	21.2	14.4	9.7	(38)	
		MCWBR	8.9	12.5	15.7	14.6	12.8	11.3	11.0	11.3	11.3	13.5	10.7	8.5	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.315	0.340	0.381	0.435	0.427	0.428	0.442	0.440	0.409	0.379	0.352	0.316	(40)	
	taud		2.345	2.298	2.249	2.137	2.209	2.243	2.209	2.223	2.276	2.332	2.357	2.380	(41)	
	Ebn at Noon		235	255	262	258	266	266	259	254	250	237	218	220	(42)	
	Edh at Noon		23	30	36	45	43	42	43	41	35	29	23	19	(43)	
	RadAvg		307	555	944	1381	1659	1800	1738	1572	1117	685	352	237	(44)	
(45) All-Sky Solar Radiation	RadStd		44	89	150	142	189	146	161	149	149	82	44	25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.12	N/A	N/A	N/A	+1.60	+1.67	N/A	-373	+263	+112
(47) Regional (49 neighbors)		+1.03	N/A	N/A	+1.69	+0.95	+0.85	-220	-311	+158	+74

Nomenclature: See separate page