

LUCENEC, Slovakia

WMO: 119270

Lat: 48.333N

Lon: 19.733E

Elev: 215

StdP: 98.77

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.5	-11.3	-17.0	0.9	-12.2	-14.3	1.1	-10.0	7.9	4.7	6.6	3.7	0.4	350	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	32.0	20.9	30.2	20.1	28.6	19.3	22.1	29.1	21.2	27.9	20.3	26.6	2.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	15.1	24.9	19.0	14.1	23.7	18.1	13.4	22.7	65.7	29.1	62.2	28.0	59.1	26.5	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.0	5.9	5.0	DB	-17.8	34.2	4.0	2.1	-20.7	35.7	-23.1	36.9	-25.3	38.1	-28.2	39.6	(4)
(5)			WB	-18.0	23.6	4.1	1.8	-20.9	24.9	-23.3	25.9	-25.6	26.9	-28.6	28.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	-2.0	0.4	5.0	10.8	15.3	18.9	20.6	20.3	15.5	10.0	4.7	-1.1	(6)	
	DBStd	8.87	4.69	4.43	3.98	3.73	3.28	3.18	2.98	3.01	3.39	3.90	4.04	4.75	(7)	
	HDD10.0	1391	371	268	160	34	2	0	0	0	1	50	162	343	(8)	
	HDD18.3	3296	629	502	414	227	103	31	12	14	97	258	408	601	(9)	
	CDD10.0	1365	0	0	4	58	167	266	330	319	166	50	4	0	(10)	
	CDD18.3	228	0	0	0	1	9	47	84	76	12	0	0	0	(11)	
	CDH23.3	2611	0	0	0	18	158	546	925	813	148	3	0	0	(12)	
	CDH26.7	842	0	0	0	2	25	161	342	284	28	0	0	0	(13)	
(14) Wind	WSAvg	1.9	1.7	1.9	2.3	2.2	2.1	1.9	1.9	1.7	1.7	1.6	1.9	1.6	(14)	
(15) Precipitation	PrecAvg	693	37	37	34	50	76	78	95	69	55	56	54	45	(15)	
	PrecMax	1215	106	138	78	121	203	161	180	153	140	111	117	115	(16)	
	PrecMin	483	2	1	1	4	25	22	11	10	5	2	4	7	(17)	
	PrecStd	139	23	27	23	29	40	36	46	42	32	32	30	28	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	13.8	20.1	25.4	29.1	32.5	35.0	34.6	29.5	23.2	16.2	9.7	(19)	
		MCWB	7.2	8.6	12.6	15.5	18.3	21.3	20.9	21.1	18.9	16.2	12.5	7.4	(20)	
	2%	DB	7.5	10.5	16.9	23.0	26.9	30.5	32.1	31.9	27.0	20.8	13.7	7.7	(21)	
		MCWB	5.7	7.2	10.3	14.0	17.3	20.4	20.8	20.8	17.8	15.0	10.6	6.4	(22)	
	5%	DB	5.8	8.3	14.2	20.9	25.1	28.6	30.2	29.8	24.9	18.8	11.8	6.1	(23)	
		MCWB	4.2	5.8	8.6	12.8	16.8	19.5	20.2	20.1	17.0	14.3	9.9	5.0	(24)	
	10%	DB	4.1	6.5	12.0	18.8	23.0	26.7	28.4	27.8	22.8	16.4	10.3	4.9	(25)	
		MCWB	2.8	4.7	7.6	11.9	15.8	18.7	19.4	19.1	16.1	13.1	9.0	4.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	9.1	13.2	17.3	19.8	23.0	23.3	23.6	20.3	17.6	13.3	7.8	(27)	
		MCDB	9.7	12.2	18.7	22.8	26.2	30.0	29.6	30.8	27.4	21.3	15.5	8.8	(28)	
	2%	WB	5.8	7.5	10.6	15.0	18.6	21.5	22.0	22.1	18.8	15.9	11.4	6.5	(29)	
		MCDB	7.2	9.9	15.4	21.3	24.7	28.3	29.4	28.6	24.5	19.5	12.8	7.3	(30)	
	5%	WB	4.4	6.2	9.3	13.7	17.6	20.4	21.0	21.0	17.9	14.7	10.2	5.2	(31)	
		MCDB	5.6	7.9	13.3	19.5	23.3	26.6	28.1	27.4	23.1	17.9	11.3	5.8	(32)	
	10%	WB	2.9	4.8	8.0	12.5	16.6	19.4	20.2	20.0	16.9	13.4	9.1	4.0	(33)	
		MCDB	3.8	6.3	11.4	17.6	21.9	25.2	26.5	26.1	21.3	16.1	10.3	4.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.0	7.9	10.3	12.2	12.3	12.4	12.8	12.9	11.6	10.0	6.6	5.2	(35)	
		MCDBR	6.7	10.6	15.0	16.2	15.7	15.3	15.9	16.1	15.1	13.2	9.4	6.1	(36)	
	5% WB	MCWBR	5.1	7.3	9.2	8.3	7.3	6.5	6.0	6.2	6.9	7.8	6.6	5.0	(37)	
		MCWBR	6.2	9.5	13.3	14.4	13.8	13.7	14.2	14.2	12.7	11.8	8.0	5.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.315	0.340	0.381	0.435	0.427	0.428	0.442	0.440	0.409	0.379	0.352	0.316	(40)	
		taud	2.345	2.298	2.249	2.137	2.209	2.243	2.209	2.223	2.276	2.332	2.357	2.380	(41)	
	Ebn at Noon		742	805	825	813	837	837	818	800	788	748	687	692	(42)	
		Edh at Noon	71	93	115	142	137	133	136	129	111	90	71	61	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.97	1.75	2.98	4.35	5.23	5.68	5.48	4.96	3.52	2.16	1.11	0.75	(44)	
	RadStd		0.14	0.28	0.47	0.45	0.59	0.46	0.51	0.47	0.47	0.26	0.14	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.62	N/A	N/A	N/A	+0.89	+0.93	N/A	-207	+146	+62	(46)
(47)	Regional (49 neighbors)	+0.57	N/A	N/A	+0.94	+0.53	+0.47	-122	-173	+88	+41	(47)

Nomenclature: See separate page