

LOMNICKY STIT, Slovakia

WMO: 119300

Lat: 49.1951N

Lon: 20.2131E

Elev: 2635

StdP: 73.42

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-22.0	-20.2	-35.5	0.2	-8.0	-32.0	0.3	-9.4	25.0	-13.9	21.3	-12.1	10.2	320	1.015

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.7	13.2	9.0	11.9	8.3	10.6	7.4	10.2	12.2	9.2	11.0	8.2	10.0	3.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.3	10.1	11.0	8.3	9.4	10.1	7.3	8.8	9.2	37.3	12.2	34.5	11.1	31.9	10.1	13.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.6	16.6	14.2	DB	-25.1	15.7	2.3	1.6	-26.7	16.9	-28.1	17.8	-29.3	18.7	-31.0	19.9	(4)
(5)			WB	-25.4	12.0	2.3	1.0	-27.0	12.7	-28.3	13.3	-29.6	13.8	-31.3	14.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.8	-10.4	-10.5	-9.0	-4.5	0.0	3.5	5.3	5.6	1.6	-1.6	-5.4	-8.9	(6)
(7)		DBStd	7.33	4.86	4.84	4.72	4.38	3.88	4.05	3.68	3.55	3.88	5.06	5.29	5.18	(7)
(8)		HDD10.0	4689	632	574	590	434	311	197	151	142	253	358	462	584	(8)
(9)		HDD18.3	7721	890	807	848	684	569	445	405	396	503	617	712	843	(9)
(10)		CDD10.0	11	0	0	0	0	0	2	4	5	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	6.3	7.6	7.5	7.2	5.9	5.2	5.2	5.3	4.7	5.5	6.2	7.0	7.9	(14)
(15)	Precipitation	PrecAvg	1251	71	68	79	89	134	150	181	132	108	89	85	66	(15)
(16)		PrecMax	1631	189	171	181	174	319	244	398	233	212	158	130	164	(16)
(17)		PrecMin	936	14	14	11	16	53	70	64	48	29	15	0	22	(17)
(18)		PrecStd	171	43	33	40	38	55	46	80	56	52	41	33	33	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.1	0.6	1.2	5.7	10.2	14.4	15.2	15.2	11.0	9.9	7.2	3.1	(19)
(20)			MCWB	-4.5	-4.0	-3.6	1.9	5.9	9.1	10.4	9.7	6.5	2.1	-0.1	-3.1	(20)
(21)		2%	DB	-0.6	-1.4	-0.4	3.5	8.1	12.3	13.1	13.1	9.2	7.9	4.4	1.0	(21)
(22)			MCWB	-4.4	-4.7	-3.7	0.9	4.7	8.4	9.2	8.9	5.1	1.1	-1.3	-4.3	(22)
(23)		5%	DB	-2.3	-2.8	-1.5	2.0	6.5	10.7	11.7	11.7	7.8	6.0	2.3	-0.9	(23)
(24)			MCWB	-5.0	-5.2	-4.1	-0.1	4.0	7.2	8.4	8.3	3.9	0.6	-1.3	-4.5	(24)
(25)		10%	DB	-3.8	-4.1	-2.8	0.6	5.2	9.2	10.3	10.3	6.5	4.6	1.0	-2.2	(25)
(26)			MCWB	-5.4	-5.7	-4.5	-0.9	3.4	6.3	7.7	7.4	3.4	0.8	-1.9	-4.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.9	-2.2	-0.9	3.4	7.3	10.9	11.6	11.5	8.4	4.7	2.5	-1.1	(27)
(28)			MCDWB	-1.2	-1.6	-0.4	4.7	9.4	13.4	13.6	13.5	9.9	6.1	4.3	-0.3	(28)
(29)		2%	WB	-3.4	-3.4	-2.2	1.6	5.7	9.2	10.3	10.1	6.7	3.6	1.1	-2.3	(29)
(30)			MCDWB	-2.4	-2.3	-1.6	2.7	7.0	11.4	12.1	12.1	8.0	5.0	1.9	-1.2	(30)
(31)		5%	WB	-4.3	-4.5	-3.2	0.4	4.7	8.0	9.2	9.1	5.7	2.8	-0.2	-3.2	(31)
(32)			MCDWB	-3.1	-3.4	-2.5	1.4	5.9	10.2	10.9	10.9	6.8	4.2	0.7	-2.0	(32)
(33)		10%	WB	-5.3	-5.5	-4.3	-0.6	3.6	6.8	8.2	8.1	4.6	1.9	-1.1	-4.1	(33)
(34)			MCDWB	-3.8	-4.4	-3.3	0.3	4.8	8.5	9.8	9.8	5.6	3.5	0.3	-2.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.6	4.8	5.0	4.8	4.6	5.0	5.0	4.7	4.2	4.2	4.3	4.5	(35)
(36)			MCDBR	4.9	5.2	5.0	4.8	5.4	6.5	6.2	5.7	5.0	4.5	3.9	4.6	(36)
(37)			MCWBR	4.1	4.5	4.6	4.8	5.2	6.6	5.8	6.0	5.9	4.2	3.2	3.8	(37)
(38)		5% WB	MCDBR	5.1	5.2	4.8	4.5	5.0	6.2	5.8	5.3	4.6	4.0	3.9	4.8	(38)
(39)			MCWBR	5.2	5.2	5.0	4.6	5.0	6.3	5.6	5.6	5.5	4.6	4.2	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.212	0.229	0.257	0.294	0.295	0.298	0.306	0.303	0.282	0.261	0.241	0.212	(40)	
(41)		taud	2.422	2.409	2.442	2.465	2.494	2.496	2.459	2.477	2.531	2.588	2.574	2.479	(41)	
(42)		Ebn at Noon	898	954	972	959	966	961	947	938	931	905	857	855	(42)	
(43)		Edh at Noon	59	78	91	100	102	103	105	98	83	66	52	49	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.91	1.67	2.83	4.10	4.94	5.28	5.12	4.71	3.32	2.03	1.04	0.70	(44)	
(45)		RadStd	0.13	0.25	0.40	0.46	0.62	0.47	0.57	0.40	0.47	0.29	0.14	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.53	N/A	N/A	+0.81	+0.73	+0.73	N/A	N/A	N/A	N/A
(47) Regional (45 neighbors)		+0.57	N/A	N/A	+0.96	+0.52	+0.44	-129	-184	+89	+39

Nomenclature: See separate page