

TELGART, Slovakia

WMO: 119380

Lat: 48.850N

Lon: 20.183E

Elev: 2972

StdP: 13.18

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.1	9.0	-3.5	5.1	9.4	1.3	6.5	13.1	32.5	18.5	29.9	19.6	11.4	80	0.664

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	78.3	64.6	75.4	62.9	72.6	61.4	65.9	75.5	64.2	73.1	62.7	70.7	9.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.3	93.9	70.5	60.8	88.7	68.8	59.3	84.3	67.2	32.4	75.6	31.0	73.3	29.8	70.8	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	23.5	20.9	-0.3	82.1	4.3	2.8	-3.4	84.1	-5.9	85.8	-8.4	87.3	-11.5	89.4
			-1.1	68.3	4.3	1.7	-4.2	69.6	-6.7	70.6	-9.1	71.6	-12.2	72.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.0	24.6	27.3	33.1	43.4	51.1	57.5	60.3	60.3	51.8	44.0	35.7	26.4
	DBStd	14.62	7.64	8.05	7.79	7.14	6.31	6.19	5.60	5.74	6.40	7.73	7.83	7.58
	HDD50	3673	788	636	523	216	64	11	1	2	55	214	430	733
	HDD65	8067	1253	1056	988	648	431	235	164	168	396	650	880	1198
	CDD50	1132	0	0	0	18	98	235	320	321	110	29	1	0
	CDD65	48	0	0	0	0	0	8	18	21	1	0	0	0
	CDH74	391	0	0	0	0	5	72	142	164	8	0	0	0
	CDH80	32	0	0	0	0	0	3	13	16	0	0	0	0
Wind	WSAvg	9.2	9.9	10.8	10.2	9.5	9.2	8.3	7.9	7.8	8.5	9.0	9.4	9.5
Precipitation	PrecAvg	33.3	1.8	1.7	1.9	2.4	3.7	4.1	4.6	3.5	2.7	2.6	2.4	1.8
	PrecMax	48.0	4.7	5.5	4.4	6.4	8.6	7.1	8.0	7.6	5.2	5.0	5.1	4.9
	PrecMin	21.9	0.2	0.4	0.4	0.3	1.4	1.5	1.2	0.9	0.6	0.2	0.0	0.4
	PrecStd	5.1	1.1	1.1	1.1	1.3	1.7	1.3	2.0	1.8	1.3	1.4	1.2	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.0	48.8	57.7	68.6	74.5	79.9	81.8	81.9	74.4	66.8	55.8	44.1
		MCWB	38.9	40.9	44.3	53.8	58.6	65.6	65.3	65.0	60.9	55.9	48.0	40.9
	2%	DB	39.5	44.4	52.9	63.7	70.1	76.3	77.9	78.2	69.4	62.5	51.2	41.1
		MCWB	37.2	38.3	42.7	50.5	57.3	63.6	64.3	64.8	58.3	54.3	46.6	39.4
	5%	DB	37.2	40.4	48.2	59.3	66.9	72.8	74.8	75.1	66.1	58.5	48.5	38.6
		MCWB	35.2	36.0	40.5	48.2	55.9	61.6	62.9	63.1	56.8	52.6	45.6	37.0
	10%	DB	34.8	37.5	44.2	55.6	63.3	69.5	71.8	71.6	62.9	54.9	46.3	36.3
		MCWB	33.1	34.7	38.7	46.2	54.1	59.8	61.5	61.5	55.2	50.7	44.2	34.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.6	42.7	46.7	54.9	60.9	67.5	67.3	68.3	62.2	57.8	50.1	42.3
		MCDB	41.2	47.6	54.0	66.2	70.2	77.1	78.0	77.4	71.2	64.1	53.7	43.2
	2%	WB	37.8	39.4	43.8	51.9	58.6	64.6	65.6	65.9	59.8	55.3	47.7	39.7
		MCDB	38.8	42.6	50.3	61.1	67.7	74.0	75.4	75.3	67.2	59.7	49.8	40.5
	5%	WB	35.5	37.3	41.6	49.6	56.7	62.7	64.0	64.2	57.9	53.3	46.1	37.4
		MCDB	36.8	39.7	46.9	56.8	64.9	70.8	72.5	72.9	64.2	57.4	47.9	38.3
	10%	WB	33.3	35.2	39.2	47.5	54.9	60.9	62.5	62.4	56.1	51.3	44.2	35.1
		MCDB	34.5	36.9	43.4	53.9	62.4	67.9	70.1	70.4	61.6	54.8	46.0	36.0
Mean Daily Temperature Range	5% DB	MDBR	10.7	12.3	14.4	16.6	16.9	17.6	17.8	17.9	15.8	14.0	10.7	10.2
		MCDBR	11.2	16.0	21.0	22.9	22.1	21.9	21.5	21.6	20.0	18.6	13.9	11.7
		MCWBR	8.9	10.7	12.6	12.1	11.8	11.5	10.6	10.5	10.8	11.1	9.4	9.2
	5% WB	MCDBR	9.0	12.7	18.2	19.9	20.2	20.2	19.9	20.1	18.1	16.4	11.2	9.8
		MCWBR	7.8	9.3	11.8	11.1	11.4	11.3	10.4	10.6	10.4	10.3	8.3	8.5
Clear-Sky Solar Irradiance	taub		0.278	0.303	0.344	0.399	0.393	0.395	0.408	0.405	0.374	0.345	0.317	0.279
	taud		2.327	2.279	2.252	2.200	2.275	2.299	2.262	2.279	2.339	2.401	2.410	2.380
	Ebn at Noon		249	268	273	268	275	275	269	264	261	250	232	233
	Edh at Noon		22	29	36	42	41	40	41	38	33	26	21	18
All-Sky Solar Radiation	RadAvg		295	535	920	1334	1608	1726	1669	1532	1084	659	339	225
	RadStd		42	84	134	143	192	142	174	133	148	89	45	25

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	+1.40	N/A	N/A	N/A	N/A
Regional (49 neighbors)	+1.03	N/A	N/A	+1.67	+0.94	+0.85	-227	-326	+160	+72

Nomenclature: See separate page