

KOSICE, Slovakia

WMO: 119680

Lat: 48.663N

Lon: 21.241E

Elev: 231

StdP: 98.58

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.0	-9.8	-16.6	0.9	-10.3	-14.0	1.1	-7.7	14.1	-3.4	12.9	-3.2	3.5	10	0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	31.1	20.8	29.5	20.1	27.9	19.4	21.9	28.7	21.0	27.5	20.2	26.1	3.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.9	25.1	18.8	14.0	24.3	18.0	13.3	23.1	65.2	28.7	61.8	27.6	58.9	26.2	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.4	9.7	8.4	-14.8	33.6	2.5	1.6	-16.6	34.7	-18.1	35.7	-19.5	36.6	-21.3	37.8		
			-15.2	23.5	2.5	1.0	-17.0	24.2	-18.5	24.8	-19.9	25.3	-21.7	26.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	-2.1	0.1	4.8	10.8	15.3	18.9	20.6	20.5	15.5	10.0	4.7	-0.8
	DBStd	8.89	4.09	4.05	4.10	3.91	3.58	3.34	3.17	3.09	3.57	3.94	4.07	4.15
	HDD10.0	1410	376	277	166	36	3	0	0	0	2	51	164	336
	HDD18.3	3320	634	511	420	226	106	33	14	14	99	258	410	594
	CDD10.0	1372	0	0	4	61	167	266	329	326	166	51	4	0
	CDD18.3	241	0	0	0	1	12	49	84	81	14	0	0	0
	CDH23.3	2110	0	0	0	12	135	420	745	686	112	1	0	0
	CDH26.7	610	0	0	0	1	21	108	241	220	19	0	0	0
Wind	WSAvg	3.1	3.0	3.3	3.8	3.6	3.4	3.3	2.9	2.9	3.0	2.7	2.6	2.8
Precipitation	PrecAvg	613	24	26	28	45	68	84	87	73	51	45	48	34
	PrecMax	852	81	68	75	102	133	182	162	171	157	202	113	84
	PrecMin	419	2	0	0	9	27	24	23	8	5	2	5	5
	PrecStd	106	17	17	19	22	30	38	36	40	31	40	30	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	11.9	18.2	24.9	29.0	31.8	33.8	33.8	29.0	22.8	16.5	9.0
		MCWB	6.8	7.4	10.7	15.1	18.5	21.3	21.2	20.9	19.1	15.6	12.3	7.4
	2%	DB	6.1	9.1	15.9	22.2	26.6	29.5	31.1	31.1	26.2	20.6	13.5	7.1
		MCWB	5.2	6.2	9.2	13.5	17.6	20.4	20.7	20.7	17.5	15.0	10.7	5.9
	5%	DB	4.6	7.2	13.7	20.0	24.8	27.8	29.4	29.1	24.1	18.4	11.9	5.9
		MCWB	3.7	5.2	8.4	12.4	17.0	19.6	20.3	19.9	16.9	14.2	9.9	4.9
	10%	DB	3.1	5.7	11.3	18.0	22.7	25.9	27.5	27.1	22.1	16.1	10.3	4.7
		MCWB	2.3	4.1	7.1	11.5	16.0	18.6	19.4	19.3	16.0	12.9	8.8	3.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.3	8.5	11.6	16.0	19.7	22.6	23.0	23.3	19.7	17.1	12.9	7.6
		MCDB	8.0	11.1	16.3	23.5	26.3	29.4	30.1	29.7	26.8	20.9	15.2	8.4
	2%	WB	5.2	6.8	10.1	14.4	18.6	21.4	22.0	21.7	18.7	15.6	11.4	6.1
		MCDB	5.7	8.4	14.6	20.7	25.1	27.9	28.9	28.1	24.6	19.3	13.1	6.7
	5%	WB	3.7	5.5	8.9	13.2	17.5	20.3	21.1	20.7	17.6	14.5	10.1	4.9
		MCDB	4.3	6.8	12.9	18.5	23.6	25.9	27.5	27.3	22.9	17.6	11.4	5.5
	10%	WB	2.4	4.1	7.6	12.1	16.4	19.3	20.2	19.8	16.6	13.3	9.0	3.8
		MCDB	3.0	5.3	10.8	17.0	21.7	24.5	25.7	26.0	21.1	15.9	10.2	4.4
Mean Daily Temperature Range	5% DB	MDBR	4.9	6.2	8.7	10.1	10.4	10.6	10.9	9.7	8.6	6.1	4.2	
		MCDBR	5.8	8.7	12.5	13.8	13.7	13.2	13.6	13.7	12.9	11.8	8.8	5.1
		MCWBR	4.7	6.1	7.3	7.0	6.6	5.9	5.4	5.4	5.9	6.9	6.1	4.2
	5% WB	MCDBR	5.0	7.9	11.3	12.0	12.4	11.8	11.9	12.2	11.1	10.5	7.5	4.6
		MCWBR	4.3	6.0	7.1	6.4	6.4	5.8	5.3	5.5	5.5	6.5	5.5	3.9
Clear-Sky Solar Irradiance	taub	0.314	0.340	0.379	0.436	0.425	0.427	0.445	0.441	0.405	0.376	0.351	0.315	
	taud	2.295	2.265	2.248	2.129	2.213	2.241	2.202	2.217	2.279	2.333	2.345	2.345	
	Ebn at Noon	732	799	825	811	838	837	814	798	789	748	682	682	
	Edh at Noon	73	95	114	142	136	133	137	129	110	89	71	62	
All-Sky Solar Radiation	RadAvg	0.93	1.68	2.95	4.27	5.16	5.53	5.35	4.94	3.50	2.12	1.10	0.70	
	RadStd	0.12	0.27	0.41	0.44	0.59	0.41	0.54	0.40	0.46	0.29	0.14	0.08	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.78	N/A	N/A	+1.14	N/A	N/A	-135	-236	+126	+57
(47)	Regional (38 neighbors)	+0.62	N/A	N/A	+1.00	+0.57	+0.49	-127	-191	+97	+43

Nomenclature: See separate page