

STROPKOV TISINEC, Slovakia

WMO: 119760

Lat: 49.217N

Lon: 21.650E

Elev: 712

StdP: 14.32

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.7	10.8	-1.0	5.4	6.5	4.7	7.2	12.3	16.6	24.9	14.6	25.2	4.1	340	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.2	87.1	70.2	84.0	68.7	81.0	66.9	71.9	83.8	70.1	81.4	68.4	78.6	4.8	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.9	105.3	78.1	66.1	98.8	75.6	64.6	93.7	73.4	36.0	84.1	34.4	80.9	33.0	78.6	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.2	12.2	10.7	-2.7	91.0	6.5	3.0	-7.4	93.2	-11.2	95.0	-14.9	96.7	-19.6	98.9		
			-3.2	74.9	6.5	1.9	-7.8	76.2	-11.6	77.3	-15.2	78.4	-19.9	79.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.2	27.5	30.8	38.6	49.6	57.8	63.7	67.0	66.5	57.6	48.6	39.9	30.2
	DBStd	15.59	8.34	8.04	7.66	6.92	6.25	5.81	5.42	5.35	6.27	7.16	7.58	8.26
	HDD50	2739	696	539	357	88	10	0	0	0	8	116	311	614
	HDD65	6389	1161	959	818	462	235	91	42	44	235	509	754	1079
	CDD50	2100	0	0	4	77	251	413	528	513	235	72	7	0
	CDD65	274	0	0	0	0	11	54	105	92	12	0	0	0
	CDH74	3103	0	0	0	25	231	626	1086	989	145	1	0	0
	CDH80	852	0	0	0	1	33	152	333	307	26	0	0	0
Wind	WSAvg	4.3	4.5	4.9	5.3	5.1	4.6	4.2	3.7	3.6	3.7	3.7	4.1	4.4
Precipitation	PrecAvg	28.2	1.5	1.6	1.3	2.0	3.1	3.3	4.3	2.8	2.6	2.3	1.8	1.6
	PrecMax	41.3	3.9	3.3	3.0	4.4	8.7	5.3	8.7	7.8	5.7	5.5	3.3	3.1
	PrecMin	21.6	0.6	0.5	0.4	0.6	1.5	1.2	0.4	0.3	0.6	0.2	0.1	0.6
	PrecStd	4.0	0.7	0.7	0.7	0.9	1.4	1.1	2.2	1.6	1.2	1.4	0.8	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.4	52.0	65.1	77.7	83.9	88.4	90.6	92.3	83.6	71.9	60.7	48.7
		MCWB	44.0	44.7	50.9	59.7	66.1	70.6	71.3	70.7	67.4	59.9	53.4	45.5
	2%	DB	43.2	47.1	59.9	72.5	79.8	84.3	87.0	87.0	78.0	67.7	56.3	45.5
		MCWB	41.2	42.6	48.3	56.7	63.4	68.9	70.2	70.5	64.3	58.7	51.0	43.2
	5%	DB	40.0	43.8	55.3	68.1	76.3	80.8	83.9	83.1	73.9	63.5	53.3	42.4
		MCWB	38.1	40.2	46.1	54.3	62.1	67.1	68.9	68.4	62.4	56.5	49.7	40.8
	10%	DB	37.6	41.2	51.0	64.0	72.3	77.6	80.5	79.5	69.9	59.9	50.6	40.1
		MCWB	36.0	38.4	44.1	52.2	60.3	65.4	67.3	66.5	60.4	54.6	47.6	38.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.6	46.1	52.5	61.1	67.8	73.3	73.9	74.3	68.5	62.0	54.4	46.0
		MCDB	45.5	50.3	61.7	74.9	79.1	85.5	86.1	85.8	81.1	68.2	57.9	47.8
	2%	WB	41.7	43.1	49.5	57.9	65.3	70.6	71.8	71.8	65.8	59.5	52.0	43.4
		MCDB	43.0	46.0	57.5	69.6	76.4	81.4	84.2	83.1	75.4	65.7	55.5	45.1
	5%	WB	38.5	41.0	47.0	55.6	63.3	68.5	70.0	69.7	63.6	57.3	49.9	41.1
		MCDB	39.6	43.4	53.9	65.7	73.9	78.3	81.4	81.2	71.6	62.6	52.8	42.3
	10%	WB	36.1	38.7	44.7	53.4	61.2	66.5	68.3	67.8	61.5	55.1	47.8	38.9
		MCDB	37.3	40.9	50.7	62.5	70.4	75.2	78.4	77.5	68.3	59.5	50.3	40.0
Mean Daily Temperature Range	5% DB	MDBR	9.2	12.0	16.6	21.1	22.0	21.2	21.2	22.6	19.6	16.4	10.9	7.7
		MCDBR	8.9	16.1	25.5	30.6	30.0	27.5	27.7	28.6	26.6	22.4	15.6	9.1
		MCWBR	7.0	11.3	15.1	15.9	14.9	13.6	12.4	12.9	13.7	13.5	10.6	7.1
	5% WB	MCDBR	7.6	14.1	22.7	26.9	26.5	24.3	25.1	26.1	23.9	20.4	13.3	8.4
		MCWBR	6.5	10.5	14.3	14.4	13.9	12.8	11.9	12.6	12.9	12.7	9.5	7.0
Clear-Sky Solar Irradiance	taub	0.314	0.339	0.383	0.440	0.430	0.432	0.451	0.446	0.409	0.376	0.351	0.314	
	taud	2.259	2.219	2.216	2.115	2.199	2.228	2.189	2.205	2.268	2.331	2.333	2.319	
	Ebn at Noon	228	251	259	255	264	264	256	251	248	235	213	213	
	Edh at Noon	23	31	37	46	44	43	44	41	35	28	22	20	
All-Sky Solar Radiation	RadAvg	289	529	900	1299	1575	1680	1630	1509	1060	649	332	219	
	RadStd	41	79	117	144	197	141	178	126	149	94	43	26	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.31	N/A	N/A	+2.92	+1.67	+1.37	-304	-475	+248	+99
Regional (35 neighbors)		+1.04	N/A	N/A	+1.75	+0.99	+0.86	-225	-328	+160	+68

Nomenclature: See separate page