

MILHOSTOV, Slovakia

WMO: 119780

Lat: 48.667N

Lon: 21.733E

Elev: 348

StdP: 14.51

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.4	14.0	2.8	6.4	11.2	7.5	8.2	15.3	26.6	20.9	23.9	26.2	8.2	350	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.5	89.4	71.0	86.1	69.9	83.0	68.1	72.9	85.4	71.2	83.1	69.6	80.5	6.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.8	107.2	79.4	67.1	101.0	77.1	65.6	95.8	75.2	36.7	85.6	35.2	83.2	33.8	80.8	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.7	20.0	17.5	DB	3.9	93.6	5.4	2.7	0.0	95.5	-3.2	97.1	-6.3	98.6	-10.2	100.5	(4)
(5)			WB	3.2	75.7	5.4	1.6	-0.7	76.9	-3.9	77.8	-7.0	78.7	-10.9	79.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.2	28.6	31.7	40.9	52.0	60.2	66.3	69.4	69.5	60.3	50.1	40.6	31.1		
	DBStd	16.08	7.63	7.55	7.49	6.75	6.11	5.75	5.60	5.25	6.35	6.94	7.09	7.66		
	HDD50	2492	665	512	292	55	4	0	0	0	2	86	289	587		
	HDD65	5880	1130	932	748	391	172	53	21	18	170	461	732	1052		
	CDD50	2548	0	0	9	115	320	490	603	603	310	91	7	0		
	CDD65	459	0	0	0	1	23	92	159	156	28	0	0	0		
	CDH74	4415	0	0	0	36	310	871	1498	1444	253	3	0	0		
	CDH80	1397	0	0	0	3	52	245	535	507	55	0	0	0		
	WSAvg	6.6	6.6	7.5	7.9	7.8	7.1	6.5	6.2	6.4	6.4	5.6	5.2	6.2		
	PrecAvg	24.3	1.1	1.3	1.1	1.7	2.8	2.9	3.5	2.4	2.3	2.1	1.6	1.5		
(15) Precipitation	PrecMax	40.0	2.8	2.9	3.2	4.2	9.1	5.6	6.4	6.0	5.5	4.7	3.3	3.1		
	PrecMin	18.7	0.3	0.3	0.2	0.2	1.4	1.1	0.5	0.3	0.3	0.2	0.1	0.2		
	PrecStd	4.3	0.6	0.8	0.7	0.9	1.5	1.0	1.7	1.5	1.1	1.3	0.8	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.4	53.6	66.3	78.7	84.7	89.9	94.3	94.8	85.5	73.8	60.8	48.0		
		MCWB	45.0	46.7	52.1	62.2	66.9	72.2	71.7	71.5	67.3	61.3	54.2	45.4		
	2%	DB	43.2	48.4	61.1	72.9	81.0	86.3	89.3	89.6	80.4	69.7	56.8	44.8		
		MCWB	41.5	44.0	50.0	57.5	65.4	70.7	71.1	70.7	64.9	59.9	52.4	43.0		
	5%	DB	40.4	45.0	57.2	69.0	77.6	82.5	85.9	85.5	76.4	65.3	53.7	42.6		
		MCWB	38.9	41.7	48.0	55.6	63.9	68.5	69.9	69.6	63.4	57.6	50.7	41.1		
	10%	DB	37.9	41.9	53.0	65.3	73.6	79.2	82.4	81.9	72.4	61.1	50.7	40.6		
		MCWB	36.5	39.1	45.9	53.8	62.2	66.9	68.5	67.7	61.6	55.8	48.3	39.2		
	0.4%	WB	45.6	47.7	54.0	62.7	69.0	74.6	74.7	75.4	68.4	63.7	55.9	45.8		
		MCDB	46.8	52.9	62.5	77.2	80.8	86.6	87.7	87.6	81.9	70.9	59.2	47.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.7	44.6	51.2	59.6	66.7	72.1	72.7	72.6	66.5	60.8	53.2	43.4		
		MCDB	42.8	47.5	58.9	70.3	78.3	83.8	85.6	84.8	77.7	67.7	56.1	44.4		
	5%	WB	39.1	42.1	48.9	57.2	64.9	70.1	71.1	70.7	64.5	58.5	50.8	41.4		
		MCDB	40.4	44.6	55.4	66.1	75.7	80.1	83.3	82.8	73.4	63.9	53.3	42.4		
	10%	WB	36.7	39.3	46.5	54.9	62.9	68.2	69.5	68.9	62.7	56.3	48.5	39.3		
		MCDB	37.8	41.6	52.4	63.2	72.0	76.8	80.1	80.0	70.6	60.7	50.5	40.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	10.8	16.0	19.7	20.1	19.9	20.5	21.1	18.5	16.1	11.0	7.5		
		MCDBR	9.0	15.9	24.2	26.9	27.8	25.9	26.8	27.5	24.9	23.0	16.3	9.5		
		MCWBR	7.4	11.6	14.3	14.0	13.9	12.5	10.8	11.3	11.3	13.6	11.7	7.9		
		MCDBR	7.8	15.1	21.5	23.5	25.0	23.2	23.9	24.9	21.9	20.2	14.2	8.7		
	5% WB	MCWBR	6.7	11.5	13.5	13.0	13.1	11.9	10.6	11.5	10.6	12.7	10.7	7.6		
(40) Clear-Sky Solar Irradiance	taub		0.322	0.346	0.386	0.441	0.430	0.432	0.450	0.446	0.409	0.380	0.357	0.322		
	taud		2.276	2.248	2.232	2.119	2.206	2.236	2.194	2.208	2.272	2.324	2.328	2.323		
	Ebn at Noon		228	250	259	256	265	264	257	252	249	235	213	212		
	Edh at Noon		24	31	37	46	43	43	44	41	35	29	23	20		
(44) All-Sky Solar Radiation	RadAvg		294	535	927	1349	1635	1756	1701	1573	1107	674	350	220		
	RadStd		42	85	129	141	187	128	169	133	148	95	47	28		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.24	N/A	N/A	+2.38	N/A	N/A	-250	-376	+218	+104
(47)	Regional (38 neighbors)	+1.10	N/A	N/A	+1.76	+1.01	+0.90	-227	-342	+175	+72

Nomenclature: See separate page