

KAMENICA NAD CIROCHOU, SlovakiaWMO: **119930**Lat: **48.933N**Lon: **22.000E**Elev: **178**StdP: **99.20**Time Zone: **1.00 (EUC)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.7	-12.0	-18.6	0.7	-14.5	-15.5	1.0	-10.6	7.1	-2.0	6.3	-0.9	0.8	70	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	31.4	21.0	29.6	20.2	27.9	19.4	22.2	29.0	21.2	27.8	20.3	26.4	2.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.9	14.9	25.4	18.9	14.0	24.3	18.1	13.3	23.2	65.8	29.1	62.2	27.7	59.0	26.6	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.3	5.4	4.8	-19.5	33.7	4.3	1.8	-22.5	35.0	-25.1	36.0	-27.5	37.0	-30.6	38.3		
(5)			-19.7	23.6	4.3	1.3	-22.8	24.5	-25.3	25.2	-27.7	25.9	-30.8	26.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	-2.0	-0.2	4.2	10.1	14.5	18.1	19.8	19.6	14.5	9.6	4.9	-0.5
	DBStd	8.68	4.95	4.72	4.31	3.91	3.57	3.28	3.15	2.99	3.51	4.10	4.52	4.88
	HDD10.0	1441	371	286	184	46	6	0	0	0	3	58	163	324
	HDD18.3	3424	629	519	439	248	127	43	21	20	122	270	404	582
	CDD10.0	1238	0	0	4	47	144	244	304	299	140	47	9	0
	CDD18.3	181	0	0	0	1	8	37	67	61	8	0	0	0
	CDH23.3	2148	0	0	0	17	166	450	718	692	104	1	0	0
	CDH26.7	644	0	0	0	1	28	121	243	232	19	0	0	0
Wind	WSAvg	1.8	1.8	1.9	2.2	2.1	1.9	1.8	1.7	1.5	1.6	1.6	1.8	1.9
Precipitation	PrecAvg	766	41	44	38	53	77	81	100	79	79	62	58	54
	PrecMax	1063	92	85	112	98	194	122	190	168	174	135	90	92
	PrecMin	578	14	19	14	12	36	35	9	10	20	3	26	23
	PrecStd	100	18	18	23	22	38	27	54	39	35	39	20	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.6	12.4	18.5	25.8	29.2	32.0	33.8	34.3	28.9	22.9	17.5	11.5
		MCWB	7.6	7.8	10.4	15.3	18.0	21.1	21.4	20.4	19.6	15.8	12.2	8.2
	2%	DB	7.8	9.8	15.8	22.7	27.2	29.9	31.4	31.3	26.1	20.7	15.2	9.6
		MCWB	6.1	6.7	9.2	13.6	17.5	20.3	21.2	21.1	18.0	15.3	11.1	7.4
	5%	DB	5.9	8.0	13.6	20.3	25.2	27.8	29.4	29.2	24.0	18.7	13.6	7.3
		MCWB	4.4	5.5	8.2	12.5	16.7	19.4	20.4	20.3	17.1	14.2	10.4	5.6
	10%	DB	4.4	6.4	11.6	18.2	22.9	26.0	27.5	27.2	21.8	16.6	11.9	5.5
		MCWB	3.1	4.3	7.2	11.4	15.5	18.5	19.6	19.5	16.0	12.9	9.3	4.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	8.4	11.6	16.0	19.5	22.7	23.4	23.7	20.1	17.0	13.0	8.8
		MCDB	9.2	11.6	16.4	23.7	26.3	29.8	30.0	29.8	27.5	20.9	15.8	10.7
	2%	WB	6.3	7.0	10.0	14.5	18.2	21.4	22.1	22.2	18.9	15.7	11.8	7.4
		MCDB	7.6	9.5	14.5	21.2	25.5	27.9	29.2	28.6	24.6	19.7	14.7	9.4
	5%	WB	4.5	5.8	8.7	13.2	17.2	20.3	21.2	21.0	17.7	14.5	10.7	5.8
		MCDB	5.6	7.6	12.9	19.1	23.8	26.3	28.0	27.4	22.6	18.2	13.2	7.2
	10%	WB	3.2	4.5	7.4	12.0	16.2	19.2	20.2	20.1	16.6	13.2	9.5	4.3
		MCDB	4.3	6.3	11.2	17.2	21.9	24.7	26.1	26.3	21.0	16.3	11.8	5.5
Mean Daily Temperature Range	5% DB	MDBR	5.8	7.4	9.5	11.9	12.6	12.2	12.0	12.9	11.3	9.7	6.9	5.0
		MCDBR	5.6	9.3	13.5	16.4	17.0	15.4	15.6	16.2	15.0	13.2	9.4	6.1
		MCWBR	4.2	6.4	8.0	8.4	8.2	7.2	6.6	7.0	7.7	8.0	6.2	4.5
	5% WB	MCDBR	4.9	8.4	11.8	14.6	15.3	13.6	14.0	14.7	13.5	11.7	8.0	5.6
MCWBR		3.9	6.1	7.4	7.7	7.6	6.7	6.3	7.0	7.2	7.3	5.5	4.5	
Clear-Sky Solar Irradiance	taub	0.320	0.345	0.389	0.445	0.433	0.435	0.455	0.450	0.412	0.381	0.357	0.320	
	taud	2.241	2.202	2.195	2.098	2.188	2.220	2.177	2.190	2.256	2.312	2.311	2.299	
	Ebn at Noon	714	784	810	800	829	829	804	788	779	738	667	664	
	Edh at Noon	76	100	120	147	140	136	140	133	112	90	73	64	
All-Sky Solar Radiation	RadAvg	0.91	1.67	2.85	4.17	5.07	5.45	5.29	4.89	3.42	2.10	1.08	0.68	
	RadStd	0.14	0.26	0.39	0.45	0.60	0.42	0.54	0.43	0.48	0.31	0.15	0.09	