

USTKA, Poland

WMO: 121150

Lat: 54.5883N

Lon: 16.8542E

Elev: 36

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.4	18.0	6.5	7.7	15.7	11.5	9.9	19.9	40.3	36.2	36.3	37.7	7.8	140	0.663

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.8	80.3	65.9	75.9	65.4	72.7	64.4	69.2	75.5	67.3	72.9	65.7	71.1	9.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.0	99.3	71.9	65.1	93.1	70.3	63.6	88.2	68.8	33.3	75.1	31.8	72.9	30.6	71.1	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.0	27.9	24.5	DB	8.7	88.9	6.8	3.6	3.7	91.5	-0.3	93.6	-4.1	95.6	-9.1	98.2	(4)
(5)			WB	7.7	72.0	6.6	2.3	3.0	73.7	-0.8	75.0	-4.5	76.3	-9.2	78.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.2	32.9	34.0	37.7	45.1	52.7	59.4	64.2	64.4	58.6	50.0	41.9	36.1	(6)
(7)		DBStd	12.74	7.83	6.93	6.15	6.57	6.29	5.03	4.60	4.49	4.60	5.52	5.81	7.18	(7)
(8)		HDD50	2323	530	448	382	179	37	0	0	0	1	69	246	431	(8)
(9)		HDD65	6264	995	868	846	599	388	184	70	65	197	464	693	895	(9)
(10)		CDD50	1653	0	0	2	31	120	281	439	447	260	70	3	0	(10)
(11)		CDD65	118	0	0	0	1	6	14	44	47	6	0	0	0	(11)
(12)		CDH74	591	0	0	0	18	65	89	197	192	30	0	0	0	(12)
(13)		CDH80	145	0	0	0	3	15	23	53	48	3	0	0	0	(13)
(14)	Wind	WSAvg	11.5	12.9	12.4	12.1	11.2	10.4	11.0	10.7	10.2	10.9	11.7	11.7	12.9	(14)
(15)	Precipitation	PrecAvg	27.0	1.7	1.5	1.6	1.2	1.9	2.3	3.0	3.4	3.1	2.8	2.4	2.1	(15)
(16)		PrecMax	37.3	4.7	2.2	3.7	2.5	4.7	8.0	6.1	7.0	8.7	8.5	5.0	4.1	(16)
(17)		PrecMin	20.6	0.2	0.2	0.4	0.3	0.6	0.0	0.6	0.3	0.8	0.7	0.2	0.9	(17)
(18)		PrecStd	4.1	1.1	0.6	0.9	0.6	1.0	1.5	1.4	1.5	1.7	1.7	1.1	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.3	51.7	59.6	75.8	82.5	83.2	86.9	86.0	78.3	67.4	55.8	52.2	(19)
(20)			MCWB	46.9	46.4	48.2	58.5	63.7	64.9	69.3	68.2	62.5	57.8	51.3	49.3	(20)
(21)		2%	DB	47.0	47.8	52.8	65.8	72.4	75.1	78.9	78.8	72.6	62.8	53.0	49.2	(21)
(22)			MCWB	44.6	44.2	47.1	53.2	59.5	63.6	68.2	66.8	61.6	56.7	50.3	46.5	(22)
(23)		5%	DB	44.3	45.0	48.7	59.0	65.9	70.2	74.8	74.6	69.0	59.9	51.2	46.6	(23)
(24)			MCWB	42.5	42.1	44.4	50.3	57.5	62.5	67.0	65.5	61.4	55.6	48.8	44.4	(24)
(25)		10%	DB	42.2	42.5	45.5	53.9	61.6	67.1	71.7	71.7	66.1	57.8	49.5	44.6	(25)
(26)			MCWB	40.4	40.2	42.2	47.8	55.7	61.0	65.4	65.0	60.1	54.5	47.4	42.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.1	47.8	51.0	60.9	64.4	67.6	71.9	71.2	66.6	60.3	52.9	50.1	(27)
(28)			MCDWB	50.1	50.2	55.3	74.1	77.0	75.1	80.7	78.6	71.8	64.2	54.6	51.5	(28)
(29)		2%	WB	44.9	44.7	47.4	54.4	61.4	65.3	69.8	68.8	64.0	57.9	50.5	47.1	(29)
(30)			MCDWB	46.7	47.3	51.7	63.3	70.9	73.2	76.7	74.9	69.0	61.2	52.3	48.8	(30)
(31)		5%	WB	42.6	42.3	44.7	51.1	58.5	63.3	68.0	67.2	62.5	56.3	49.1	44.6	(31)
(32)			MCDWB	44.1	44.5	48.1	57.4	64.8	69.3	73.3	72.5	66.9	59.2	50.9	46.0	(32)
(33)		10%	WB	40.5	40.4	42.5	48.5	56.0	61.5	66.2	65.7	60.9	54.7	47.5	43.0	(33)
(34)			MCDWB	42.0	42.4	45.1	53.2	60.9	66.6	71.0	70.7	65.8	57.5	49.3	44.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.6	7.4	8.7	10.8	11.3	11.1	11.8	11.7	9.4	7.0	6.2	(35)	
(36)			MCDBR	7.5	10.1	14.5	20.2	20.3	18.0	17.9	17.8	17.6	12.6	8.2	7.1	(36)
(37)			MCWBR	6.7	7.5	9.4	11.2	10.7	10.2	9.6	9.2	9.6	8.2	6.3	6.4	(37)
(38)		5% WB	MCDBR	7.2	9.1	12.5	17.1	17.7	15.6	15.2	14.7	13.8	11.3	7.7	6.7	(38)
(39)			MCWBR	6.6	7.3	8.8	10.5	10.5	10.0	9.0	9.1	9.1	8.0	6.5	6.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.316	0.341	0.366	0.405	0.401	0.395	0.420	0.417	0.379	0.363	0.345	0.311	(40)	
(41)		taud	2.298	2.304	2.288	2.245	2.318	2.367	2.316	2.326	2.407	2.410	2.331	2.289	(41)	
(42)		Ebn at Noon	196	233	254	259	268	271	260	253	249	224	183	170	(42)	
(43)		Edh at Noon	18	25	32	38	37	36	37	35	29	23	18	15	(43)	
(44)	All-Sky Solar Radiation	RadAvg	145	349	748	1321	1726	1834	1657	1374	980	493	193	105	(44)	
(45)		RadStd	19	49	74	152	188	132	181	129	105	73	28	10	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (32 neighbors)		+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-234	+108	N/A	(47)

Nomenclature: See separate page